




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate										
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost					
1	Heavings less than 1"	2 EA	1	Heavings less than 1"	1 EA	\$ 100.00	\$	100.00	Curb Ramps	4	4	\$	11100.00	● Heavings < 1" (Excluded)***	● Heavings < 1"	
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	0	0	\$	0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	0	0	\$	0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving	
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$	0.00	Transit Stops	0	0	\$	0.00	— Heaving Clusters (Excluded)	— Heaving Clusters	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00	Accessible Parking Spaces	0	0	\$	0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:		\$	11100.00	■ Missing Sidewalk Obstruction	◆ Residential Entrance		
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00	Corridor Total:				\$	20204.00	■ Other Obstruction	✚ Commercial Entrance (within slope violation)
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00	■ Curb Ramps - Compliant	■ Curb Ramps - Adjacent	■ Island Curb Cuts - Compliant	■ Island Curb Cuts - Adjacent	■ Pole Post Hydrant Obstruction	■ Cross Slope	■ Residential Entrance (within slope violation)	
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00								■ Signals - Compliant
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Transit Stops - Non Compliant	■ Transit Stops - Adjacent	■ Utility Obstruction	■ Running Slope	■ Running Slope	
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent	■ Railroad Crossings - Compliant	■ Railroad Crossings - Adjacent	■ Vegetation Obstruction - Low	■ Running Slope	■ Running Slope	
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Railroad Crossings - Non Compliant	■ Railroad Crossings - Adjacent	■ Vegetation Obstruction - Overhead	■ Running Slope	■ Running Slope	
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00	■ Transit Stops - Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Compliant	■ Accessible Parking - Adjacent	■ Sidewalk Collection Path	■ Running Slope	■ Running Slope	
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00	■ Transit Stops - Non Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent	■ Adjacent Sidewalk Collection Path	■ Running Slope	■ Running Slope	
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent	■ Buried Sidewalk	■ Running Slope	■ Running Slope	
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent	■ Sidewalk Not Surveyed	■ Running Slope	■ Running Slope	
18	Vegetation Obstruction - Low	1 EA	18	Vegetation Obstruction - Low	1 EA	\$150.00	\$	150.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent	■ Missing Sidewalk Gap	■ Running Slope	■ Running Slope	
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00	■ Transit Stops - Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent	■ No Sidewalk on Block	■ Running Slope	■ Running Slope	
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$	0.00	■ Transit Stops - Non Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
21	Residential Entrance	3 EA	21	Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$	6000.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
22	Total Sidewalk Length Assessed	221.598 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$	0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	38.052 SY	\$ 75.00	\$	2854.00	■ Transit Stops - Non Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$	0.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00	■ Transit Stops - Non Compliant	■ Transit Stops - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00	■ Signals - Non Compliant	■ Signals - Adjacent	■ Accessible Parking - Non Compliant	■ Accessible Parking - Adjacent		■ Running Slope	■ Running Slope	
Sidewalk SubTotal:						\$	9104.00									

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.