




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate												
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost						
1	Heavings less than 1"	6 EA	1	Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps		3	3	\$ 7900.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"		
2	Heavings 1" or greater	2 EA	2	Heavings 1" or greater	2 EA	\$ 400.00	\$ 800.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"		
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving		
4	Heaving Clusters	21.356 SY	4	Heaving Clusters	21.356 SY	\$ 75.00	\$ 1602.00	Transit Stops		0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters		
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap		
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance		
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 7900.00	■	Missing Sidewalk Obstruction	◆	Residential Entrance		
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 27812.00	■	Other Obstruction	⊕	Commercial Entrance (within slope violation)		
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■	Curb Ramps - Compliant	■	Curb Ramps - Adjacent		■	Pole Post Hydrant Obstruction	⊕	Residential Entrance (within slope violation)		
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■	Curb Ramps - Non Compliant				■	Ponding Obstruction	Cross Slope			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■	Island Curb Cuts - Compliant	■	Island Curb Cuts - Adjacent		■	Sidewalk Joint Obstruction	■	2 - 3%	■	7.01 - 8%
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■	Island Curb Cuts - Non Compliant				■	Sign Obstruction	■	3.01 - 4%	■	8.01 - 9%
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■	Signals - Compliant	■	Signals - Adjacent		■	Storm Grate Obstruction	■	4.01 - 5%	■	9.01 - 10%
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	■	Signals - Non Compliant				■	Transit Obstruction	■	5.01% - 6%	■	10.01 - 12%
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■	Transit Stops - Compliant	■	Transit Stops - Adjacent		■	Traffic Obstruction	■	6.01 - 7%	■	> 12%
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	■	Transit Stops - Non Compliant				■	Tree Obstruction	Running Slope			
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■	Railroad Crossings - Compliant	■	Railroad Crossings - Adjacent		■	Utility Obstruction	■	5 - 8.33%		
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■	Railroad Crossings - Non Compliant				■	Vegetation Obstruction - Low	■	8.34% - 10%		
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■	Accessible Parking - Compliant	■	Accessible Parking - Adjacent		■	Vegetation Obstruction - Overhead	■	10.01 - 12.5%		
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■	Accessible Parking - Non Compliant				—	Sidewalk Collection Path	■	> 12.5%		
21	Residential Entrance	2 EA	21	Residential Entrance (within slope violation)	1 EA	\$ 3000.00	\$ 3000.00	■					—	Adjacent Sidewalk Collection Path				
22	Total Sidewalk Length Assessed	471.477 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	■					—	Buried Sidewalk				
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	20.424 SY	\$ 75.00	\$ 1532.00	■					—	Sidewalk Not Surveyed				
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	166.38 SY	\$ 75.00	\$ 12479.00	■					—	Missing Sidewalk Gap				
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00	■					—	No Sidewalk on Block				
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00											
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00											
				Sidewalk SubTotal:				\$ 19912.00										
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.																		
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.																		