




| ADA Survey Summary                   |            | ADA Compliance Cost Estimate *                   |            |             | Intersection Inventory & Compliance Cost Estimate |                           |             |                     |            |
|--------------------------------------|------------|--------------------------------------------------|------------|-------------|---------------------------------------------------|---------------------------|-------------|---------------------|------------|
| Item Description                     | Quantity   | Item Description                                 | Quantity   | Unit Price  | Item Cost                                         | Item Description          | Total Count | Non Compliant Count | Cost       |
| 1 Heavings less than 1"              | 8 EA       | 1 Heavings less than 1"                          | 2 EA       | \$ 100.00   | \$ 200.00                                         | Curb Ramps                | 1           | 1                   | \$ 3200.00 |
| 2 Heavings 1" or greater             | 0 EA       | 2 Heavings 1" or greater                         | 0 EA       | \$ 400.00   | \$ 0.00                                           | Island Curb Cuts          | 0           | 0                   | \$ 0.00    |
| 3 Uneven Heavings                    | 0 EA       | 3 Uneven Heavings                                | 0 EA       | \$ 400.00   | \$ 0.00                                           | Signal Push Buttons       | 0           | 0                   | \$ 0.00    |
| 4 Heaving Clusters                   | 0 SY       | 4 Heaving Clusters                               | 0 SY       | \$ 75.00    | \$ 0.00                                           | Transit Stops             | 0           | 0                   | \$ 0.00    |
| 5 Sidewalk Joint Gaps                | 0 EA       | 5 Sidewalk Joint Gaps                            | 0 EA       | \$ 200.00   | \$ 0.00                                           | Railroad Crossings        | 0           | 0                   | \$ 0.00    |
| 6 Miscellaneous Obstruction          | 0 EA       | 6 Miscellaneous Obstruction                      | 0 EA       | \$ 1500.00  | \$ 0.00                                           | Accessible Parking Spaces | 0           | 0                   | \$ 0.00    |
| 7 Missing Sidewalk Obstruction       | 0 EA       | 7 Missing Sidewalk Obstruction                   | 0 EA       | \$ 200.00   | \$ 0.00                                           | Intersection SubTotal:    |             |                     | \$ 3200.00 |
| 8 Other Obstruction                  | 0 EA       | 8 Other Obstruction                              | 0 EA       | \$ 500.00   | \$ 0.00                                           |                           |             |                     |            |
| 9 Pole Post Hydrant Obstruction      | 0 EA       | 9 Pole Post Hydrant Obstruction                  | 0 EA       | \$ 5000.00  | \$ 0.00                                           |                           |             |                     |            |
| 10 Ponding Obstruction               | 0 EA       | 10 Ponding Obstruction                           | 0 EA       | \$ 400.00   | \$ 0.00                                           |                           |             |                     |            |
| 11 Sidewalk Joint Obstruction        | 0 EA       | 11 Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00   | \$ 0.00                                           |                           |             |                     |            |
| 12 Sign Obstruction                  | 0 EA       | 12 Sign Obstruction                              | 0 EA       | \$ 150.00   | \$ 0.00                                           |                           |             |                     |            |
| 13 Storm Grate Obstruction           | 0 EA       | 13 Storm Grate Obstruction                       | 0 EA       | \$700.00    | \$ 0.00                                           |                           |             |                     |            |
| 14 Transit Obstruction               | 0 EA       | 14 Transit Obstruction                           | 0 EA       | \$500.00    | \$ 0.00                                           |                           |             |                     |            |
| 15 Traffic Obstruction               | 0 EA       | 15 Traffic Obstruction                           | 0 EA       | \$2000.00   | \$ 0.00                                           |                           |             |                     |            |
| 16 Tree Obstruction                  | 0 EA       | 16 Tree Obstruction                              | 0 EA       | \$500.00    | \$ 0.00                                           |                           |             |                     |            |
| 17 Utility Obstruction               | 0 EA       | 17 Utility Obstruction                           | 0 EA       | \$1500.00   | \$ 0.00                                           |                           |             |                     |            |
| 18 Vegetation Obstruction - Low      | 3 EA       | 18 Vegetation Obstruction - Low                  | 3 EA       | \$150.00    | \$ 450.00                                         |                           |             |                     |            |
| 19 Vegetation Obstruction - Overhead | 0 EA       | 19 Vegetation Obstruction - Overhead             | 0 EA       | \$150.00    | \$ 0.00                                           |                           |             |                     |            |
| 20 Commercial Entrance               | 0 EA       | 20 Commercial Entrance (within slope violation)  | 0 EA       | \$ 5000.00  | \$ 0.00                                           |                           |             |                     |            |
| 21 Residential Entrance              | 7 EA       | 21 Residential Entrance (within slope violation) | 7 EA       | \$ 3000.00  | \$ 21000.00                                       |                           |             |                     |            |
| 22 Total Sidewalk Length Assessed    | 706.122 LF | 22 Running Slope Violations**                    | 0 SY       | \$ 75.00    | \$ 0.00                                           |                           |             |                     |            |
| 23 Average Sidewalk Width            | 48 IN      | 23 Cross Slope Violations                        | 167.878 SY | \$ 75.00    | \$ 12591.00                                       |                           |             |                     |            |
| 24 No Sidewalk on Block (Approx.)    | 672.355 LF | 24 Running and Cross Slope Violations            | 0 SY       | \$ 75.00    | \$ 0.00                                           |                           |             |                     |            |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF       | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
| 26 Poor Surface Condition (Approx.)  | 0 LF       | 26 Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
| 27 Buried Sidewalk (Approx.)         | 0 LF       | 27 Buried Sidewalk (Approx.)                     | 0 LF       | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
|                                      |            | Sidewalk SubTotal:                               |            | \$ 34241.00 |                                                   |                           |             |                     |            |

</