




ADA Survey Summary						ADA Compliance Cost Estimate *						Intersection Inventory & Compliance Cost Estimate									
Item Description		Quantity	Item Description		Quantity	Unit Price	Item Cost	Item Description		Total Count	Non Compliant Count	Cost									
1	Heavings less than 1"	20 EA	1	Heavings less than 1"	19 EA	\$ 100.00	\$ 1900.00	Curb Ramps		4	4	\$ 11450.00		•	Heavings < 1" (Excluded)***	•	Heavings < 1"				
2	Heavings 1" or greater	2 EA	2	Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts		0	0	\$ 0.00		•	Heavings ≥ 1" (Excluded)***	•	Heavings ≥ 1"				
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00		•	Uneven Heaving (Excluded)***		Uneven Heaving				
4	Heaving Clusters	6.06 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00		—	Heaving Clusters (Excluded)	—	Heaving Clusters				
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00		▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap				
6	Miscellaneous Obstruction	2 EA	6	Miscellaneous Obstruction	2 EA	\$ 1500.00	\$ 3000.00	Accessible Parking Spaces		0	0	\$ 0.00		■	Miscellaneous Obstruction	■	Commercial Entrance				
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 11450.00		■	Missing Sidewalk Obstruction	■	Residential Entrance				
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00							■	Other Obstruction	■	Commercial Entrance (within slope violation)				
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00							■	Pole Post Hydrant Obstruction	■	Residential Entrance (within slope violation)				
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00							■	Ponding Obstruction						
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00							■	Sidewalk Joint Obstruction						
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00							■	Sign Obstruction						
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00							■	Storm Grate Obstruction						
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00							■	Transit Obstruction						
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00							■	Traffic Obstruction						
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00							■	Tree Obstruction						
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00							■	Utility Obstruction						
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00							■	Vegetation Obstruction - Low						
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00							■	Vegetation Obstruction - Overhead						
20	Commercial Entrance	1 EA	20	Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$ 5000.00							■	Sidewalk Collection Path						
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00							■	Adjacent Sidewalk Collection Path						
22	Total Sidewalk Length Assessed	1891.924 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00							■	Buried Sidewalk						
23	Average Sidewalk Width	66 IN	23	Cross Slope Violations	130.898 SY	\$ 75.00	\$ 9817.00							■	Sidewalk Not Surveyed						
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	0.555 SY	\$ 75.00	\$ 42.00							■	Missing Sidewalk Gap						
25	Missing Sidewalk Gaps (Approx.)	587.685 LF	25	Missing Sidewalk Gaps (Approx.)	587.685 LF	\$ 41.67	\$ 24420.00							■	No Sidewalk on Block						
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00														
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00														
			Sidewalk SubTotal:				\$ 20159.00														

Corridor Total:

\$ 56029.00

■

Curb Ramps - Compliant

■

Curb Ramps - Non Compliant

■

Island Curb Cuts - Compliant

■

Island Curb Cuts - Non Compliant

■

Signals - Compliant

■

Signals - Non Compliant

■

Transit Stops - Compliant

■

Transit Stops - Non Compliant

■

Railroad Crossings - Compliant

■

Railroad Crossings - Non Compliant

■

Accessible Parking - Compliant

■

Accessible Parking - Non Compliant

■

Curb Ramps - Adjacent

■

Island Curb Cuts - Adjacent

■

Signals - Adjacent

■

Transit Stops - Adjacent

■

Railroad Crossings - Adjacent

■

Accessible Parking - Adjacent

Cross Slope

■ 2 - 3% ■ 7.01 - 8%

■ 3.01 - 4% ■ 8.01 - 9%

■ 4.01 - 5% ■ 9.01 - 10%

■ 5.01% - 6% ■ 10.01 - 12%

■ 6.01 - 7% ■ > 12%

Running Slope

■ 5 - 8.33%

■ 8.34% - 10%

■ 10.01 - 12.5%

■ > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.