




| ADA Survey Summary                   |            |                                                  |            | ADA Compliance Cost Estimate * |             |  |  |
|--------------------------------------|------------|--------------------------------------------------|------------|--------------------------------|-------------|--|--|
| Item Description                     | Quantity   | Item Description                                 | Quantity   | Unit Price                     | Item Cost   |  |  |
| 1 Heavings less than 1"              | 52 EA      | 1 Heavings less than 1"                          | 7 EA       | \$ 100.00                      | \$ 700.00   |  |  |
| 2 Heavings 1" or greater             | 3 EA       | 2 Heavings 1" or greater                         | 0 EA       | \$ 400.00                      | \$ 0.00     |  |  |
| 3 Uneven Heavings                    | 0 EA       | 3 Uneven Heavings                                | 0 EA       | \$ 400.00                      | \$ 0.00     |  |  |
| 4 Heaving Clusters                   | 21.844 SY  | 4 Heaving Clusters                               | 2.27 SY    | \$ 75.00                       | \$ 170.00   |  |  |
| 5 Sidewalk Joint Gaps                | 0 EA       | 5 Sidewalk Joint Gaps                            | 0 EA       | \$ 200.00                      | \$ 0.00     |  |  |
| 6 Miscellaneous Obstruction          | 0 EA       | 6 Miscellaneous Obstruction                      | 0 EA       | \$ 1500.00                     | \$ 0.00     |  |  |
| 7 Missing Sidewalk Obstruction       | 0 EA       | 7 Missing Sidewalk Obstruction                   | 0 EA       | \$ 200.00                      | \$ 0.00     |  |  |
| 8 Other Obstruction                  | 0 EA       | 8 Other Obstruction                              | 0 EA       | \$ 500.00                      | \$ 0.00     |  |  |
| 9 Pole Post Hydrant Obstruction      | 0 EA       | 9 Pole Post Hydrant Obstruction                  | 0 EA       | \$ 5000.00                     | \$ 0.00     |  |  |
| 10 Ponding Obstruction               | 0 EA       | 10 Ponding Obstruction                           | 0 EA       | \$ 400.00                      | \$ 0.00     |  |  |
| 11 Sidewalk Joint Obstruction        | 0 EA       | 11 Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00                      | \$ 0.00     |  |  |
| 12 Sign Obstruction                  | 0 EA       | 12 Sign Obstruction                              | 0 EA       | \$ 150.00                      | \$ 0.00     |  |  |
| 13 Storm Grate Obstruction           | 0 EA       | 13 Storm Grate Obstruction                       | 0 EA       | \$700.00                       | \$ 0.00     |  |  |
| 14 Transit Obstruction               | 0 EA       | 14 Transit Obstruction                           | 0 EA       | \$500.00                       | \$ 0.00     |  |  |
| 15 Traffic Obstruction               | 0 EA       | 15 Traffic Obstruction                           | 0 EA       | \$2000.00                      | \$ 0.00     |  |  |
| 16 Tree Obstruction                  | 0 EA       | 16 Tree Obstruction                              | 0 EA       | \$500.00                       | \$ 0.00     |  |  |
| 17 Utility Obstruction               | 0 EA       | 17 Utility Obstruction                           | 0 EA       | \$1500.00                      | \$ 0.00     |  |  |
| 18 Vegetation Obstruction - Low      | 5 EA       | 18 Vegetation Obstruction - Low                  | 5 EA       | \$150.00                       | \$ 750.00   |  |  |
| 19 Vegetation Obstruction - Overhead | 1 EA       | 19 Vegetation Obstruction - Overhead             | 1 EA       | \$150.00                       | \$ 150.00   |  |  |
| 20 Commercial Entrance               | 2 EA       | 20 Commercial Entrance (within slope violation)  | 2 EA       | \$ 5000.00                     | \$ 10000.00 |  |  |
| 21 Residential Entrance              | 3 EA       | 21 Residential Entrance (within slope violation) | 2 EA       | \$ 3000.00                     | \$ 6000.00  |  |  |
| 22 Total Sidewalk Length Assessed    | 1523.47 LF | 22 Running Slope Violations**                    | 10.414 SY  | \$ 75.00                       | \$ 781.00   |  |  |
| 23 Average Sidewalk Width            | 60 IN      | 23 Cross Slope Violations                        | 633.186 SY | \$ 75.00                       | \$ 47489.00 |  |  |
| 24 No Sidewalk on Block (Approx.)    | 0 LF       | 24 Running and Cross Slope Violations            | 50.686 SY  | \$ 75.00                       | \$ 3801.00  |  |  |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF       | \$ 41.67                       | \$ 0.00     |  |  |
| 26 Poor Surface Condition (Approx.)  | 0 LF       | 26 Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67                       | \$ 0.00     |  |  |
| 27 Buried Sidewalk (Approx.)         | 0 LF       | 27 Buried Sidewalk (Approx.)                     | 0 LF       | \$ 41.67                       | \$ 0.00     |  |  |
| Sidewalk SubTotal:                   |            |                                                  |            |                                | \$ 69842.00 |  |  |

| Intersection Inventory & Compliance Cost Estimate                                                                        |                                                                                                                     |                     |             |
|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|---------------------|-------------|
| Item Description                                                                                                         | Total Count                                                                                                         | Non Compliant Count | Cost        |
| Curb Ramps                                                                                                               | 3                                                                                                                   | 3                   | \$ 7900.00  |
| Island Curb Cuts                                                                                                         | 0                                                                                                                   | 0                   | \$ 0.00     |
| Signal Push Buttons                                                                                                      | 0                                                                                                                   | 0                   | \$ 0.00     |
| Transit Stops                                                                                                            | 0                                                                                                                   | 0                   | \$ 0.00     |
| Railroad Crossings                                                                                                       | 0                                                                                                                   | 0                   | \$ 0.00     |
| Accessible Parking Spaces                                                                                                | 0                                                                                                                   | 0                   | \$ 0.00     |
| Intersection SubTotal:                                                                                                   |                                                                                                                     |                     | \$ 7900.00  |
| Corridor Total:                                                                                                          |                                                                                                                     |                     | \$ 77742.00 |
|  Curb Ramps - Compliant             |  Curb Ramps - Adjacent         |                     |             |
|  Curb Ramps - Non Compliant         |  Island Curb Cuts - Adjacent   |                     |             |
|  Island Curb Cuts - Compliant       |  Signals - Adjacent            |                     |             |
|  Island Curb Cuts - Non Compliant   |  Transit Stops - Adjacent      |                     |             |
|  Signals - Compliant                |  Railroad Crossings - Adjacent |                     |             |
|  Signals - Non Compliant            |  Accessible Parking - Adjacent |                     |             |
|  Transit Stops - Compliant          |                                                                                                                     |                     |             |
|  Transit Stops - Non Compliant      |                                                                                                                     |                     |             |
|  Railroad Crossings - Compliant     |                                                                                                                     |                     |             |
|  Railroad Crossings - Non Compliant |                                                                                                                     |                     |             |
|  Accessible Parking - Compliant     |                                                                                                                     |                     |             |
|  Accessible Parking - Non Compliant |                                                                                                                     |                     |             |

\*Note: ADA pedestrian issues corrective measure. The ADA

\*\*Note: Additional investigation

- Heavings < 1" (Excluded)\*\*\*

● Heavings ≥ 1" (Excluded)\*\*\*

● Uneven Heaving (Excluded)\*\*\*

— Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)\*\*\*

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

— Sidewalk Collection Path

— Adjacent Sidewalk Collection Path

— Buried Sidewalk

— Sidewalk Not Surveyed

— Missing Sidewalk Gap

— No Sidewalk on Block

● Heavings < 1"

● Heavings ≥ 1"

● Uneven Heaving

— Heaving Clusters

▲ Sidewalk Joint Gap

◆ Commercial Entrance

◆ Residential Entrance

■ Commercial Entrance (within slope violation)

■ Residential Entrance (within slope violation)

Cross Slope

— 2 - 3%

— 3.01 - 4%

— 4.01 - 5%

— 5.01% - 6%

— 6.01 - 7%

— 7.01 - 8%

— 8.01 - 9%

— 9.01 - 10%

— 10.01 - 12%

— > 12%

Running Slope

— 5 - 8.33%

— 8.34% - 10%

— 10.01 - 12.5%

— > 12.5%
- \*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

\*\*\*Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.