




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate										
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	Heavings < 1" (Excluded)***	Heavings < 1"	Heavings ≥ 1" (Excluded)***	Heavings ≥ 1"	Uneven Heaving (Excluded)***	Uneven Heaving	
1 Heavings less than 1"	3 EA	1 Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00	Curb Ramps	2	2	\$ 4350.00	Heaving Clusters (Excluded)	Heaving Clusters	Sidewalk Joint Gap (Excluded)***	Sidewalk Joint Gap	Miscellaneous Obstruction	Commercial Entrance	
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	Missing Sidewalk Obstruction	Residential Entrance	Other Obstruction	Commercial Entrance (within slope violation)	Pole Post Hydrant Obstruction	Residential Entrance (within slope violation)	
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	2	2	\$ 1300.00	Ponding Obstruction		Sidewalk Joint Obstruction	2 - 3%	7.01 - 8%		
4 Heaving Clusters	4.863 SY	4 Heaving Clusters	4.863 SY	\$ 75.00	\$ 365.00	Transit Stops	0	0	\$ 0.00	Sign Obstruction		Sign Obstruction	3.01 - 4%	8.01 - 9%		
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	Storm Grate Obstruction		Storm Grate Obstruction	4.01 - 5%	9.01 - 10%		
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	Transit Obstruction		Transit Obstruction	5.01% - 6%	10.01 - 12%		
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 5650.00	Traffic Obstruction		Traffic Obstruction	6.01 - 7%	> 12%		
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					Tree Obstruction				Running Slope		
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					Utility Obstruction		Utility Obstruction	5 - 8.33%	8.34% - 10%		
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					Vegetation Obstruction - Low		Vegetation Obstruction - Low	10.01 - 12.5%	> 12.5%		
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					Vegetation Obstruction - Overhead				Sidewalk Collection Path		
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					Adjacent Sidewalk Collection Path		Adjacent Sidewalk Collection Path		Buried Sidewalk		
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					Sidewalk Not Surveyed		Sidewalk Not Surveyed		Missing Sidewalk Gap		
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					Missing Sidewalk Gap		Missing Sidewalk Gap		No Sidewalk on Block		
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					No Sidewalk on Block						
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00											
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00											
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00											
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00											
20 Commercial Entrance	1 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00											
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00											
22 Total Sidewalk Length Assessed	774.041 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00											
23 Average Sidewalk Width	72 IN	23 Cross Slope Violations	207.266 SY	\$ 75.00	\$ 15545.00											
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00											
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00											
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00											
27 Buried Sidewalk (Approx.)	17.605 LF	27 Buried Sidewalk (Approx.)	17.605 LF	\$ 41.67	\$ 660.00											
		Sidewalk SubTotal:			\$ 16110.00											

Corridor Total:

\$ 21760.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

▲ Island Curb Cuts - Compliant

▲ Island Curb Cuts - Non Compliant

■ Signals - Compliant

■ Signals - Non Compliant

■ Transit Stops - Compliant

■ Transit Stops - Non Compliant

■ Railroad Crossings - Compliant

■ Railroad Crossings - Non Compliant

■ Accessible Parking - Compliant

■ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

▲ Island Curb Cuts - Adjacent

■ Signals - Adjacent

■ Transit Stops - Adjacent

■ Railroad Crossings - Adjacent

■ Accessible Parking - Adjacent

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.