




| ADA Survey Summary                   |            | ADA Compliance Cost Estimate *                   |            |            | Intersection Inventory & Compliance Cost Estimate |                           |             |                     |            |
|--------------------------------------|------------|--------------------------------------------------|------------|------------|---------------------------------------------------|---------------------------|-------------|---------------------|------------|
| Item Description                     | Quantity   | Item Description                                 | Quantity   | Unit Price | Item Cost                                         | Item Description          | Total Count | Non Compliant Count | Cost       |
| 1 Heavings less than 1"              | 4 EA       | 1 Heavings less than 1"                          | 0 EA       | \$ 100.00  | \$ 0.00                                           | Curb Ramps                | 2           | 2                   | \$ 5050.00 |
| 2 Heavings 1" or greater             | 1 EA       | 2 Heavings 1" or greater                         | 0 EA       | \$ 400.00  | \$ 0.00                                           | Island Curb Cuts          | 0           | 0                   | \$ 0.00    |
| 3 Uneven Heavings                    | 0 EA       | 3 Uneven Heavings                                | 0 EA       | \$ 400.00  | \$ 0.00                                           | Signal Push Buttons       | 0           | 0                   | \$ 0.00    |
| 4 Heaving Clusters                   | 2.869 SY   | 4 Heaving Clusters                               | 1.093 SY   | \$ 75.00   | \$ 82.00                                          | Transit Stops             | 0           | 0                   | \$ 0.00    |
| 5 Sidewalk Joint Gaps                | 0 EA       | 5 Sidewalk Joint Gaps                            | 0 EA       | \$ 200.00  | \$ 0.00                                           | Railroad Crossings        | 0           | 0                   | \$ 0.00    |
| 6 Miscellaneous Obstruction          | 0 EA       | 6 Miscellaneous Obstruction                      | 0 EA       | \$ 1500.00 | \$ 0.00                                           | Accessible Parking Spaces | 0           | 0                   | \$ 0.00    |
| 7 Missing Sidewalk Obstruction       | 0 EA       | 7 Missing Sidewalk Obstruction                   | 0 EA       | \$ 200.00  | \$ 0.00                                           | Intersection SubTotal:    |             |                     | \$ 5050.00 |
| 8 Other Obstruction                  | 0 EA       | 8 Other Obstruction                              | 0 EA       | \$ 500.00  | \$ 0.00                                           |                           |             |                     |            |
| 9 Pole Post Hydrant Obstruction      | 0 EA       | 9 Pole Post Hydrant Obstruction                  | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |                     |            |
| 10 Ponding Obstruction               | 0 EA       | 10 Ponding Obstruction                           | 0 EA       | \$ 400.00  | \$ 0.00                                           |                           |             |                     |            |
| 11 Sidewalk Joint Obstruction        | 0 EA       | 11 Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00  | \$ 0.00                                           |                           |             |                     |            |
| 12 Sign Obstruction                  | 0 EA       | 12 Sign Obstruction                              | 0 EA       | \$ 150.00  | \$ 0.00                                           |                           |             |                     |            |
| 13 Storm Grate Obstruction           | 0 EA       | 13 Storm Grate Obstruction                       | 0 EA       | \$700.00   | \$ 0.00                                           |                           |             |                     |            |
| 14 Transit Obstruction               | 0 EA       | 14 Transit Obstruction                           | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |                     |            |
| 15 Traffic Obstruction               | 0 EA       | 15 Traffic Obstruction                           | 0 EA       | \$2000.00  | \$ 0.00                                           |                           |             |                     |            |
| 16 Tree Obstruction                  | 0 EA       | 16 Tree Obstruction                              | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |                     |            |
| 17 Utility Obstruction               | 0 EA       | 17 Utility Obstruction                           | 0 EA       | \$1500.00  | \$ 0.00                                           |                           |             |                     |            |
| 18 Vegetation Obstruction - Low      | 0 EA       | 18 Vegetation Obstruction - Low                  | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |                     |            |
| 19 Vegetation Obstruction - Overhead | 0 EA       | 19 Vegetation Obstruction - Overhead             | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |                     |            |
| 20 Commercial Entrance               | 0 EA       | 20 Commercial Entrance (within slope violation)  | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |                     |            |
| 21 Residential Entrance              | 10 EA      | 21 Residential Entrance (within slope violation) | 10 EA      | \$ 3000.00 | \$ 30000.00                                       |                           |             |                     |            |
| 22 Total Sidewalk Length Assessed    | 674.106 LF | 22 Running Slope Violations**                    | 0 SY       | \$ 75.00   | \$ 0.00                                           |                           |             |                     |            |
| 23 Average Sidewalk Width            | 48 IN      | 23 Cross Slope Violations                        | 160.785 SY | \$ 75.00   | \$ 12059.00                                       |                           |             |                     |            |
| 24 No Sidewalk on Block (Approx.)    | 0 LF       | 24 Running and Cross Slope Violations            | 2.812 SY   | \$ 75.00   | \$ 211.00                                         |                           |             |                     |            |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |                     |            |
| 26 Poor Surface Condition (Approx.)  | 0 LF       | 26 Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |                     |            |
| 27 Buried Sidewalk (Approx.)         | 0 LF       | 27 Buried Sidewalk (Approx.)                     | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |                     |            |
| Sidewalk SubTotal:                   |            |                                                  |            |            | \$ 42352.00                                       |                           |             |                     |            |

Corridor Total:

\$ 47402.00

● Curb Ramps - Compliant

● Curb Ramps - Non Compliant

● Island Curb Cuts - Compliant

● Island Curb Cuts - Non Compliant

● Signals - Compliant

● Signals - Non Compliant

● Transit Stops - Compliant

● Transit Stops - Non Compliant

● Railroad Crossings - Compliant

● Railroad Crossings - Non Compliant

● Accessible Parking - Compliant

● Accessible Parking - Non Compliant

● Curb Ramps - Adjacent

● Island Curb Cuts - Adjacent

● Signals - Adjacent

● Transit Stops - Adjacent

● Railroad Crossings - Adjacent

● Accessible Parking - Adjacent

● Heavings < 1" (Excluded)\*\*\*

● Heavings ≥ 1" (Excluded)\*\*\*

● Uneven Heaving (Excluded)\*\*\*

● Heaving Clusters (Excluded)

● Sidewalk Joint Gap (Excluded)\*\*\*

● Miscellaneous Obstruction

● Missing Sidewalk Obstruction

● Other Obstruction

● Pole Post Hydrant Obstruction

● Ponding Obstruction

● Sidewalk Joint Obstruction

● Sign Obstruction

● Storm Grate Obstruction

● Transit Obstruction

● Traffic Obstruction

● Tree Obstruction

● Utility Obstruction

● Vegetation Obstruction - Low

● Vegetation Obstruction - Overhead

● Sidewalk Collection Path

● Adjacent Sidewalk Collection Path

● Buried Sidewalk

● Sidewalk Not Surveyed

● Missing Sidewalk Gap

● No Sidewalk on Block

Cross Slope

2 - 3%

3.01 - 4%

4.01 - 5%

5.01% - 6%

6.01 - 7%

7.01 - 8%

8.01 - 9%

9.01 - 10%

10.01 - 12%

> 12%

Running Slope

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

\*\*\*Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.