




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost				
1 Heavings less than 1"	7 EA		1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	1	1	\$ 1500.00	● Heavings < 1" (Excluded)***	● Heavings < 1"		
2 Heavings 1" or greater	1 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"		
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving		
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	— Heaving Clusters (Excluded)	— Heaving Clusters		
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap		
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance		
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 1500.00	■ Missing Sidewalk Obstruction	◆ Residential Entrance		
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction	✚ Commercial Entrance (within slope violation)		
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction	✚ Residential Entrance (within slope violation)		
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction			
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction			
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction			
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■ Storm Grate Obstruction			
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■ Transit Obstruction			
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■ Traffic Obstruction			
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■ Tree Obstruction			
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■ Utility Obstruction			
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Low			
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Overhead			
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					— Sidewalk Collection Path			
21 Residential Entrance	8 EA		21 Residential Entrance (within slope violation)	6 EA	\$ 3000.00	\$ 18000.00					— Adjacent Sidewalk Collection Path			
22 Total Sidewalk Length Assessed	701.323 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					— Buried Sidewalk			
23 Average Sidewalk Width	48 IN		23 Cross Slope Violations	161.818 SY	\$ 75.00	\$ 12136.00					— Sidewalk Not Surveyed			
24 No Sidewalk on Block (Approx.)	0 LF		24 Running and Cross Slope Violations	7.343 SY	\$ 75.00	\$ 551.00					— Missing Sidewalk Gap			
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					— No Sidewalk on Block			
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
			Sidewalk SubTotal:			\$ 30787.00								

Corridor Total:

\$ 32287.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

▲ Island Curb Cuts - Compliant

▲ Island Curb Cuts - Non Compliant

■ Signals - Compliant

■ Signals - Non Compliant

■ Transit Stops - Compliant

■ Transit Stops - Non Compliant

■ Railroad Crossings - Compliant

■ Railroad Crossings - Non Compliant

■ Accessible Parking - Compliant

■ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

▲ Island Curb Cuts - Adjacent

■ Signals - Adjacent

■ Transit Stops - Adjacent

■ Railroad Crossings - Adjacent

■ Accessible Parking - Adjacent

● Heavings < 1" (Excluded)***

● Heavings ≥ 1" (Excluded)***

● Uneven Heaving (Excluded)***

— Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)***

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

— Sidewalk Collection Path

— Adjacent Sidewalk Collection Path

— Buried Sidewalk

— Sidewalk Not Surveyed

— Missing Sidewalk Gap

— No Sidewalk on Block

Cross Slope

2 - 3% 7.01 - 8%

3.01 - 4% 8.01 - 9%

4.01 - 5% 9.01 - 10%

5.01% - 6% 10.01 - 12%

6.01 - 7% > 12%

Running Slope

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.