




| ADA Survey Summary                   |            | ADA Compliance Cost Estimate *                   |           |             | Intersection Inventory & Compliance Cost Estimate |                           |             |                     |            |
|--------------------------------------|------------|--------------------------------------------------|-----------|-------------|---------------------------------------------------|---------------------------|-------------|---------------------|------------|
| Item Description                     | Quantity   | Item Description                                 | Quantity  | Unit Price  | Item Cost                                         | Item Description          | Total Count | Non Compliant Count | Cost       |
| 1 Heavings less than 1"              | 5 EA       | 1 Heavings less than 1"                          | 4 EA      | \$ 100.00   | \$ 400.00                                         | Curb Ramps                | 2           | 2                   | \$ 4700.00 |
| 2 Heavings 1" or greater             | 0 EA       | 2 Heavings 1" or greater                         | 0 EA      | \$ 400.00   | \$ 0.00                                           | Island Curb Cuts          | 0           | 0                   | \$ 0.00    |
| 3 Uneven Heavings                    | 0 EA       | 3 Uneven Heavings                                | 0 EA      | \$ 400.00   | \$ 0.00                                           | Signal Push Buttons       | 0           | 0                   | \$ 0.00    |
| 4 Heaving Clusters                   | 80.427 SY  | 4 Heaving Clusters                               | 8.038 SY  | \$ 75.00    | \$ 603.00                                         | Transit Stops             | 0           | 0                   | \$ 0.00    |
| 5 Sidewalk Joint Gaps                | 0 EA       | 5 Sidewalk Joint Gaps                            | 0 EA      | \$ 200.00   | \$ 0.00                                           | Railroad Crossings        | 0           | 0                   | \$ 0.00    |
| 6 Miscellaneous Obstruction          | 0 EA       | 6 Miscellaneous Obstruction                      | 0 EA      | \$ 1500.00  | \$ 0.00                                           | Accessible Parking Spaces | 0           | 0                   | \$ 0.00    |
| 7 Missing Sidewalk Obstruction       | 0 EA       | 7 Missing Sidewalk Obstruction                   | 0 EA      | \$ 200.00   | \$ 0.00                                           | Intersection SubTotal:    |             |                     | \$ 4700.00 |
| 8 Other Obstruction                  | 0 EA       | 8 Other Obstruction                              | 0 EA      | \$ 500.00   | \$ 0.00                                           |                           |             |                     |            |
| 9 Pole Post Hydrant Obstruction      | 0 EA       | 9 Pole Post Hydrant Obstruction                  | 0 EA      | \$ 5000.00  | \$ 0.00                                           |                           |             |                     |            |
| 10 Ponding Obstruction               | 0 EA       | 10 Ponding Obstruction                           | 0 EA      | \$ 400.00   | \$ 0.00                                           |                           |             |                     |            |
| 11 Sidewalk Joint Obstruction        | 0 EA       | 11 Sidewalk Joint Obstruction                    | 0 EA      | \$ 100.00   | \$ 0.00                                           |                           |             |                     |            |
| 12 Sign Obstruction                  | 0 EA       | 12 Sign Obstruction                              | 0 EA      | \$ 150.00   | \$ 0.00                                           |                           |             |                     |            |
| 13 Storm Grate Obstruction           | 0 EA       | 13 Storm Grate Obstruction                       | 0 EA      | \$700.00    | \$ 0.00                                           |                           |             |                     |            |
| 14 Transit Obstruction               | 0 EA       | 14 Transit Obstruction                           | 0 EA      | \$500.00    | \$ 0.00                                           |                           |             |                     |            |
| 15 Traffic Obstruction               | 0 EA       | 15 Traffic Obstruction                           | 0 EA      | \$2000.00   | \$ 0.00                                           |                           |             |                     |            |
| 16 Tree Obstruction                  | 0 EA       | 16 Tree Obstruction                              | 0 EA      | \$500.00    | \$ 0.00                                           |                           |             |                     |            |
| 17 Utility Obstruction               | 0 EA       | 17 Utility Obstruction                           | 0 EA      | \$1500.00   | \$ 0.00                                           |                           |             |                     |            |
| 18 Vegetation Obstruction - Low      | 0 EA       | 18 Vegetation Obstruction - Low                  | 0 EA      | \$150.00    | \$ 0.00                                           |                           |             |                     |            |
| 19 Vegetation Obstruction - Overhead | 0 EA       | 19 Vegetation Obstruction - Overhead             | 0 EA      | \$150.00    | \$ 0.00                                           |                           |             |                     |            |
| 20 Commercial Entrance               | 0 EA       | 20 Commercial Entrance (within slope violation)  | 0 EA      | \$ 5000.00  | \$ 0.00                                           |                           |             |                     |            |
| 21 Residential Entrance              | 7 EA       | 21 Residential Entrance (within slope violation) | 3 EA      | \$ 3000.00  | \$ 9000.00                                        |                           |             |                     |            |
| 22 Total Sidewalk Length Assessed    | 691.704 LF | 22 Running Slope Violations**                    | 0 SY      | \$ 75.00    | \$ 0.00                                           |                           |             |                     |            |
| 23 Average Sidewalk Width            | 48 IN      | 23 Cross Slope Violations                        | 74.914 SY | \$ 75.00    | \$ 5619.00                                        |                           |             |                     |            |
| 24 No Sidewalk on Block (Approx.)    | 0 LF       | 24 Running and Cross Slope Violations            | 78.999 SY | \$ 75.00    | \$ 5925.00                                        |                           |             |                     |            |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF      | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
| 26 Poor Surface Condition (Approx.)  | 0 LF       | 26 Poor Surface Condition (Approx.)              | 0 LF      | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
| 27 Buried Sidewalk (Approx.)         | 0 LF       | 27 Buried Sidewalk (Approx.)                     | 0 LF      | \$ 41.67    | \$ 0.00                                           |                           |             |                     |            |
|                                      |            | Sidewalk SubTotal:                               |           | \$ 21546.00 |                                                   |                           |             |                     |            |

|                                    |                               |             |
|------------------------------------|-------------------------------|-------------|
| Corridor Total:                    |                               | \$ 26246.00 |
| Curb Ramps - Compliant             | Curb Ramps - Adjacent         |             |
| Curb Ramps - Non Compliant         |                               |             |
| Island Curb Cuts - Compliant       | Island Curb Cuts - Adjacent   |             |
| Island Curb Cuts - Non Compliant   |                               |             |
| Signals - Compliant                | Signals - Adjacent            |             |
| Signals - Non Compliant            |                               |             |
| Transit Stops - Compliant          | Transit Stops - Adjacent      |             |
| Transit Stops - Non Compliant      |                               |             |
| Railroad Crossings - Compliant     | Railroad Crossings - Adjacent |             |
| Railroad Crossings - Non Compliant |                               |             |
| Accessible Parking - Compliant     | Accessible Parking - Adjacent |             |
| Accessible Parking - Non Compliant |                               |             |

|                                   |                                               |
|-----------------------------------|-----------------------------------------------|
| Heavings < 1" (Excluded)***       | Heavings < 1"                                 |
| Heavings ≥ 1" (Excluded)***       | Heavings ≥ 1"                                 |
| Uneven Heaving (Excluded)***      | Uneven Heaving                                |
| Heaving Clusters (Excluded)       | Heaving Clusters                              |
| Sidewalk Joint Gap (Excluded)***  | Sidewalk Joint Gap                            |
| Miscellaneous Obstruction         | Commercial Entrance                           |
| Missing Sidewalk Obstruction      | Residential Entrance                          |
| Other Obstruction                 | Commercial Entrance (within slope violation)  |
| Pole Post Hydrant Obstruction     | Residential Entrance (within slope violation) |
| Ponding Obstruction               | Cross Slope                                   |
| Sidewalk Joint Obstruction        | 2 - 3%  7.01 - 8%                             |
| Sign Obstruction                  | 3.01 - 4%  8.01 - 9%                          |
| Storm Grate Obstruction           | 4.01 - 5%  9.01 - 10%                         |
| Transit Obstruction               | 5.01% - 6%  10.01 - 12%                       |
| Traffic Obstruction               | 6.01 - 7%  > 12%                              |
| Tree Obstruction                  | Running Slope                                 |
| Utility Obstruction               | 5 - 8.33%                                     |
| Vegetation Obstruction - Low      | 8.34% - 10%                                   |
| Vegetation Obstruction - Overhead | 10.01 - 12.5%                                 |
| Sidewalk Collection Path          | > 12.5%                                       |
| Adjacent Sidewalk Collection Path |                                               |
| Buried Sidewalk                   |                                               |
| Sidewalk Not Surveyed             |                                               |
| Missing Sidewalk Gap              |                                               |
| No Sidewalk on Block              |                                               |

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.