




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	28 EA	1	Heavings less than 1"	6 EA	\$ 100.00	\$ 600.00	Curb Ramps		2	2	\$ 5050.00	●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	2 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***
4	Heaving Clusters	2.22 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	—	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 5050.00	■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:		\$ 112661.00				
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■	Curb Ramps - Compliant	■	Curb Ramps - Adjacent			
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■	Curb Ramps - Non Compliant	■	Island Curb Cuts - Adjacent			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■	Island Curb Cuts - Compliant	■	Signals - Adjacent			
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■	Island Curb Cuts - Non Compliant	■	Transit Stops - Adjacent			
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■	Signals - Compliant	■	Railroad Crossings - Adjacent			
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	■	Signals - Non Compliant	■	Accessible Parking - Adjacent			
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■	Transit Stops - Compliant	■				
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	■	Transit Stops - Non Compliant	■				
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■	Railroad Crossings - Compliant	■				
18	Vegetation Obstruction - Low	1 EA	18	Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00	■	Railroad Crossings - Non Compliant	■				
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■	Accessible Parking - Compliant	■				
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■	Accessible Parking - Non Compliant	■				
21	Residential Entrance	14 EA	21	Residential Entrance (within slope violation)	12 EA	\$ 3000.00	\$ 36000.00							
22	Total Sidewalk Length Assessed	1338.242 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00							
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	303.05 SY	\$ 75.00	\$ 22729.00							
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	78.566 SY	\$ 75.00	\$ 5892.00							
25	Missing Sidewalk Gaps (Approx.)	1011.497 LF	25	Missing Sidewalk Gaps (Approx.)	1011.497 LF	\$ 41.67	\$ 42240.00							
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00							
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00							
			Sidewalk SubTotal:				\$ 65371.00							

Cross Slope

2 - 3% 3.01 - 4% 4.01 - 5% 5.01% - 6% 6.01 - 7% 7.01 - 8% 8.01 - 9% 9.01 - 10% 10.01 - 12% > 12%

Running Slope

5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.