




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost					
1 Heavings less than 1"	3 EA		1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	6	6	\$ 17500.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"	
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"	
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving	
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters	
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap	
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	■	Commercial Entrance	
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 17500.00	■	Missing Sidewalk Obstruction	■	Residential Entrance	
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 28065.00	■	Other Obstruction	■	Commercial Entrance (within slope violation)
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■ Curb Ramps - Compliant				■	Pole Post Hydrant Obstruction	■	Residential Entrance (within slope violation)	
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■ Curb Ramps - Non Compliant				■	Ponding Obstruction		Cross Slope	
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■ Island Curb Cuts - Compliant				■	Sidewalk Joint Obstruction	■	2 - 3%	7.01 - 8%
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■ Island Curb Cuts - Non Compliant				■	Sign Obstruction	■	3.01 - 4%	8.01 - 9%
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Signals - Compliant				■	Storm Grate Obstruction	■	4.01 - 5%	9.01 - 10%
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Non Compliant				■	Transit Obstruction	■	5.01% - 6%	10.01 - 12%
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Transit Stops - Compliant				■	Traffic Obstruction	■	6.01 - 7%	> 12%
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Transit Stops - Non Compliant				■	Tree Obstruction		Running Slope	
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■ Railroad Crossings - Compliant				■	Utility Obstruction	■	5 - 8.33%	
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■ Railroad Crossings - Non Compliant				■	Vegetation Obstruction - Low	■	8.34% - 10%	
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■ Accessible Parking - Compliant				■	Vegetation Obstruction - Overhead	■	10.01 - 12.5%	
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■ Accessible Parking - Non Compliant				—	Sidewalk Collection Path	—	> 12.5%	
21 Residential Entrance	0 EA		21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						—	Adjacent Sidewalk Collection Path		
22 Total Sidewalk Length Assessed	382.105 LF		22 Running Slope Violations**	14.699 SY	\$ 75.00	\$ 1102.00						—	Buried Sidewalk		
23 Average Sidewalk Width	48 IN		23 Cross Slope Violations	103.141 SY	\$ 75.00	\$ 7736.00						—	Sidewalk Not Surveyed		
24 No Sidewalk on Block (Approx.)	0 LF		24 Running and Cross Slope Violations	23.024 SY	\$ 75.00	\$ 1727.00						—	Missing Sidewalk Gap		
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						—	No Sidewalk on Block		
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00									
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00									
			Sidewalk SubTotal:		\$ 10565.00										
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.															
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.															
***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.															