




| ADA Survey Summary |                                   |            | ADA Compliance Cost Estimate * |                                               |           | Intersection Inventory & Compliance Cost Estimate |             |                           |             |             |                     |            |
|--------------------|-----------------------------------|------------|--------------------------------|-----------------------------------------------|-----------|---------------------------------------------------|-------------|---------------------------|-------------|-------------|---------------------|------------|
| Item               | Description                       | Quantity   | Item                           | Description                                   | Quantity  | Unit Price                                        | Item Cost   | Item                      | Description | Total Count | Non Compliant Count | Cost       |
| 1                  | Heavings less than 1"             | 1 EA       | 1                              | Heavings less than 1"                         | 0 EA      | \$ 100.00                                         | \$ 0.00     | Curb Ramps                |             | 4           | 4                   | \$ 8500.00 |
| 2                  | Heavings 1" or greater            | 0 EA       | 2                              | Heavings 1" or greater                        | 0 EA      | \$ 400.00                                         | \$ 0.00     | Island Curb Cuts          |             | 1           | 1                   | \$ 2400.00 |
| 3                  | Uneven Heavings                   | 0 EA       | 3                              | Uneven Heavings                               | 0 EA      | \$ 400.00                                         | \$ 0.00     | Signal Push Buttons       |             | 2           | 2                   | \$ 2600.00 |
| 4                  | Heaving Clusters                  | 0 SY       | 4                              | Heaving Clusters                              | 0 SY      | \$ 75.00                                          | \$ 0.00     | Transit Stops             |             | 0           | 0                   | \$ 0.00    |
| 5                  | Sidewalk Joint Gaps               | 0 EA       | 5                              | Sidewalk Joint Gaps                           | 0 EA      | \$ 200.00                                         | \$ 0.00     | Railroad Crossings        |             | 0           | 0                   | \$ 0.00    |
| 6                  | Miscellaneous Obstruction         | 0 EA       | 6                              | Miscellaneous Obstruction                     | 0 EA      | \$ 1500.00                                        | \$ 0.00     | Accessible Parking Spaces |             | 0           | 0                   | \$ 0.00    |
| 7                  | Missing Sidewalk Obstruction      | 0 EA       | 7                              | Missing Sidewalk Obstruction                  | 0 EA      | \$ 200.00                                         | \$ 0.00     | Intersection SubTotal:    |             |             | \$                  | 13500.00   |
| 8                  | Other Obstruction                 | 0 EA       | 8                              | Other Obstruction                             | 0 EA      | \$ 500.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 9                  | Pole Post Hydrant Obstruction     | 0 EA       | 9                              | Pole Post Hydrant Obstruction                 | 0 EA      | \$ 5000.00                                        | \$ 0.00     |                           |             |             |                     |            |
| 10                 | Ponding Obstruction               | 0 EA       | 10                             | Ponding Obstruction                           | 0 EA      | \$ 400.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 11                 | Sidewalk Joint Obstruction        | 0 EA       | 11                             | Sidewalk Joint Obstruction                    | 0 EA      | \$ 100.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 12                 | Sign Obstruction                  | 0 EA       | 12                             | Sign Obstruction                              | 0 EA      | \$ 150.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 13                 | Storm Grate Obstruction           | 0 EA       | 13                             | Storm Grate Obstruction                       | 0 EA      | \$700.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 14                 | Transit Obstruction               | 0 EA       | 14                             | Transit Obstruction                           | 0 EA      | \$500.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 15                 | Traffic Obstruction               | 0 EA       | 15                             | Traffic Obstruction                           | 0 EA      | \$2000.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 16                 | Tree Obstruction                  | 0 EA       | 16                             | Tree Obstruction                              | 0 EA      | \$500.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 17                 | Utility Obstruction               | 0 EA       | 17                             | Utility Obstruction                           | 0 EA      | \$1500.00                                         | \$ 0.00     |                           |             |             |                     |            |
| 18                 | Vegetation Obstruction - Low      | 0 EA       | 18                             | Vegetation Obstruction - Low                  | 0 EA      | \$150.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 19                 | Vegetation Obstruction - Overhead | 0 EA       | 19                             | Vegetation Obstruction - Overhead             | 0 EA      | \$150.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 20                 | Commercial Entrance               | 0 EA       | 20                             | Commercial Entrance (within slope violation)  | 0 EA      | \$ 5000.00                                        | \$ 0.00     |                           |             |             |                     |            |
| 21                 | Residential Entrance              | 0 EA       | 21                             | Residential Entrance (within slope violation) | 0 EA      | \$ 3000.00                                        | \$ 0.00     |                           |             |             |                     |            |
| 22                 | Total Sidewalk Length Assessed    | 731.279 LF | 22                             | Running Slope Violations**                    | 4.035 SY  | \$ 75.00                                          | \$ 303.00   |                           |             |             |                     |            |
| 23                 | Average Sidewalk Width            | 60 IN      | 23                             | Cross Slope Violations                        | 172.05 SY | \$ 75.00                                          | \$ 12904.00 |                           |             |             |                     |            |
| 24                 | No Sidewalk on Block (Approx.)    | 0 LF       | 24                             | Running and Cross Slope Violations            | 0 SY      | \$ 75.00                                          | \$ 0.00     |                           |             |             |                     |            |
| 25                 | Missing Sidewalk Gaps (Approx.)   | 0 LF       | 25                             | Missing Sidewalk Gaps (Approx.)               | 0 LF      | \$ 41.67                                          | \$ 0.00     |                           |             |             |                     |            |
| 26                 | Poor Surface Condition (Approx.)  | 0 LF       | 26                             | Poor Surface Condition (Approx.)              | 0 LF      | \$ 41.67                                          | \$ 0.00     |                           |             |             |                     |            |
| 27                 | Buried Sidewalk (Approx.)         | 0 LF       | 27                             | Buried Sidewalk (Approx.)                     | 0 LF      | \$ 41.67                                          | \$ 0.00     |                           |             |             |                     |            |
|                    |                                   |            |                                | Sidewalk SubTotal:                            |           |                                                   | \$ 13206.00 |                           |             |             |                     |            |

<