




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate					
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	
1 Heavings less than 1"	5 EA		1 Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00	Curb Ramps	1	1	\$ 3200.00	● Heavings < 1" (Excluded)***
2 Heavings 1" or greater	1 EA		2 Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	● Heaving Clusters (Excluded)
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 3200.00		■ Missing Sidewalk Obstruction
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■ Storm Grate Obstruction
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■ Transit Obstruction
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■ Traffic Obstruction
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■ Tree Obstruction
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■ Utility Obstruction
18 Vegetation Obstruction - Low	2 EA		18 Vegetation Obstruction - Low	2 EA	\$150.00	\$ 300.00					■ Vegetation Obstruction - Low
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Overhead
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					■ Sidewalk Collection Path
21 Residential Entrance	5 EA		21 Residential Entrance (within slope violation)	5 EA	\$ 3000.00	\$ 15000.00					■ Adjacent Sidewalk Collection Path
22 Total Sidewalk Length Assessed	490.568 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					■ Buried Sidewalk
23 Average Sidewalk Width	60 IN		23 Cross Slope Violations	77.005 SY	\$ 75.00	\$ 5775.00					■ Sidewalk Not Surveyed
24 No Sidewalk on Block (Approx.)	479.379 LF		24 Running and Cross Slope Violations	110.014 SY	\$ 75.00	\$ 8251.00					■ Missing Sidewalk Gap
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					■ No Sidewalk on Block
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00					
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00					
			Sidewalk SubTotal:			\$ 29926.00					
Corridor Total: \$ 33126.00 ■ Curb Ramps - Compliant ■ Curb Ramps - Non Compliant ■ Island Curb Cuts - Compliant ■ Island Curb Cuts - Non Compliant ■ Signals - Compliant ■ Signals - Non Compliant ■ Transit Stops - Compliant ■ Transit Stops - Non Compliant ■ Railroad Crossings - Compliant ■ Railroad Crossings - Non Compliant ■ Accessible Parking - Compliant ■ Accessible Parking - Non Compliant ■ Curb Ramps - Adjacent ■ Island Curb Cuts - Adjacent ■ Signals - Adjacent ■ Transit Stops - Adjacent ■ Railroad Crossings - Adjacent ■ Accessible Parking - Adjacent											
● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)*** ● Heaving Clusters (Excluded) ▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead ■ Sidewalk Collection Path ■ Adjacent Sidewalk Collection Path ■ Buried Sidewalk ■ Sidewalk Not Surveyed ■ Missing Sidewalk Gap ■ No Sidewalk on Block ● Heavings < 1" ● Heavings ≥ 1" ● Uneven Heaving ● Heaving Clusters ▲ Sidewalk Joint Gap ◆ Commercial Entrance ◆ Residential Entrance ✚ Commercial Entrance (within slope violation) ✚ Residential Entrance (within slope violation) Cross Slope 2 - 3% 7.01 - 8% 3.01 - 4% 8.01 - 9% 4.01 - 5% 9.01 - 10% 5.01% - 6% 10.01 - 12% 6.01 - 7% > 12% Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%											
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. **Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.											