




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate										
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost					
1	Heavings less than 1"	5 EA	1	Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	0	0	\$ 0.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"		
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"		
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving		
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters		
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap		
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance		
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 0.00	■	Missing Sidewalk Obstruction	◆	Residential Entrance		
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■	Other Obstruction	✚	Commercial Entrance (within slope violation)		
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■	Pole Post Hydrant Obstruction	✚	Residential Entrance (within slope violation)		
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■	Ponding Obstruction				
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■	Sidewalk Joint Obstruction	2 - 3%	7.01 - 8%		
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■	Sign Obstruction	3.01 - 4%	8.01 - 9%		
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■	Storm Grate Obstruction	4.01 - 5%	9.01 - 10%		
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00					■	Transit Obstruction	5.01% - 6%	10.01 - 12%		
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■	Traffic Obstruction	6.01 - 7%	> 12%		
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00					■	Tree Obstruction				
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■	Utility Obstruction	5 - 8.33%			
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■	Vegetation Obstruction - Low	8.34% - 10%			
19	Vegetation Obstruction - Overhead	2 EA	19	Vegetation Obstruction - Overhead	2 EA	\$150.00	\$ 300.00					■	Vegetation Obstruction - Overhead	10.01 - 12.5%			
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					—	Sidewalk Collection Path	> 12.5%			
21	Residential Entrance	5 EA	21	Residential Entrance (within slope violation)	3 EA	\$ 3000.00	\$ 9000.00					—	Adjacent Sidewalk Collection Path				
22	Total Sidewalk Length Assessed	309.469 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					—	Buried Sidewalk				
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	72.798 SY	\$ 75.00	\$ 5460.00					—	Sidewalk Not Surveyed				
24	No Sidewalk on Block (Approx.)	347.595 LF	24	Running and Cross Slope Violations	4.243 SY	\$ 75.00	\$ 318.00					—	Missing Sidewalk Gap				
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					—	No Sidewalk on Block				
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00										
27	Buried Sidewalk (Approx.)	19.857 LF	27	Buried Sidewalk (Approx.)	19.857 LF	\$ 41.67	\$ 880.00										
			Sidewalk SubTotal:				\$ 15078.00										
										Corridor Total:		\$ 15078.00					
										Curb Ramps - Compliant		Curb Ramps - Adjacent					
										Curb Ramps - Non Compliant		Island Curb Cuts - Adjacent					
										Island Curb Cuts - Compliant		Island Curb Cuts - Non Compliant					
										Island Curb Cuts - Non Compliant		Signals - Adjacent					
										Signals - Compliant		Signals - Non Compliant					
										Signals - Non Compliant		Transit Stops - Adjacent					
										Transit Stops - Compliant		Transit Stops - Non Compliant					
										Transit Stops - Non Compliant		Railroad Crossings - Adjacent					
										Railroad Crossings - Compliant		Railroad Crossings - Non Compliant					
										Railroad Crossings - Non Compliant		Accessible Parking - Adjacent					
										Accessible Parking - Compliant		Accessible Parking - Non Compliant					
										Accessible Parking - Non Compliant							