


To:



Intersection Inventory & Compliance Cost Estimate

Item Description	Quantity	Unit Price	Item Cost
1 Heavings less than 1"	6 EA	\$ 100.00	\$ 600.00
2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00
3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00
4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00
5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00
6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00
7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00
8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00
9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00
10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00
11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00
12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00
13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00
14 Transit Obstruction	0 EA	\$500.00	\$ 0.00
15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00
16 Tree Obstruction	0 EA	\$500.00	\$ 0.00
17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00
18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00
19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00
20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00
21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00
22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00
23 Cross Slope Violations	5.284 SY	\$ 75.00	\$ 396.00
24 Running and Cross Slope Violations	107.944 SY	\$ 75.00	\$ 8096.00
25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00
26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00
27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00

Item Description	Quantity	Unit Price	Item Cost
Heavings less than 1"	6 EA	\$ 100.00	\$ 600.00
Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00
Uneven Heavings	0 EA	\$ 400.00	\$ 0.00
Heaving Clusters	0 SY	\$ 75.00	\$ 0.00
Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00
Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00
Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00
Other Obstruction	0 EA	\$ 500.00	\$ 0.00
Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00
Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00
Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00
Sign Obstruction	0 EA	\$ 150.00	\$ 0.00
Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00
Transit Obstruction	0 EA	\$500.00	\$ 0.00
Traffic Obstruction	0 EA	\$2000.00	\$ 0.00
Tree Obstruction	0 EA	\$500.00	\$ 0.00
Utility Obstruction	0 EA	\$1500.00	\$ 0.00
Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00
Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00
Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00
Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00
Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00
Cross Slope Violations	5.284 SY	\$ 75.00	\$ 396.00
Running and Cross Slope Violations	107.944 SY	\$ 75.00	\$ 8096.00
Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00
Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00
Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00

Corridor Total: \$ 10742.00

 Curb Ramps - Compliant	 Curb Ramps - Adjacent
 Curb Ramps - Non Compliant	
 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent
 Island Curb Cuts - Non Compliant	
 Signals - Compliant	 Signals - Adjacent
 Signals - Non Compliant	
 Transit Stops - Compliant	 Transit Stops - Adjacent
 Transit Stops - Non Compliant	
 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent
 Railroad Crossings - Non Compliant	
 Accessible Parking - Compliant	 Accessible Parking - Adjacent
 Accessible Parking - Non Compliant	

 Curb Ramps - Compliant	 Curb Ramps - Adjacent
 Curb Ramps - Non Compliant	
 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent
 Island Curb Cuts - Non Compliant	
 Signals - Compliant	 Signals - Adjacent
 Signals - Non Compliant	
 Transit Stops - Compliant	 Transit Stops - Adjacent
 Transit Stops - Non Compliant	
 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent
 Railroad Crossings - Non Compliant	
 Accessible Parking - Compliant	 Accessible Parking - Adjacent
 Accessible Parking - Non Compliant	

- Legend:**

 - Heavings < 1" (Excluded)***
 - Heavings ≥ 1" (Excluded)***
 - Uneven Heaving (Excluded)***
 - Heaving Clusters (Excluded)
 - Sidewalk Joint Gap (Excluded)***
 - Miscellaneous Obstruction
 - Missing Sidewalk Obstruction
 - Other Obstruction
 - Pole Post Hydrant Obstruction
 - Ponding Obstruction
 - Sidewalk Joint Obstruction
 - Sign Obstruction
 - Storm Grate Obstruction
 - Transit Obstruction
 - Traffic Obstruction
 - Tree Obstruction
 - Utility Obstruction
 - Vegetation Obstruction - Low
 - Vegetation Obstruction - Overhead
 - Sidewalk Collection Path
 - Adjacent Sidewalk Collection Path
 - Buried Sidewalk
 - Sidewalk Not Surveyed
 - Missing Sidewalk Gap
 - No Sidewalk on Block
 - Heavings < 1"
 - Heavings ≥ 1"
 - Uneven Heaving
 - Heaving Clusters
 - Sidewalk Joint Gap
 - Commercial Entrance
 - Residential Entrance
 - Commercial Entrance (within slope violation)
 - Residential Entrance (within slope violation)

Cross Slope

2 - 3%	7.01 - 8%
3.01 - 4%	8.01 - 9%
4.01 - 5%	9.01 - 10%
5.01% - 6%	10.01 - 12%
6.01 - 7%	> 12%

Running Slope

5 - 8.33%
8.34% - 10%
10.01 - 12.5%
> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.