




ADA Survey Summary						ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	Item Description	Total Count	Non Compliant Count	Cost				
1 Heavings less than 1"	14 EA	1 Heavings less than 1"	6 EA	\$ 100.00	\$ 600.00	Curb Ramps - Compliant	0	0	\$ 0.00	Heavings < 1" (Excluded)***	0	0	\$ 0.00	Heavings < 1"	0	0	\$ 0.00
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Curb Ramps - Non Compliant	0	0	\$ 0.00	Heavings ≥ 1" (Excluded)***	0	0	\$ 0.00	Heavings ≥ 1"	0	0	\$ 0.00
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts - Compliant	0	0	\$ 0.00	Uneven Heaving (Excluded)***	0	0	\$ 0.00	Uneven Heaving	0	0	\$ 0.00
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Island Curb Cuts - Non Compliant	0	0	\$ 0.00	Heaving Clusters (Excluded)	0	0	\$ 0.00	Heaving Clusters	0	0	\$ 0.00
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Signals - Compliant	0	0	\$ 0.00	Sidewalk Joint Gap (Excluded)***	0	0	\$ 0.00	Sidewalk Joint Gap	0	0	\$ 0.00
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Signals - Non Compliant	0	0	\$ 0.00	Miscellaneous Obstruction	0	0	\$ 0.00	Miscellaneous Obstruction	0	0	\$ 0.00
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Transit Stops - Compliant	0	0	\$ 0.00	Missing Sidewalk Obstruction	0	0	\$ 0.00	Missing Sidewalk Obstruction	0	0	\$ 0.00
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Transit Stops - Non Compliant	0	0	\$ 0.00	Other Obstruction	0	0	\$ 0.00	Other Obstruction	0	0	\$ 0.00
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Railroad Crossings - Compliant	0	0	\$ 0.00	Pole Post Hydrant Obstruction	0	0	\$ 0.00	Pole Post Hydrant Obstruction	0	0	\$ 0.00
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	Railroad Crossings - Non Compliant	0	0	\$ 0.00	Ponding Obstruction	0	0	\$ 0.00	Ponding Obstruction	0	0	\$ 0.00
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	Accessible Parking - Compliant	0	0	\$ 0.00	Sidewalk Joint Obstruction	0	0	\$ 0.00	Sidewalk Joint Obstruction	0	0	\$ 0.00
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	Accessible Parking - Non Compliant	0	0	\$ 0.00	Sign Obstruction	0	0	\$ 0.00	Sign Obstruction	0	0	\$ 0.00
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					Storm Grate Obstruction	0	0	\$ 0.00	Storm Grate Obstruction	0	0	\$ 0.00
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					Transit Obstruction	0	0	\$ 0.00	Transit Obstruction	0	0	\$ 0.00
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					Traffic Obstruction	0	0	\$ 0.00	Traffic Obstruction	0	0	\$ 0.00
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					Tree Obstruction	0	0	\$ 0.00	Tree Obstruction	0	0	\$ 0.00
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					Utility Obstruction	0	0	\$ 0.00	Utility Obstruction	0	0	\$ 0.00
18 Vegetation Obstruction - Low	2 EA	18 Vegetation Obstruction - Low	2 EA	\$150.00	\$ 300.00					Vegetation Obstruction - Low	2	2	\$ 300.00	Vegetation Obstruction - Low	2	2	\$ 300.00
19 Vegetation Obstruction - Overhead	1 EA	19 Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00					Vegetation Obstruction - Overhead	1	1	\$ 150.00	Vegetation Obstruction - Overhead	1	1	\$ 150.00
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					Sidewalk Collection Path	0	0	\$ 0.00	Sidewalk Collection Path	0	0	\$ 0.00
21 Residential Entrance	13 EA	21 Residential Entrance (within slope violation)	10 EA	\$ 3000.00	\$ 30000.00					Adjacent Sidewalk Collection Path	0	0	\$ 0.00	Adjacent Sidewalk Collection Path	0	0	\$ 0.00
22 Total Sidewalk Length Assessed	733.876 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					Buried Sidewalk	0	0	\$ 0.00	Buried Sidewalk	0	0	\$ 0.00
23 Average Sidewalk Width	54 IN	23 Cross Slope Violations	173.905 SY	\$ 75.00	\$ 13043.00					Sidewalk Not Surveyed	0	0	\$ 0.00	Sidewalk Not Surveyed	0	0	\$ 0.00
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	38.314 SY	\$ 75.00	\$ 2874.00					Missing Sidewalk Gap	0	0	\$ 0.00	Missing Sidewalk Gap	0	0	\$ 0.00
25 Missing Sidewalk Gaps (Approx.)	803.673 LF	25 Missing Sidewalk Gaps (Approx.)	803.673 LF	\$ 41.67	\$ 33440.00					No Sidewalk on Block	0	0	\$ 0.00	No Sidewalk on Block	0	0	\$ 0.00
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00												
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00												
Sidewalk SubTotal:					\$ 46966.00												

Corridor Total:

\$ 80406.00

Curb Ramps - Compliant

Curb Ramps - Non Compliant

Island Curb Cuts - Compliant

Island Curb Cuts - Non Compliant

Signals - Compliant

Signals - Non Compliant

Transit Stops - Compliant

Transit Stops - Non Compliant

Railroad Crossings - Compliant

Railroad Crossings - Non Compliant

Accessible Parking - Compliant

Accessible Parking - Non Compliant

Curb Ramps - Adjacent

Island Curb Cuts - Adjacent

Signals - Adjacent

Transit Stops - Adjacent

Railroad Crossings - Adjacent

Accessible Parking - Adjacent

Cross Slope

Running Slope

2 - 3%

3.01 - 4%

4.01 - 5%

5.01% - 6%

6.01 - 7%

7.01 - 8%

8.01 - 9%

9.01 - 10%

10.01 - 12%

> 12%

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.