




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity		Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	10 EA		1	Heavings less than 1"	3 EA	\$ 100.00	\$ 300.00	Curb Ramps		4	4	\$ 9400.00	●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	1 EA		2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA		3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***
4	Heaving Clusters	1.776 SY		4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	—	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA		5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA		6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA		7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 9400.00	■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA		8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00						■	Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA		9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						■	Pole Post Hydrant Obstruction
10	Ponding Obstruction	0 EA		10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						■	Ponding Obstruction
11	Sidewalk Joint Obstruction	0 EA		11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						■	Sidewalk Joint Obstruction
12	Sign Obstruction	0 EA		12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						■	Sign Obstruction
13	Storm Grate Obstruction	0 EA		13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00						■	Storm Grate Obstruction
14	Transit Obstruction	0 EA		14	Transit Obstruction	0 EA	\$500.00	\$ 0.00						■	Transit Obstruction
15	Traffic Obstruction	0 EA		15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00						■	Traffic Obstruction
16	Tree Obstruction	0 EA		16	Tree Obstruction	0 EA	\$500.00	\$ 0.00						■	Tree Obstruction
17	Utility Obstruction	0 EA		17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00						■	Utility Obstruction
18	Vegetation Obstruction - Low	0 EA		18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Low
19	Vegetation Obstruction - Overhead	0 EA		19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Overhead
20	Commercial Entrance	3 EA		20	Commercial Entrance (within slope violation)	2 EA	\$ 5000.00	\$ 10000.00						■	Sidewalk Collection Path
21	Residential Entrance	0 EA		21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						■	Adjacent Sidewalk Collection Path
22	Total Sidewalk Length Assessed	951.349 LF		22	Running Slope Violations**	2.464 SY	\$ 75.00	\$ 185.00						■	Buried Sidewalk
23	Average Sidewalk Width	68 IN		23	Cross Slope Violations	256.209 SY	\$ 75.00	\$ 19216.00						■	Sidewalk Not Surveyed
24	No Sidewalk on Block (Approx.)	606.94 LF		24	Running and Cross Slope Violations	52.151 SY	\$ 75.00	\$ 3911.00						■	Missing Sidewalk Gap
25	Missing Sidewalk Gaps (Approx.)	94.667 LF		25	Missing Sidewalk Gaps (Approx.)	94.667 LF	\$ 41.67	\$ 3960.00						■	No Sidewalk on Block
26	Poor Surface Condition (Approx.)	0 LF		26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00							
27	Buried Sidewalk (Approx.)	9.135 LF		27	Buried Sidewalk (Approx.)	9.135 LF	\$ 41.67	\$ 440.00							
Sidewalk SubTotal:								\$ 33612.00							

● Heavings < 1" (Excluded)*** |

● Heavings ≥ 1" (Excluded)*** |

● Uneven Heaving (Excluded)*** |

— Heaving Clusters (Excluded) |

▲ Sidewalk Joint Gap (Excluded)*** |

■ Miscellaneous Obstruction |

■ Missing Sidewalk Obstruction |

■ Other Obstruction |

■ Pole Post Hydrant Obstruction |

■ Ponding Obstruction |

■ Sidewalk Joint Obstruction |

■ Sign Obstruction |

■ Storm Grate Obstruction |

■ Transit Obstruction |

■ Traffic Obstruction |

■ Tree Obstruction |

■ Utility Obstruction |

■ Vegetation Obstruction - Low |

■ Vegetation Obstruction - Overhead |

■ Sidewalk Collection Path |

■ Adjacent Sidewalk Collection Path |

■ Buried Sidewalk |

■ Sidewalk Not Surveyed |

■ Missing Sidewalk Gap |

■ No Sidewalk on Block |

● Heavings < 1" |

● Heavings ≥ 1" |

● Uneven Heaving |

— Heaving Clusters |

▲ Sidewalk Joint Gap |

◆ Commercial Entrance |

◆ Residential Entrance |

⊕ Commercial Entrance (within slope violation) |

⊕ Residential Entrance (within slope violation) |

Cross Slope

2 - 3%

7.01 - 8%

3.01 - 4%

8.01 - 9%

4.01 - 5%

9.01 - 10%

5.01% - 6%

10.01 - 12%

6.01 - 7%

> 12%

Running Slope

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.