




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate						
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost		
1 Heavings less than 1"	4 EA		1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	1	1	\$ 1850.00	● Heavings < 1" (Excluded)***	● Heavings < 1"
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	● Heaving Clusters (Excluded)	● Heaving Clusters
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 1850.00		■ Missing Sidewalk Obstruction	◆ Residential Entrance
8 Other Obstruction	1 EA		8 Other Obstruction	1 EA	\$ 500.00	\$ 500.00					■ Other Obstruction	✚ Commercial Entrance (within slope violation)
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction	✚ Residential Entrance (within slope violation)
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction	
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction	Cross Slope
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction	2 - 3%
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■ Storm Grate Obstruction	3.01 - 4%
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■ Transit Obstruction	4.01 - 5%
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■ Traffic Obstruction	5.01% - 6%
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■ Tree Obstruction	6.01 - 7%
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■ Utility Obstruction	> 12%
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Low	Running Slope
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Overhead	5 - 8.33%
20 Commercial Entrance	1 EA		20 Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$ 5000.00					■ Sidewalk Collection Path	8.34% - 10%
21 Residential Entrance	2 EA		21 Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00					■ Adjacent Sidewalk Collection Path	10.01 - 12.5%
22 Total Sidewalk Length Assessed	465.069 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					■ Buried Sidewalk	> 12.5%
23 Average Sidewalk Width	46.8 IN		23 Cross Slope Violations	137.75 SY	\$ 75.00	\$ 10331.00					■ Sidewalk Not Surveyed	
24 No Sidewalk on Block (Approx.)	689.341 LF		24 Running and Cross Slope Violations	23.266 SY	\$ 75.00	\$ 1745.00					■ Missing Sidewalk Gap	
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					■ No Sidewalk on Block	
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00						
27 Buried Sidewalk (Approx.)	259.092 LF		27 Buried Sidewalk (Approx.)	259.092 LF	\$ 41.67	\$ 10780.00						
			Sidewalk SubTotal:			\$ 23576.00						
							Corridor Total:			\$ 25426.00		
							Curb Ramps - Compliant			Curb Ramps - Adjacent		
							Curb Ramps - Non Compliant			Curb Ramps - Adjacent		
							Island Curb Cuts - Compliant			Island Curb Cuts - Adjacent		
							Island Curb Cuts - Non Compliant			Island Curb Cuts - Adjacent		
							Signals - Compliant			Signals - Adjacent		
							Signals - Non Compliant			Signals - Adjacent		
							Transit Stops - Compliant			Transit Stops - Adjacent		
							Transit Stops - Non Compliant			Transit Stops - Adjacent		
							Railroad Crossings - Compliant			Railroad Crossings - Adjacent		
							Railroad Crossings - Non Compliant			Railroad Crossings - Adjacent		
							Accessible Parking - Compliant			Accessible Parking - Adjacent		
							Accessible Parking - Non Compliant			Accessible Parking - Adjacent		
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.												
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.												