




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate											
Item Description		Quantity		Item Description		Quantity	Unit Price	Item Cost	Item Description		Total Count	Non Compliant Count	Cost						
1	Heavings less than 1"	7 EA		1	Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	2	2	\$ 6400.00		Heavings < 1" (Excluded)***		Heavings < 1"			
2	Heavings 1" or greater	0 EA		2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00		Heavings ≥ 1" (Excluded)***		Heavings ≥ 1"			
3	Uneven Heavings	0 EA		3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00		Uneven Heaving (Excluded)***		Uneven Heaving			
4	Heaving Clusters	0 SY		4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00		Heaving Clusters (Excluded)		Heaving Clusters			
5	Sidewalk Joint Gaps	0 EA		5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00		Sidewalk Joint Gap (Excluded)***		Sidewalk Joint Gap			
6	Miscellaneous Obstruction	0 EA		6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00		Miscellaneous Obstruction		Commercial Entrance			
7	Missing Sidewalk Obstruction	0 EA		7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 6400.00			Missing Sidewalk Obstruction		Residential Entrance			
8	Other Obstruction	0 EA		8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00						Other Obstruction		Commercial Entrance (within slope violation)			
9	Pole Post Hydrant Obstruction	0 EA		9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						Pole Post Hydrant Obstruction		Residential Entrance (within slope violation)			
10	Ponding Obstruction	0 EA		10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						Ponding Obstruction		Cross Slope			
11	Sidewalk Joint Obstruction	0 EA		11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						Sidewalk Joint Obstruction		2 - 3%		7.01 - 8%	
12	Sign Obstruction	0 EA		12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						Sign Obstruction		3.01 - 4%		8.01 - 9%	
13	Storm Grate Obstruction	0 EA		13	Storm Grate Obstruction	0 EA	\$ 700.00	\$ 0.00						Storm Grate Obstruction		4.01 - 5%		9.01 - 10%	
14	Transit Obstruction	0 EA		14	Transit Obstruction	0 EA	\$ 500.00	\$ 0.00						Transit Obstruction		5.01% - 6%		10.01 - 12%	
15	Traffic Obstruction	0 EA		15	Traffic Obstruction	0 EA	\$ 2000.00	\$ 0.00						Traffic Obstruction		6.01 - 7%		> 12%	
16	Tree Obstruction	0 EA		16	Tree Obstruction	0 EA	\$ 500.00	\$ 0.00						Tree Obstruction		Running Slope			
17	Utility Obstruction	0 EA		17	Utility Obstruction	0 EA	\$ 1500.00	\$ 0.00						Utility Obstruction		5 - 8.33%			
18	Vegetation Obstruction - Low	2 EA		18	Vegetation Obstruction - Low	2 EA	\$ 150.00	\$ 300.00						Vegetation Obstruction - Low		8.34% - 10%			
19	Vegetation Obstruction - Overhead	0 EA		19	Vegetation Obstruction - Overhead	0 EA	\$ 150.00	\$ 0.00						Vegetation Obstruction - Overhead		10.01 - 12.5%			
20	Commercial Entrance	8 EA		20	Commercial Entrance (within slope violation)	4 EA	\$ 5000.00	\$ 20000.00						Sidewalk Collection Path		> 12.5%			
21	Residential Entrance	0 EA		21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						Adjacent Sidewalk Collection Path					
22	Total Sidewalk Length Assessed	884.607 LF		22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00						Buried Sidewalk					
23	Average Sidewalk Width	56 IN		23	Cross Slope Violations	152.061 SY	\$ 75.00	\$ 11405.00						Sidewalk Not Surveyed					
24	No Sidewalk on Block (Approx.)	0 LF		24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00						Missing Sidewalk Gap					
25	Missing Sidewalk Gaps (Approx.)	858.253 LF		25	Missing Sidewalk Gaps (Approx.)	858.253 LF	\$ 41.67	\$ 35860.00						No Sidewalk on Block					
26	Poor Surface Condition (Approx.)	0 LF		26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00											
27	Buried Sidewalk (Approx.)	0 LF		27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00											
				Sidewalk SubTotal:				\$ 31705.00											
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. **Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way. ***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.																			