




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost						
1 Heavings less than 1"	16 EA	1 Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps	2	2	\$ 3350.00	● Heavings < 1" (Excluded)***	● Heavings < 1"				
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"				
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving				
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	— Heaving Clusters (Excluded)	— Heaving Clusters				
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap				
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance				
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 3350.00		■ Missing Sidewalk Obstruction	◆ Residential Entrance				
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:		\$ 103801.00		■ Other Obstruction	■ Commercial Entrance (within slope violation)				
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■ Curb Ramps - Compliant				■ Pole Post Hydrant Obstruction	■ Residential Entrance (within slope violation)				
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■ Curb Ramps - Non Compliant				■ Ponding Obstruction	Cross Slope				
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■ Island Curb Cuts - Compliant				■ Sidewalk Joint Obstruction	— 2 - 3%	— 7.01 - 8%			
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■ Island Curb Cuts - Non Compliant				■ Sign Obstruction	— 3.01 - 4%	— 8.01 - 9%			
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Signals - Compliant				■ Storm Grate Obstruction	— 4.01 - 5%	— 9.01 - 10%			
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Non Compliant				■ Transit Obstruction	— 5.01% - 6%	— 10.01 - 12%			
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Transit Stops - Compliant				■ Traffic Obstruction	— 6.01 - 7%	— > 12%			
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Transit Stops - Non Compliant				■ Tree Obstruction	Running Slope				
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■ Railroad Crossings - Compliant				■ Utility Obstruction	— 5 - 8.33%				
18 Vegetation Obstruction - Low	1 EA	18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00	■ Railroad Crossings - Non Compliant				■ Vegetation Obstruction - Low	— 8.34% - 10%				
19 Vegetation Obstruction - Overhead	3 EA	19 Vegetation Obstruction - Overhead	3 EA	\$150.00	\$ 450.00	■ Accessible Parking - Compliant				■ Vegetation Obstruction - Overhead	— 10.01 - 12.5%				
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■ Accessible Parking - Non Compliant				— Sidewalk Collection Path	— > 12.5%				
21 Residential Entrance	27 EA	21 Residential Entrance (within slope violation)	24 EA	\$ 3000.00	\$ 72000.00	■ Accessible Parking - Non Compliant				— Adjacent Sidewalk Collection Path					
22 Total Sidewalk Length Assessed	1917.394 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	■ Accessible Parking - Non Compliant				— Buried Sidewalk					
23 Average Sidewalk Width	48 IN	23 Cross Slope Violations	344.561 SY	\$ 75.00	\$ 25842.00					— Sidewalk Not Surveyed					
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	14.253 SY	\$ 75.00	\$ 1069.00					— Missing Sidewalk Gap					
25 Missing Sidewalk Gaps (Approx.)	10.136 LF	25 Missing Sidewalk Gaps (Approx.)	10.136 LF	\$ 41.67	\$ 440.00					— No Sidewalk on Block					
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00										
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00										
Sidewalk SubTotal:					\$ 100011.00										
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.															
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.															
***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.															