




ADA Survey Summary						ADA Compliance Cost Estimate *						Intersection Inventory & Compliance Cost Estimate											
Item Description		Quantity	Item Description		Quantity	Unit Price	Item Cost	Item Description		Total Count	Non Compliant Count	Cost											
1	Heavings less than 1"	25 EA	1	Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps		1	1	\$ 1850.00		●	Heavings < 1" (Excluded)***	●	Heavings < 1"						
2	Heavings 1" or greater	1 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00		●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"						
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00		●	Uneven Heaving (Excluded)***	●	Uneven Heaving						
4	Heaving Clusters	3.685 SY	4	Heaving Clusters	1.909 SY	\$ 75.00	\$ 143.00	Transit Stops		0	0	\$ 0.00		●	Heaving Clusters (Excluded)	●	Heaving Clusters						
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00		▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap						
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00		■	Miscellaneous Obstruction	■	Miscellaneous Obstruction						
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 1850.00		■	Missing Sidewalk Obstruction	■	Missing Sidewalk Obstruction						
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 117433.00		■	Other Obstruction	■	Other Obstruction						
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00							■	Pole Post Hydrant Obstruction	■	Pole Post Hydrant Obstruction						
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00							■	Ponding Obstruction	■	Ponding Obstruction						
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00							■	Sidewalk Joint Obstruction	■	Sidewalk Joint Obstruction						
12	Sign Obstruction	2 EA	12	Sign Obstruction	2 EA	\$ 150.00	\$ 300.00							■	Sign Obstruction	■	Sign Obstruction						
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00							■	Storm Grate Obstruction	■	Storm Grate Obstruction						
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00							■	Transit Obstruction	■	Transit Obstruction						
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00							■	Traffic Obstruction	■	Traffic Obstruction						
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00							■	Tree Obstruction	■	Tree Obstruction						
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00							■	Utility Obstruction	■	Utility Obstruction						
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00							■	Vegetation Obstruction - Low	■	Vegetation Obstruction - Low						
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00							■	Vegetation Obstruction - Overhead	■	Vegetation Obstruction - Overhead						
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00							■	Sidewalk Collection Path	■	Sidewalk Collection Path						
21	Residential Entrance	35 EA	21	Residential Entrance (within slope violation)	30 EA	\$ 3000.00	\$ 90000.00							■	Adjacent Sidewalk Collection Path	■	Adjacent Sidewalk Collection Path						
22	Total Sidewalk Length Assessed	1660.022 LF	22	Running Slope Violations**	2.664 SY	\$ 75.00	\$ 200.00							■	Buried Sidewalk	■	Buried Sidewalk						
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	204.068 SY	\$ 75.00	\$ 15305.00							■	Sidewalk Not Surveyed	■	Sidewalk Not Surveyed						
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	119.795 SY	\$ 75.00	\$ 8985.00							■	Missing Sidewalk Gap	■	Missing Sidewalk Gap						
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00							■	No Sidewalk on Block	■	No Sidewalk on Block						
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00																
27	Buried Sidewalk (Approx.)	8.986 LF	27	Buried Sidewalk (Approx.)	8.986 LF	\$ 41.67	\$ 440.00																
			Sidewalk SubTotal:				\$ 115583.00																

Curb Ramps - Compliant

Island Curb Cuts - Compliant

Signals - Compliant

Transit Stops - Compliant

Railroad Crossings - Compliant

Accessible Parking - Compliant

Curb Ramps - Non Compliant

Island Curb Cuts - Non Compliant

Signals - Non Compliant

Transit Stops - Non Compliant

Railroad Crossings - Non Compliant

Accessible Parking - Non Compliant

Curb Ramps - Adjacent

Island Curb Cuts - Adjacent

Signals - Adjacent

Transit Stops - Adjacent

Railroad Crossings - Adjacent

Accessible Parking - Adjacent

2 - 3%

3.01 - 4%

4.01 - 5%

5.01% - 6%

6.01 - 7%

7.01 - 8%

8.01 - 9%

9.01 - 10%

10.01 - 12%

> 12%

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

Heavings < 1"

Heavings ≥ 1"

Uneven Heaving

Heaving Clusters

Sidewalk Joint Gap

Commercial Entrance

Residential Entrance

Commercial Entrance (within slope violation)

Residential Entrance (within slope violation)

Cross Slope

Running Slope

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.