



ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate								
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost			
1	Heavings less than 1"	0 EA	1	Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps		2	2	\$ 2850.00	●	Heavings < 1" (Excluded)***	●
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction	■
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 2850.00	■	Missing Sidewalk Obstruction	■
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00						■	Other Obstruction	■
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						■	Pole Post Hydrant Obstruction	■
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						■	Ponding Obstruction	■
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						■	Sidewalk Joint Obstruction	■
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						■	Sign Obstruction	■
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00						■	Storm Grate Obstruction	■
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00						■	Transit Obstruction	■
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00						■	Traffic Obstruction	■
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00						■	Tree Obstruction	■
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00						■	Utility Obstruction	■
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Low	■
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00						■	Vegetation Obstruction - Overhead	■
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00						—	Sidewalk Collection Path	—
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						—	Adjacent Sidewalk Collection Path	—
22	Total Sidewalk Length Assessed	0 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00						—	Buried Sidewalk	—
23	Average Sidewalk Width	0 IN	23	Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00						—	Sidewalk Not Surveyed	—
24	No Sidewalk on Block (Approx.)	1117.783 LF	24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00						—	Missing Sidewalk Gap	—
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						—	No Sidewalk on Block	—
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
				Sidewalk SubTotal:			\$ 0.00								

Corridor Total:

\$ 2850.00

🚶

Curb Ramps - Compliant

🚶

Curb Ramps - Non Compliant

🚶

Island Curb Cuts - Compliant

🚶

Island Curb Cuts - Non Compliant

🚶

Signals - Compliant

🚶

Signals - Non Compliant

🚶

Transit Stops - Compliant

🚶

Transit Stops - Non Compliant

🚶

Railroad Crossings - Compliant

🚶

Railroad Crossings - Non Compliant

🚶

Accessible Parking - Compliant

🚶

Accessible Parking - Non Compliant

🚶

Curb Ramps - Adjacent

🚶

Island Curb Cuts - Adjacent

🚶

Signals - Adjacent

🚶

Transit Stops - Adjacent

🚶

Railroad Crossings - Adjacent

🚶

Accessible Parking - Adjacent

● Heavings < 1" (Excluded)*** | ● | Heavings < 1" |

● Heavings ≥ 1" (Excluded)*** | ● | Heavings ≥ 1" |

● Uneven Heaving (Excluded)*** | ● | Uneven Heaving |

— Heaving Clusters (Excluded) | — | Heaving Clusters |

▲ Sidewalk Joint Gap (Excluded)*** | ▲ | Sidewalk Joint Gap |

■ Miscellaneous Obstruction | ■ | Commercial Entrance |

■ Missing Sidewalk Obstruction | ■ | Residential Entrance |

■ Other Obstruction | ■ | Commercial Entrance (within slope violation) |

■ Pole Post Hydrant Obstruction | ■ | Residential Entrance (within slope violation) |

■ Ponding Obstruction | | Cross Slope |

■ Sidewalk Joint Obstruction | 2 - 3% | 7.01 - 8% |

■ Sign Obstruction | 3.01 - 4% | 8.01 - 9% |

■ Storm Grate Obstruction | 4.01 - 5% | 9.01 - 10% |

■ Transit Obstruction | 5.01% - 6% | 10.01 - 12% |

■ Traffic Obstruction | 6.01 - 7% | > 12% |

■ Tree Obstruction | | Running Slope |

■ Utility Obstruction | 5 - 8.33% | |

■ Vegetation Obstruction - Low | 8.34% - 10% | |

■ Vegetation Obstruction - Overhead | 10.01 - 12.5% | |

— Sidewalk Collection Path | > 12.5% | |

— Adjacent Sidewalk Collection Path | | |

— Buried Sidewalk | | |

— Sidewalk Not Surveyed | | |

— Missing Sidewalk Gap | | |

— No Sidewalk on Block | | |

*Note:

ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note:

Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note:

Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.