




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate												
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost						
1	Heavings less than 1"	15 EA	1	Heavings less than 1"	10 EA	\$ 100.00	\$ 1000.00	Curb Ramps		4	4	\$ 8400.00						
2	Heavings 1" or greater	2 EA	2	Heavings 1" or greater	2 EA	\$ 400.00	\$ 800.00	Island Curb Cuts		0	0	\$ 0.00						
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00						
4	Heaving Clusters	5.332 SY	4	Heaving Clusters	1.778 SY	\$ 75.00	\$ 133.00	Transit Stops		0	0	\$ 0.00						
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00						
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00						
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 8400.00						
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:								\$ 30212.00		
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Curb Ramps - Compliant			Curb Ramps - Adjacent		Heavings < 1" (Excluded)***	Heavings < 1"				
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	Curb Ramps - Non Compliant			Island Curb Cuts - Adjacent		Heavings ≥ 1" (Excluded)***	Heavings ≥ 1"				
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	Island Curb Cuts - Compliant			Signals - Adjacent		Uneven Heaving (Excluded)***	Uneven Heaving				
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	Island Curb Cuts - Non Compliant			Transit Stops - Adjacent		Heaving Clusters (Excluded)	Heaving Clusters				
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	Signals - Compliant			Railroad Crossings - Adjacent		Sidewalk Joint Gap (Excluded)***	Sidewalk Joint Gap				
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	Signals - Non Compliant			Accessible Parking - Adjacent		Miscellaneous Obstruction	Commercial Entrance				
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	Transit Stops - Compliant					Missing Sidewalk Obstruction	Residential Entrance				
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	Transit Stops - Non Compliant					Other Obstruction	Commercial Entrance (within slope violation)				
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	Railroad Crossings - Compliant					Pole Post Hydrant Obstruction	Residential Entrance (within slope violation)				
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	Railroad Crossings - Non Compliant					Ponding Obstruction		Cross Slope			
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	Accessible Parking - Compliant					Sidewalk Joint Obstruction	2 - 3%	7.01 - 8%			
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	Accessible Parking - Non Compliant					Sign Obstruction	3.01 - 4%	8.01 - 9%			
21	Residential Entrance	6 EA	21	Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00						Storm Grate Obstruction	4.01 - 5%	9.01 - 10%			
22	Total Sidewalk Length Assessed	622.735 LF	22	Running Slope Violations**	6.799 SY	\$ 75.00	\$ 510.00						Transit Obstruction	5.01% - 6%	10.01 - 12%			
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	60.667 SY	\$ 75.00	\$ 4550.00						Traffic Obstruction	6.01 - 7%	> 12%			
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	117.582 SY	\$ 75.00	\$ 8819.00						Tree Obstruction		Running Slope			
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						Utility Obstruction	5 - 8.33%				
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00						Vegetation Obstruction - Low	8.34% - 10%				
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00						Vegetation Obstruction - Overhead	10.01 - 12.5%				
							\$ 21812.00									Sidewalk Collection Path	> 12.5%	
																Adjacent Sidewalk Collection Path		
																Buried Sidewalk		
																Sidewalk Not Surveyed		
																Missing Sidewalk Gap		
																No Sidewalk on Block		
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.																		
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.																		