




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	Heavings < 1" (Excluded)***	Heavings < 1"		
1 Heavings less than 1"	2 EA	1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	1	1	\$ 1850.00	Heavings ≥ 1" (Excluded)***	Heavings ≥ 1"		
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	Uneven Heaving (Excluded)***	Uneven Heaving		
3 Uneven Heavings	1 EA	3 Uneven Heavings	1 EA	\$ 400.00	\$ 400.00	Signal Push Buttons	0	0	\$ 0.00	Heaving Clusters (Excluded)	Heaving Clusters		
4 Heaving Clusters	3.729 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	Sidewalk Joint Gap (Excluded)***	Sidewalk Joint Gap		
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	Miscellaneous Obstruction	Commercial Entrance		
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	Missing Sidewalk Obstruction	Residential Entrance		
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 1850.00	Other Obstruction	Commercial Entrance (within slope violation)		
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					Pole Post Hydrant Obstruction	Residential Entrance (within slope violation)		
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					Ponding Obstruction			
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					Sidewalk Joint Obstruction	2 - 3% 7.01 - 8%		
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					Sign Obstruction	3.01 - 4% 8.01 - 9%		
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					Storm Grate Obstruction	4.01 - 5% 9.01 - 10%		
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					Transit Obstruction	5.01% - 6% 10.01 - 12%		
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					Traffic Obstruction	6.01 - 7% > 12%		
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					Tree Obstruction	Running Slope		
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					Utility Obstruction	5 - 8.33%		
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					Vegetation Obstruction - Low	8.34% - 10%		
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					Vegetation Obstruction - Overhead	10.01 - 12.5%		
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					Sidewalk Collection Path	> 12.5%		
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					Adjacent Sidewalk Collection Path			
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00					Buried Sidewalk			
22 Total Sidewalk Length Assessed	100.25 LF	22 Running Slope Violations**	22.551 SY	\$ 75.00	\$ 1691.00					Sidewalk Not Surveyed			
23 Average Sidewalk Width	48 IN	23 Cross Slope Violations	5.179 SY	\$ 75.00	\$ 388.00					Missing Sidewalk Gap			
24 No Sidewalk on Block (Approx.)	150.379 LF	24 Running and Cross Slope Violations	4.485 SY	\$ 75.00	\$ 336.00					No Sidewalk on Block			
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00								
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	35.327 LF	27 Buried Sidewalk (Approx.)	35.327 LF	\$ 41.67	\$ 1540.00								
Sidewalk SubTotal:					\$ 2816.00	Corridor Total: \$ 4666.00							
Curb Ramps - Compliant Curb Ramps - Non Compliant Island Curb Cuts - Compliant Island Curb Cuts - Non Compliant Signals - Compliant Signals - Non Compliant Transit Stops - Compliant Transit Stops - Non Compliant Railroad Crossings - Compliant Railroad Crossings - Non Compliant Accessible Parking - Compliant Accessible Parking - Non Compliant Curb Ramps - Adjacent Island Curb Cuts - Adjacent Signals - Adjacent Transit Stops - Adjacent Railroad Crossings - Adjacent Accessible Parking - Adjacent													
Heavings < 1" (Excluded)*** Heavings ≥ 1" (Excluded)*** Uneven Heaving (Excluded)*** Heaving Clusters (Excluded) Sidewalk Joint Gap (Excluded)*** Miscellaneous Obstruction Missing Sidewalk Obstruction Other Obstruction Pole Post Hydrant Obstruction Ponding Obstruction Sidewalk Joint Obstruction Sign Obstruction Storm Grate Obstruction Transit Obstruction Traffic Obstruction Tree Obstruction Utility Obstruction Vegetation Obstruction - Low Vegetation Obstruction - Overhead Sidewalk Collection Path Adjacent Sidewalk Collection Path Buried Sidewalk Sidewalk Not Surveyed Missing Sidewalk Gap No Sidewalk on Block													
Heavings < 1" Heavings ≥ 1" Uneven Heaving Heaving Clusters Sidewalk Joint Gap Commercial Entrance Residential Entrance Commercial Entrance (within slope violation) Residential Entrance (within slope violation) Cross Slope 2 - 3% 7.01 - 8% 3.01 - 4% 8.01 - 9% 4.01 - 5% 9.01 - 10% 5.01% - 6% 10.01 - 12% 6.01 - 7% > 12% Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%													
Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way. Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.													