




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost						
1 Heavings less than 1"	2 EA	1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	1	1	\$ 1850.00	•	Heavings < 1" (Excluded)***	●	Heavings < 1"		
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	•	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"		
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	•	Uneven Heaving (Excluded)***	●	Uneven Heaving		
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	2	2	\$ 2650.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters		
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap		
6 Miscellaneous Obstruction	1 EA	6 Miscellaneous Obstruction	1 EA	\$ 1500.00	\$ 1500.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	■	Miscellaneous Obstruction		
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 4500.00	■	Missing Sidewalk Obstruction	■	Missing Sidewalk Obstruction		
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total: \$ 23557.00				■	Other Obstruction	■	Other Obstruction		
9 Pole Post Hydrant Obstruction	1 EA	9 Pole Post Hydrant Obstruction	1 EA	\$ 5000.00	\$ 5000.00					■	Pole Post Hydrant Obstruction	■	Pole Post Hydrant Obstruction		
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■	Ponding Obstruction	■	Ponding Obstruction		
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■	Sidewalk Joint Obstruction	■	Sidewalk Joint Obstruction		
12 Sign Obstruction	1 EA	12 Sign Obstruction	1 EA	\$ 150.00	\$ 150.00					■	Sign Obstruction	■	Sign Obstruction		
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■	Storm Grate Obstruction	■	Storm Grate Obstruction		
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■	Transit Obstruction	■	Transit Obstruction		
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■	Traffic Obstruction	■	Traffic Obstruction		
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■	Tree Obstruction	■	Tree Obstruction		
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■	Utility Obstruction	■	Utility Obstruction		
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■	Vegetation Obstruction - Low	■	Vegetation Obstruction - Low		
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■	Vegetation Obstruction - Overhead	■	Vegetation Obstruction - Overhead		
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					■	Sidewalk Collection Path	■	Sidewalk Collection Path		
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00					■	Adjacent Sidewalk Collection Path	■	Adjacent Sidewalk Collection Path		
22 Total Sidewalk Length Assessed	407.739 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					■	Buried Sidewalk	■	Buried Sidewalk		
23 Average Sidewalk Width	45.5 IN	23 Cross Slope Violations	165.426 SY	\$ 75.00	\$ 12407.00					■	Sidewalk Not Surveyed	■	Sidewalk Not Surveyed		
24 No Sidewalk on Block (Approx.)	592.972 LF	24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00					■	Missing Sidewalk Gap	■	Missing Sidewalk Gap		
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00					■	No Sidewalk on Block	■	No Sidewalk on Block		
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00										
27 Buried Sidewalk (Approx.)	113.807 LF	27 Buried Sidewalk (Approx.)	113.807 LF	\$ 41.67	\$ 4840.00										
		Sidewalk SubTotal:			\$ 19057.00										

■

 Curb Ramps - Compliant

■

 Curb Ramps - Non Compliant

■

 Island Curb Cuts - Compliant

■

 Island Curb Cuts - Non Compliant

■

 Signals - Compliant

■

 Signals - Non Compliant

■

 Transit Stops - Compliant

■

 Transit Stops - Non Compliant

■

 Railroad Crossings - Compliant

■

 Railroad Crossings - Non Compliant

■

 Accessible Parking - Compliant

■

 Accessible Parking - Non Compliant

■

 Curb Ramps - Adjacent

■

 Island Curb Cuts - Adjacent

■

 Signals - Adjacent

■

 Transit Stops - Adjacent

■

 Railroad Crossings - Adjacent

■

 Accessible Parking - Adjacent

■

 Heavings < 1" (Excluded)***

■

 Heavings ≥ 1" (Excluded)***

■

 Uneven Heaving (Excluded)***

■

 Heaving Clusters (Excluded)

■

 Sidewalk Joint Gap (Excluded)***

■

 Miscellaneous Obstruction

■

 Missing Sidewalk Obstruction

■

 Other Obstruction

■

 Pole Post Hydrant Obstruction

■

 Ponding Obstruction

■

 Sidewalk Joint Obstruction

■

 Sign Obstruction

■

 Storm Grate Obstruction

■

 Transit Obstruction

■

 Traffic Obstruction

■

 Tree Obstruction

■

 Utility Obstruction

■

 Vegetation Obstruction - Low

■

 Vegetation Obstruction - Overhead

■

 Sidewalk Collection Path

■

 Adjacent Sidewalk Collection Path

■

 Buried Sidewalk

■

 Sidewalk Not Surveyed

■

 Missing Sidewalk Gap

■

 No Sidewalk on Block

■

 Heavings < 1"

■

 Heavings ≥ 1"

■

 Uneven Heaving

■

 Heaving Clusters

■

 Sidewalk Joint Gap

■

 Commercial Entrance

■

 Residential Entrance

■

 Commercial Entrance (within slope violation)

■

 Residential Entrance (within slope violation)

■

 Cross Slope

■

 Running Slope

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.