




ADA Survey Summary						ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	Item Description	Total Count	Non Compliant Count	Cost	Item Description	Quantity	Item Description	Quantity
1 Heavings less than 1"	14 EA	1 Heavings less than 1"	7 EA	\$ 100.00	\$ 700.00	1 Curb Ramps - Compliant	11	11	\$ 20350.00	1 Heavings < 1" (Excluded)***	0	0	\$ 0.00	1 Heavings < 1"	0	1 Heavings < 1"	0
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	2 Curb Ramps - Non Compliant	0	0	\$ 0.00	2 Heavings ≥ 1" (Excluded)***	0	0	\$ 0.00	2 Heavings ≥ 1"	0	2 Heavings ≥ 1"	0
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	3 Island Curb Cuts - Compliant	5	5	\$ 4000.00	3 Uneven Heaving (Excluded)***	0	0	\$ 0.00	3 Uneven Heaving	0	3 Uneven Heaving	0
4 Heaving Clusters	1.798 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	4 Signal Push Buttons	0	0	\$ 0.00	4 Heaving Clusters (Excluded)	0	0	\$ 0.00	4 Heaving Clusters	0	4 Heaving Clusters	0
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	5 Transit Stops	0	0	\$ 0.00	5 Sidewalk Joint Gap (Excluded)***	0	0	\$ 0.00	5 Sidewalk Joint Gap	0	5 Sidewalk Joint Gap	0
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	6 Railroad Crossings	0	0	\$ 0.00	6 Miscellaneous Obstruction	0	0	\$ 0.00	6 Miscellaneous Obstruction	0	6 Miscellaneous Obstruction	0
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	7 Accessible Parking Spaces	0	0	\$ 0.00	7 Missing Sidewalk Obstruction	0	0	\$ 0.00	7 Missing Sidewalk Obstruction	0	7 Missing Sidewalk Obstruction	0
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Intersection SubTotal:			\$ 24350.00	8 Other Obstruction	0	0	\$ 0.00	8 Other Obstruction	0	8 Other Obstruction	0
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Corridor Total:			\$ 141110.00	9 Pole Post Hydrant Obstruction	0	0	\$ 0.00	9 Pole Post Hydrant Obstruction	0	9 Pole Post Hydrant Obstruction	0
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	1 Curb Ramps - Adjacent	0	0	\$ 0.00	10 Ponding Obstruction	0	0	\$ 0.00	10 Ponding Obstruction	0	10 Ponding Obstruction	0
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	2 Island Curb Cuts - Non Compliant	0	0	\$ 0.00	2 Sidewalk Joint Obstruction	0	0	\$ 0.00	2 Sidewalk Joint Obstruction	0	2 Sidewalk Joint Obstruction	0
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	3 Signals - Compliant	0	0	\$ 0.00	3 Sign Obstruction	0	0	\$ 0.00	3 Sign Obstruction	0	3 Sign Obstruction	0
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	4 Signals - Non Compliant	0	0	\$ 0.00	4 Storm Grate Obstruction	0	0	\$ 0.00	4 Storm Grate Obstruction	0	4 Storm Grate Obstruction	0
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	5 Transit Stops - Compliant	0	0	\$ 0.00	5 Transit Obstruction	0	0	\$ 0.00	5 Transit Obstruction	0	5 Transit Obstruction	0
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	6 Transit Stops - Non Compliant	0	0	\$ 0.00	6 Traffic Obstruction	0	0	\$ 0.00	6 Traffic Obstruction	0	6 Traffic Obstruction	0
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	7 Railroad Crossings - Compliant	0	0	\$ 0.00	7 Tree Obstruction	0	0	\$ 0.00	7 Tree Obstruction	0	7 Tree Obstruction	0
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	8 Accessible Parking - Compliant	0	0	\$ 0.00	8 Utility Obstruction	0	0	\$ 0.00	8 Utility Obstruction	0	8 Utility Obstruction	0
18 Vegetation Obstruction - Low	1 EA	18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00	9 Accessible Parking - Non Compliant	0	0	\$ 0.00	9 Vegetation Obstruction - Low	0	0	\$ 0.00	9 Vegetation Obstruction - Low	0	9 Vegetation Obstruction - Low	0
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	10 Curb Ramps - Adjacent	0	0	\$ 0.00	9 Vegetation Obstruction - Overhead	0	0	\$ 0.00	9 Vegetation Obstruction - Overhead	0	9 Vegetation Obstruction - Overhead	0
20 Commercial Entrance	3 EA	20 Commercial Entrance (within slope violation)	3 EA	\$ 5000.00	\$ 15000.00	11 Island Curb Cuts - Adjacent	0	0	\$ 0.00	10 Commercial Entrance	0	0	\$ 0.00	10 Commercial Entrance	0	10 Commercial Entrance	0
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	12 Signals - Adjacent	0	0	\$ 0.00	11 Residential Entrance	0	0	\$ 0.00	11 Residential Entrance	0	11 Residential Entrance	0
22 Total Sidewalk Length Assessed	3399.735 LF	22 Running Slope Violations**	442.33 SY	\$ 75.00	\$ 33175.00	13 Transit Stops - Adjacent	0	0	\$ 0.00	12 Missing Sidewalk Obstruction	0	0	\$ 0.00	12 Missing Sidewalk Obstruction	0	12 Missing Sidewalk Obstruction	0
23 Average Sidewalk Width	67.5 IN	23 Cross Slope Violations	704.376 SY	\$ 75.00	\$ 52828.00	14 Railroad Crossings - Adjacent	0	0	\$ 0.00	13 Storm Grate Obstruction	0	0	\$ 0.00	13 Storm Grate Obstruction	0	13 Storm Grate Obstruction	0
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	198.758 SY	\$ 75.00	\$ 14907.00	15 Accessible Parking - Adjacent	0	0	\$ 0.00	14 Transit Obstruction	0	0	\$ 0.00	14 Transit Obstruction	0	14 Transit Obstruction	0
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00	16 Sidewalk Collection Path	0	0	\$ 0.00	15 Traffic Obstruction	0	0	\$ 0.00	15 Traffic Obstruction	0	15 Traffic Obstruction	0
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00	17 Adjacent Sidewalk Collection Path	0	0	\$ 0.00	16 Tree Obstruction	0	0	\$ 0.00	16 Tree Obstruction	0	16 Tree Obstruction	0
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00	18 Buried Sidewalk	0	0	\$ 0.00	17 Utility Obstruction	0	0	\$ 0.00	17 Utility Obstruction	0	17 Utility Obstruction	0
Sidewalk SubTotal:					\$ 116760.00	19 Vegetation Obstruction - Low	0	0	\$ 0.00	18 Vegetation Obstruction - Low	0	0	\$ 0.00	18 Vegetation Obstruction - Low	0	18 Vegetation Obstruction - Low	0
						19 Vegetation Obstruction - Overhead	0	0	\$ 0.00	19 Vegetation Obstruction - Overhead	0	0	\$ 0.00	19 Vegetation Obstruction - Overhead	0	19 Vegetation Obstruction - Overhead	0
						20 Commercial Entrance	0	0	\$ 0.00	20 Commercial Entrance	0	0	\$ 0.00	20 Commercial Entrance	0	20 Commercial Entrance	0
						21 Residential Entrance	0	0	\$ 0.00	21 Residential Entrance	0	0	\$ 0.00	21 Residential Entrance	0	21 Residential Entrance	0
						22 Total Sidewalk Length Assessed	3399.735 LF			22 Total Sidewalk Length Assessed	3399.735 LF			22 Total Sidewalk Length Assessed	3399.735 LF	22 Total Sidewalk Length Assessed	3399.735 LF
						23 Average Sidewalk Width	67.5 IN			23 Average Sidewalk Width	67.5 IN			23 Average Sidewalk Width	67.5 IN	23 Average Sidewalk Width	67.5 IN
						24 No Sidewalk on Block (Approx.)	0 LF			24 No Sidewalk on Block (Approx.)	0 LF			24 No Sidewalk on Block (Approx.)	0 LF	24 No Sidewalk on Block (Approx.)	0 LF
						25 Missing Sidewalk Gaps (Approx.)	0 LF			25 Missing Sidewalk Gaps (Approx.)	0 LF			25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF
						26 Poor Surface Condition (Approx.)	0 LF			26 Poor Surface Condition (Approx.)	0 LF			26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF
						27 Buried Sidewalk (Approx.)	0 LF			27 Buried Sidewalk (Approx.)	0 LF			27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF

0

70

140

280

420

560

Feet



1 Heavings < 1" (Excluded)***

2 Heavings ≥ 1" (Excluded)***

3 Uneven Heaving (Excluded)***

4 Heaving Clusters (Excluded)

5 Sidewalk Joint Gap (Excluded)***

6 Miscellaneous Obstruction

7 Missing Sidewalk Obstruction

8 Other Obstruction

9 Pole Post Hydrant Obstruction

10 Ponding Obstruction

11 Sidewalk Joint Obstruction

12 Sign Obstruction

13 Storm Grate Obstruction

14 Transit Obstruction

15 Traffic Obstruction

16 Tree Obstruction

17 Utility Obstruction

18 Vegetation Obstruction - Low

19 Vegetation Obstruction - Overhead

20 Sidewalk Collection Path

21 Adjacent Sidewalk Collection Path

22 Buried Sidewalk

23 Sidewalk Not Surveyed

24 Missing Sidewalk Gap

25 No Sidewalk on Block

1 Heavings < 1"

2 Heavings ≥ 1"

3 Uneven Heaving

4 Heaving Clusters

5 Sidewalk Joint Gap

6 Commercial Entrance

7 Residential Entrance

8 Commercial Entrance (within slope violation)

9 Residential Entrance (within slope violation)

10 Cross Slope

11 2 - 3%

12 3.01 - 4%

13 4.01 - 5%

14 5.01% - 6%

15 6.01 - 7%

16 7.01 - 8%

17 8.01 - 9%

18 9.01 - 10%

19 10.01 - 12%

20 > 12%

21 Running Slope

22 5 - 8.33%

23 8.34% - 10%

24 10.01 - 12.5%

25 > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.