



ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate								
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost				
1 Heavings less than 1"	5 EA		1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	1	1	\$ 3200.00	● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)*** — Heaving Clusters (Excluded) ▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead — Sidewalk Collection Path — Adjacent Sidewalk Collection Path — Buried Sidewalk — Sidewalk Not Surveyed — Missing Sidewalk Gap — No Sidewalk on Block ● Heavings < 1" ● Heavings ≥ 1" ● Uneven Heaving — Heaving Clusters ▲ Sidewalk Joint Gap ◆ Commercial Entrance ◆ Residential Entrance ✚ Commercial Entrance (within slope violation) ✚ Residential Entrance (within slope violation) Cross Slope 2 - 3%7.01 - 8% 3.01 - 4%8.01 - 9% 4.01 - 5%9.01 - 10% 5.01% - 6%10.01 - 12% 6.01 - 7%> 12% Running Slope 5 - 8.33%8.34% - 10% 10.01 - 12.5%> 12.5%			
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00				
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00				
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00				
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00				
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00				
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 3200.00					
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:					\$ 10560.00		
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■ Curb Ramps - Compliant		■ Curb Ramps - Adjacent					
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■ Curb Ramps - Non Compliant							
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	▲ Island Curb Cuts - Compliant		▲ Island Curb Cuts - Adjacent					
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	▲ Island Curb Cuts - Non Compliant							
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Signals - Compliant		■ Signals - Adjacent					
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Non Compliant							
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Transit Stops - Compliant		■ Transit Stops - Adjacent					
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Transit Stops - Non Compliant							
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■ Railroad Crossings - Compliant		■ Railroad Crossings - Adjacent					
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■ Railroad Crossings - Non Compliant							
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■ Accessible Parking - Compliant		■ Accessible Parking - Adjacent					
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■ Accessible Parking - Non Compliant							
21 Residential Entrance	0 EA		21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00								
22 Total Sidewalk Length Assessed	370.017 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00								
23 Average Sidewalk Width	48 IN		23 Cross Slope Violations	96.796 SY	\$ 75.00	\$ 7260.00								
24 No Sidewalk on Block (Approx.)	405.519 LF		24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00								
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00								
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	34.601 LF		27 Buried Sidewalk (Approx.)	34.601 LF	\$ 41.67	\$ 1540.00								
Sidewalk SubTotal:					\$ 7360.00		*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.							
							**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.							