




| ADA Survey Summary                   |            |  | ADA Compliance Cost Estimate *                   |            |            |             |
|--------------------------------------|------------|--|--------------------------------------------------|------------|------------|-------------|
| Item Description                     | Quantity   |  | Item Description                                 | Quantity   | Unit Price | Item Cost   |
| 1 Heavings less than 1"              | 3 EA       |  | 1 Heavings less than 1"                          | 0 EA       | \$ 100.00  | \$ 0.00     |
| 2 Heavings 1" or greater             | 0 EA       |  | 2 Heavings 1" or greater                         | 0 EA       | \$ 400.00  | \$ 0.00     |
| 3 Uneven Heavings                    | 0 EA       |  | 3 Uneven Heavings                                | 0 EA       | \$ 400.00  | \$ 0.00     |
| 4 Heaving Clusters                   | 0 SY       |  | 4 Heaving Clusters                               | 0 SY       | \$ 75.00   | \$ 0.00     |
| 5 Sidewalk Joint Gaps                | 0 EA       |  | 5 Sidewalk Joint Gaps                            | 0 EA       | \$ 200.00  | \$ 0.00     |
| 6 Miscellaneous Obstruction          | 0 EA       |  | 6 Miscellaneous Obstruction                      | 0 EA       | \$ 1500.00 | \$ 0.00     |
| 7 Missing Sidewalk Obstruction       | 0 EA       |  | 7 Missing Sidewalk Obstruction                   | 0 EA       | \$ 200.00  | \$ 0.00     |
| 8 Other Obstruction                  | 0 EA       |  | 8 Other Obstruction                              | 0 EA       | \$ 500.00  | \$ 0.00     |
| 9 Pole Post Hydrant Obstruction      | 0 EA       |  | 9 Pole Post Hydrant Obstruction                  | 0 EA       | \$ 5000.00 | \$ 0.00     |
| 10 Ponding Obstruction               | 0 EA       |  | 10 Ponding Obstruction                           | 0 EA       | \$ 400.00  | \$ 0.00     |
| 11 Sidewalk Joint Obstruction        | 0 EA       |  | 11 Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00  | \$ 0.00     |
| 12 Sign Obstruction                  | 0 EA       |  | 12 Sign Obstruction                              | 0 EA       | \$ 150.00  | \$ 0.00     |
| 13 Storm Grate Obstruction           | 0 EA       |  | 13 Storm Grate Obstruction                       | 0 EA       | \$700.00   | \$ 0.00     |
| 14 Transit Obstruction               | 0 EA       |  | 14 Transit Obstruction                           | 0 EA       | \$500.00   | \$ 0.00     |
| 15 Traffic Obstruction               | 0 EA       |  | 15 Traffic Obstruction                           | 0 EA       | \$2000.00  | \$ 0.00     |
| 16 Tree Obstruction                  | 0 EA       |  | 16 Tree Obstruction                              | 0 EA       | \$500.00   | \$ 0.00     |
| 17 Utility Obstruction               | 0 EA       |  | 17 Utility Obstruction                           | 0 EA       | \$1500.00  | \$ 0.00     |
| 18 Vegetation Obstruction - Low      | 0 EA       |  | 18 Vegetation Obstruction - Low                  | 0 EA       | \$150.00   | \$ 0.00     |
| 19 Vegetation Obstruction - Overhead | 0 EA       |  | 19 Vegetation Obstruction - Overhead             | 0 EA       | \$150.00   | \$ 0.00     |
| 20 Commercial Entrance               | 0 EA       |  | 20 Commercial Entrance (within slope violation)  | 0 EA       | \$ 5000.00 | \$ 0.00     |
| 21 Residential Entrance              | 1 EA       |  | 21 Residential Entrance (within slope violation) | 1 EA       | \$ 3000.00 | \$ 3000.00  |
| 22 Total Sidewalk Length Assessed    | 229.306 LF |  | 22 Running Slope Violations**                    | 0 SY       | \$ 75.00   | \$ 0.00     |
| 23 Average Sidewalk Width            | 54 IN      |  | 23 Cross Slope Violations                        | 62.678 SY  | \$ 75.00   | \$ 4701.00  |
| 24 No Sidewalk on Block (Approx.)    | 463.449 LF |  | 24 Running and Cross Slope Violations            | 25.924 SY  | \$ 75.00   | \$ 1944.00  |
| 25 Missing Sidewalk Gaps (Approx.)   | 0 LF       |  | 25 Missing Sidewalk Gaps (Approx.)               | 0 LF       | \$ 41.67   | \$ 0.00     |
| 26 Poor Surface Condition (Approx.)  | 0 LF       |  | 26 Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67   | \$ 0.00     |
| 27 Buried Sidewalk (Approx.)         | 289.386 LF |  | 27 Buried Sidewalk (Approx.)                     | 289.386 LF | \$ 41.67   | \$ 12100.00 |
|                                      |            |  | Sidewalk SubTotal:                               |            |            | \$ 9645.00  |

| Item Description          | Total Count | Non Compliant Count | Cost        |
|---------------------------|-------------|---------------------|-------------|
| Curb Ramps                | 3           | 3                   | \$ 6550.00  |
| Island Curb Cuts          | 0           | 0                   | \$ 0.00     |
| Signal Push Buttons       | 0           | 0                   | \$ 0.00     |
| Transit Stops             | 3           | 3                   | \$ 6150.00  |
| Railroad Crossings        | 0           | 0                   | \$ 0.00     |
| Accessible Parking Spaces | 0           | 0                   | \$ 0.00     |
| Intersection SubTotal:    |             |                     | \$ 12700.00 |

**Corridor Total:** \$ 22345.00

|                                                                                                                          |                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|
|  Curb Ramps - Compliant             |  Curb Ramps - Adjacent         |
|  Curb Ramps - Non Compliant         |                                                                                                                     |
|  Island Curb Cuts - Compliant       |  Island Curb Cuts - Adjacent   |
|  Island Curb Cuts - Non Compliant   |                                                                                                                     |
|  Signals - Compliant                |  Signals - Adjacent            |
|  Signals - Non Compliant            |                                                                                                                     |
|  Transit Stops - Compliant          |  Transit Stops - Adjacent      |
|  Transit Stops - Non Compliant      |                                                                                                                     |
|  Railroad Crossings - Compliant     |  Railroad Crossings - Adjacent |
|  Railroad Crossings - Non Compliant |                                                                                                                     |
|  Accessible Parking - Compliant     |  Accessible Parking - Adjacent |
|  Accessible Parking - Non Compliant |                                                                                                                     |

**Obstruction Legend:**

- Yellow circle: Heavings < 1" (Excluded)\*\*\*
- Orange circle: Heavings ≥ 1" (Excluded)\*\*\*
- Red circle: Uneven Heaving (Excluded)\*\*\*
- Yellow line: Heaving Clusters (Excluded)
- Purple triangle: Sidewalk Joint Gap (Excluded)\*\*\*
- Purple square: Miscellaneous Obstruction
- Pink square: Missing Sidewalk Obstruction
- Blue square: Other Obstruction
- Orange square: Pole Post Hydrant Obstruction
- Light blue square: Ponding Obstruction
- Yellow square: Sidewalk Joint Obstruction
- Gray square: Sign Obstruction
- Blue square: Storm Grate Obstruction
- Orange square: Transit Obstruction
- Black square: Traffic Obstruction
- Green square: Tree Obstruction
- Black square: Utility Obstruction
- Green square: Vegetation Obstruction - Low
- Teal square: Vegetation Obstruction - Overhead
- Green line: Sidewalk Collection Path
- Gray line: Adjacent Sidewalk Collection Path
- Orange line: Buried Sidewalk
- Brown line: Sidewalk Not Surveyed
- Pink line: Missing Sidewalk Gap
- Blue line: No Sidewalk on Block

**Heaving and Unevenness Legend:**

- Yellow circle: Heavings < 1"
- Orange circle: Heavings ≥ 1"
- Red circle: Uneven Heaving
- Yellow line: Heaving Clusters
- Purple triangle: Sidewalk Joint Gap
- Purple diamond: Commercial Entrance
- Purple diamond: Residential Entrance
- Purple cross: Commercial Entrance (within slope violation)
- Purple cross: Residential Entrance (within slope violation)

**Cross Slope Legend:**

- Light red: 2 - 3%
- Red: 7.01 - 8%
- Light red: 3.01 - 4%
- Red: 8.01 - 9%
- Light red: 4.01 - 5%
- Red: 9.01 - 10%
- Light red: 5.01% - 6%
- Red: 10.01 - 12%
- Light red: 6.01 - 7%
- Red: > 12%

**Running Slope Legend:**

- Light blue: 5 - 8.33%
- Blue: 8.34% - 10%
- Dark blue: 10.01 - 12.5%
- Dark blue: > 12.5%

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

\*\*\*Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.