



| ADA Survey Summary                                                                                                                                                                                                                                                                                                 |                                   |             | ADA Compliance Cost Estimate * |                                               |          |            | Intersection Inventory & Compliance Cost Estimate |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|-------------|--------------------------------|-----------------------------------------------|----------|------------|---------------------------------------------------|---------------------------|------------------------------------|---------------------|-------------------------------|---|-----------------------------------|---|-----------------------------------------------|---|-------------|
| Item                                                                                                                                                                                                                                                                                                               | Description                       | Quantity    | Item                           | Description                                   | Quantity | Unit Price | Item Cost                                         | Item Description          | Total Count                        | Non Compliant Count | Cost                          |   |                                   |   |                                               |   |             |
| 1                                                                                                                                                                                                                                                                                                                  | Heavings less than 1"             | 0 EA        | 1                              | Heavings less than 1"                         | 0 EA     | \$ 100.00  | \$ 0.00                                           | Curb Ramps                | 0                                  | 0                   | \$ 0.00                       | ● | Heavings < 1" (Excluded)***       | ● | Heavings < 1"                                 |   |             |
| 2                                                                                                                                                                                                                                                                                                                  | Heavings 1" or greater            | 0 EA        | 2                              | Heavings 1" or greater                        | 0 EA     | \$ 400.00  | \$ 0.00                                           | Island Curb Cuts          | 0                                  | 0                   | \$ 0.00                       | ● | Heavings ≥ 1" (Excluded)***       | ● | Heavings ≥ 1"                                 |   |             |
| 3                                                                                                                                                                                                                                                                                                                  | Uneven Heavings                   | 0 EA        | 3                              | Uneven Heavings                               | 0 EA     | \$ 400.00  | \$ 0.00                                           | Signal Push Buttons       | 0                                  | 0                   | \$ 0.00                       | ● | Uneven Heaving (Excluded)***      | ● | Uneven Heaving                                |   |             |
| 4                                                                                                                                                                                                                                                                                                                  | Heaving Clusters                  | 0 SY        | 4                              | Heaving Clusters                              | 0 SY     | \$ 75.00   | \$ 0.00                                           | Transit Stops             | 0                                  | 0                   | \$ 0.00                       | — | Heaving Clusters (Excluded)       | — | Heaving Clusters                              |   |             |
| 5                                                                                                                                                                                                                                                                                                                  | Sidewalk Joint Gaps               | 0 EA        | 5                              | Sidewalk Joint Gaps                           | 0 EA     | \$ 200.00  | \$ 0.00                                           | Railroad Crossings        | 0                                  | 0                   | \$ 0.00                       | ▲ | Sidewalk Joint Gap (Excluded)***  | ▲ | Sidewalk Joint Gap                            |   |             |
| 6                                                                                                                                                                                                                                                                                                                  | Miscellaneous Obstruction         | 0 EA        | 6                              | Miscellaneous Obstruction                     | 0 EA     | \$ 1500.00 | \$ 0.00                                           | Accessible Parking Spaces | 0                                  | 0                   | \$ 0.00                       | ■ | Miscellaneous Obstruction         | ◆ | Commercial Entrance                           |   |             |
| 7                                                                                                                                                                                                                                                                                                                  | Missing Sidewalk Obstruction      | 0 EA        | 7                              | Missing Sidewalk Obstruction                  | 0 EA     | \$ 200.00  | \$ 0.00                                           | Intersection SubTotal:    |                                    | \$ 0.00             |                               | ■ | Missing Sidewalk Obstruction      | ◆ | Residential Entrance                          |   |             |
| 8                                                                                                                                                                                                                                                                                                                  | Other Obstruction                 | 0 EA        | 8                              | Other Obstruction                             | 0 EA     | \$ 500.00  | \$ 0.00                                           | Corridor Total:           |                                    | \$ 0.00             |                               | ■ | Other Obstruction                 | ⊕ | Commercial Entrance (within slope violation)  |   |             |
| 9                                                                                                                                                                                                                                                                                                                  | Pole Post Hydrant Obstruction     | 0 EA        | 9                              | Pole Post Hydrant Obstruction                 | 0 EA     | \$ 5000.00 | \$ 0.00                                           |                           |                                    |                     |                               | ■ | Pole Post Hydrant Obstruction     | ⊕ | Residential Entrance (within slope violation) |   |             |
| 10                                                                                                                                                                                                                                                                                                                 | Ponding Obstruction               | 0 EA        | 10                             | Ponding Obstruction                           | 0 EA     | \$ 400.00  | \$ 0.00                                           |                           |                                    |                     |                               | ■ | Ponding Obstruction               |   | Cross Slope                                   |   |             |
| 11                                                                                                                                                                                                                                                                                                                 | Sidewalk Joint Obstruction        | 0 EA        | 11                             | Sidewalk Joint Obstruction                    | 0 EA     | \$ 100.00  | \$ 0.00                                           | ■                         | Curb Ramps - Compliant             | ■                   | Curb Ramps - Adjacent         | ■ | Sidewalk Joint Obstruction        | ■ | 2 - 3%                                        | ■ | 7.01 - 8%   |
| 12                                                                                                                                                                                                                                                                                                                 | Sign Obstruction                  | 0 EA        | 12                             | Sign Obstruction                              | 0 EA     | \$ 150.00  | \$ 0.00                                           | ■                         | Curb Ramps - Non Compliant         |                     |                               | ■ | Sign Obstruction                  | ■ | 3.01 - 4%                                     | ■ | 8.01 - 9%   |
| 13                                                                                                                                                                                                                                                                                                                 | Storm Grate Obstruction           | 0 EA        | 13                             | Storm Grate Obstruction                       | 0 EA     | \$700.00   | \$ 0.00                                           | ■                         | Island Curb Cuts - Compliant       | ■                   | Island Curb Cuts - Adjacent   | ■ | Storm Grate Obstruction           | ■ | 4.01 - 5%                                     | ■ | 9.01 - 10%  |
| 14                                                                                                                                                                                                                                                                                                                 | Transit Obstruction               | 0 EA        | 14                             | Transit Obstruction                           | 0 EA     | \$500.00   | \$ 0.00                                           | ■                         | Island Curb Cuts - Non Compliant   |                     |                               | ■ | Transit Obstruction               | ■ | 5.01% - 6%                                    | ■ | 10.01 - 12% |
| 15                                                                                                                                                                                                                                                                                                                 | Traffic Obstruction               | 0 EA        | 15                             | Traffic Obstruction                           | 0 EA     | \$2000.00  | \$ 0.00                                           | ■                         | Signals - Compliant                | ■                   | Signals - Adjacent            | ■ | Traffic Obstruction               | ■ | 6.01 - 7%                                     | ■ | > 12%       |
| 16                                                                                                                                                                                                                                                                                                                 | Tree Obstruction                  | 0 EA        | 16                             | Tree Obstruction                              | 0 EA     | \$500.00   | \$ 0.00                                           | ■                         | Signals - Non Compliant            |                     |                               | ■ | Tree Obstruction                  |   | Running Slope                                 |   |             |
| 17                                                                                                                                                                                                                                                                                                                 | Utility Obstruction               | 0 EA        | 17                             | Utility Obstruction                           | 0 EA     | \$1500.00  | \$ 0.00                                           | ■                         | Transit Stops - Compliant          | ■                   | Transit Stops - Adjacent      | ■ | Utility Obstruction               | ■ | 5 - 8.33%                                     | ■ |             |
| 18                                                                                                                                                                                                                                                                                                                 | Vegetation Obstruction - Low      | 0 EA        | 18                             | Vegetation Obstruction - Low                  | 0 EA     | \$150.00   | \$ 0.00                                           | ■                         | Transit Stops - Non Compliant      |                     |                               | ■ | Vegetation Obstruction - Low      | ■ | 8.34% - 10%                                   | ■ |             |
| 19                                                                                                                                                                                                                                                                                                                 | Vegetation Obstruction - Overhead | 0 EA        | 19                             | Vegetation Obstruction - Overhead             | 0 EA     | \$150.00   | \$ 0.00                                           | ■                         | Railroad Crossings - Compliant     | ■                   | Railroad Crossings - Adjacent | ■ | Vegetation Obstruction - Overhead | ■ | 10.01 - 12.5%                                 | ■ |             |
| 20                                                                                                                                                                                                                                                                                                                 | Commercial Entrance               | 0 EA        | 20                             | Commercial Entrance (within slope violation)  | 0 EA     | \$ 5000.00 | \$ 0.00                                           | ■                         | Railroad Crossings - Non Compliant |                     |                               | ■ | Sidewalk Collection Path          | ■ | > 12.5%                                       | ■ |             |
| 21                                                                                                                                                                                                                                                                                                                 | Residential Entrance              | 0 EA        | 21                             | Residential Entrance (within slope violation) | 0 EA     | \$ 3000.00 | \$ 0.00                                           | ■                         | Accessible Parking - Compliant     | ■                   | Accessible Parking - Adjacent | ■ | Adjacent Sidewalk Collection Path | ■ |                                               | ■ |             |
| 22                                                                                                                                                                                                                                                                                                                 | Total Sidewalk Length Assessed    | 0 LF        | 22                             | Running Slope Violations**                    | 0 SY     | \$ 75.00   | \$ 0.00                                           | ■                         | Accessible Parking - Non Compliant |                     |                               | ■ | Buried Sidewalk                   | ■ |                                               | ■ |             |
| 23                                                                                                                                                                                                                                                                                                                 | Average Sidewalk Width            | 0 IN        | 23                             | Cross Slope Violations                        | 0 SY     | \$ 75.00   | \$ 0.00                                           |                           |                                    |                     |                               | ■ | Sidewalk Not Surveyed             | ■ |                                               | ■ |             |
| 24                                                                                                                                                                                                                                                                                                                 | No Sidewalk on Block (Approx.)    | 1380.468 LF | 24                             | Running and Cross Slope Violations            | 0 SY     | \$ 75.00   | \$ 0.00                                           |                           |                                    |                     |                               | ■ | Missing Sidewalk Gap              | ■ |                                               | ■ |             |
| 25                                                                                                                                                                                                                                                                                                                 | Missing Sidewalk Gaps (Approx.)   | 0 LF        | 25                             | Missing Sidewalk Gaps (Approx.)               | 0 LF     | \$ 41.67   | \$ 0.00                                           |                           |                                    |                     |                               | ■ | No Sidewalk on Block              | ■ |                                               | ■ |             |
| 26                                                                                                                                                                                                                                                                                                                 | Poor Surface Condition (Approx.)  | 0 LF        | 26                             | Poor Surface Condition (Approx.)              | 0 LF     | \$ 41.67   | \$ 0.00                                           |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |
| 27                                                                                                                                                                                                                                                                                                                 | Buried Sidewalk (Approx.)         | 0 LF        | 27                             | Buried Sidewalk (Approx.)                     | 0 LF     | \$ 41.67   | \$ 0.00                                           |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |
|                                                                                                                                                                                                                                                                                                                    |                                   |             |                                | Sidewalk SubTotal:                            |          |            |                                                   | \$ 0.00                   |                                    |                     |                               |   |                                   |   |                                               |   |             |
| *Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. |                                   |             |                                |                                               |          |            |                                                   |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |
| **Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.                                                                                                                                                                                                |                                   |             |                                |                                               |          |            |                                                   |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |
| ***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.                                                                                                                                                                                    |                                   |             |                                |                                               |          |            |                                                   |                           |                                    |                     |                               |   |                                   |   |                                               |   |             |