

To: BRECKFIELD_CT



Intersection Inventory & Compliance Cost Estimate			
Item Description	Total Count	Non Compliant Count	Cost
Curb Ramps	3	3	\$ 7900.00
Island Curb Cuts	0	0	\$ 0.00
Signal Push Buttons	0	0	\$ 0.00
Transit Stops	0	0	\$ 0.00
Railroad Crossings	0	0	\$ 0.00
Accessible Parking Spaces	0	0	\$ 0.00
Intersection SubTotal:			\$ 7900.00
Corridor Total:		\$	15545.00

 Curb Ramps - Compliant	 Curb Ramps - Adjacent
 Curb Ramps - Non Compliant	
 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent
 Island Curb Cuts - Non Compliant	
 Signals - Compliant	 Signals - Adjacent
 Signals - Non Compliant	
 Transit Stops - Compliant	 Transit Stops - Adjacent
 Transit Stops - Non Compliant	
 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent
 Railroad Crossings - Non Compliant	
 Accessible Parking - Compliant	 Accessible Parking - Adjacent
 Accessible Parking - Non Compliant	

*Note: ADA pedestrian issues corrective measure. The ADA

**Note: Additional investigation

The legend is organized into two columns. The left column lists 20 sidewalk issues, each preceded by a small colored square or line segment. The right column lists 10 issues, each preceded by a small colored circle. Below these lists are two sections: 'Cross Slope' and 'Running Slope', each with a color-coded range of values.

Issue	Symbol/Color
Heavings < 1" (Excluded)***	Yellow circle
Heavings ≥ 1" (Excluded)***	Orange circle
Uneven Heaving (Excluded)***	Red circle
Heaving Clusters (Excluded)	Yellow line
Sidewalk Joint Gap (Excluded)***	Purple triangle
Miscellaneous Obstruction	Purple diamond
Missing Sidewalk Obstruction	Pink square
Other Obstruction	Blue square
Pole Post Hydrant Obstruction	Orange square
Ponding Obstruction	Light blue square
Sidewalk Joint Obstruction	Yellow square
Sign Obstruction	Gray square
Storm Grate Obstruction	Blue square
Transit Obstruction	Orange square
Traffic Obstruction	Black square
Tree Obstruction	Green square
Utility Obstruction	Black square
Vegetation Obstruction - Low	Green square
Vegetation Obstruction - Overhead	Teal square
Sidewalk Collection Path	Green line
Adjacent Sidewalk Collection Path	Gray line
Buried Sidewalk	Orange line
Sidewalk Not Surveyed	Brown line
Missing Sidewalk Gap	Pink line
No Sidewalk on Block	Blue line
Heavings < 1"	Yellow circle
Heavings ≥ 1"	Orange circle
Uneven Heaving	Red circle
Heaving Clusters	Yellow line
Sidewalk Joint Gap	Purple triangle
Commercial Entrance	Purple diamond
Residential Entrance	Pink diamond
Commercial Entrance (within slope violation)	Purple plus
Residential Entrance (within slope violation)	Pink plus

Cross Slope	
2 - 3%	7.01 - 8%
3.01 - 4%	8.01 - 9%
4.01 - 5%	9.01 - 10%
5.01% - 6%	10.01 - 12%
6.01 - 7%	> 12%

Running Slope	
5 - 8.33%	
8.34% - 10%	
10.01 - 12.5%	
> 12.5%	

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.