




| ADA Survey Summary |                                   |            | ADA Compliance Cost Estimate * |                                               |            |            | Intersection Inventory & Compliance Cost Estimate |                           |             |             |                     |         |                                     |                                                 |
|--------------------|-----------------------------------|------------|--------------------------------|-----------------------------------------------|------------|------------|---------------------------------------------------|---------------------------|-------------|-------------|---------------------|---------|-------------------------------------|-------------------------------------------------|
| Item               | Description                       | Quantity   | Item                           | Description                                   | Quantity   | Unit Price | Item Cost                                         | Item                      | Description | Total Count | Non Compliant Count | Cost    |                                     |                                                 |
| 1                  | Heavings less than 1"             | 3 EA       | 1                              | Heavings less than 1"                         | 2 EA       | \$ 100.00  | \$ 200.00                                         | Curb Ramps                |             | 0           | 0                   | \$ 0.00 | ● Heavings < 1" (Excluded)***       | ● Heavings < 1"                                 |
| 2                  | Heavings 1" or greater            | 0 EA       | 2                              | Heavings 1" or greater                        | 0 EA       | \$ 400.00  | \$ 0.00                                           | Island Curb Cuts          |             | 0           | 0                   | \$ 0.00 | ● Heavings ≥ 1" (Excluded)***       | ● Heavings ≥ 1"                                 |
| 3                  | Uneven Heavings                   | 0 EA       | 3                              | Uneven Heavings                               | 0 EA       | \$ 400.00  | \$ 0.00                                           | Signal Push Buttons       |             | 0           | 0                   | \$ 0.00 | ● Uneven Heaving (Excluded)***      | ● Uneven Heaving                                |
| 4                  | Heaving Clusters                  | 0 SY       | 4                              | Heaving Clusters                              | 0 SY       | \$ 75.00   | \$ 0.00                                           | Transit Stops             |             | 0           | 0                   | \$ 0.00 | — Heaving Clusters (Excluded)       | — Heaving Clusters                              |
| 5                  | Sidewalk Joint Gaps               | 0 EA       | 5                              | Sidewalk Joint Gaps                           | 0 EA       | \$ 200.00  | \$ 0.00                                           | Railroad Crossings        |             | 0           | 0                   | \$ 0.00 | ▲ Sidewalk Joint Gap (Excluded)***  | ▲ Sidewalk Joint Gap                            |
| 6                  | Miscellaneous Obstruction         | 0 EA       | 6                              | Miscellaneous Obstruction                     | 0 EA       | \$ 1500.00 | \$ 0.00                                           | Accessible Parking Spaces |             | 0           | 0                   | \$ 0.00 | ■ Miscellaneous Obstruction         | ◆ Commercial Entrance                           |
| 7                  | Missing Sidewalk Obstruction      | 0 EA       | 7                              | Missing Sidewalk Obstruction                  | 0 EA       | \$ 200.00  | \$ 0.00                                           | Intersection SubTotal:    |             |             |                     | \$ 0.00 | ■ Missing Sidewalk Obstruction      | ◆ Residential Entrance                          |
| 8                  | Other Obstruction                 | 0 EA       | 8                              | Other Obstruction                             | 0 EA       | \$ 500.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Other Obstruction                 | ✚ Commercial Entrance (within slope violation)  |
| 9                  | Pole Post Hydrant Obstruction     | 0 EA       | 9                              | Pole Post Hydrant Obstruction                 | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |             |                     |         | ■ Pole Post Hydrant Obstruction     | ✚ Residential Entrance (within slope violation) |
| 10                 | Ponding Obstruction               | 0 EA       | 10                             | Ponding Obstruction                           | 0 EA       | \$ 400.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Ponding Obstruction               |                                                 |
| 11                 | Sidewalk Joint Obstruction        | 0 EA       | 11                             | Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Sidewalk Joint Obstruction        |                                                 |
| 12                 | Sign Obstruction                  | 0 EA       | 12                             | Sign Obstruction                              | 0 EA       | \$ 150.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Sign Obstruction                  |                                                 |
| 13                 | Storm Grate Obstruction           | 0 EA       | 13                             | Storm Grate Obstruction                       | 0 EA       | \$700.00   | \$ 0.00                                           |                           |             |             |                     |         | ■ Storm Grate Obstruction           |                                                 |
| 14                 | Transit Obstruction               | 0 EA       | 14                             | Transit Obstruction                           | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |             |                     |         | ■ Transit Obstruction               |                                                 |
| 15                 | Traffic Obstruction               | 0 EA       | 15                             | Traffic Obstruction                           | 0 EA       | \$2000.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Traffic Obstruction               |                                                 |
| 16                 | Tree Obstruction                  | 0 EA       | 16                             | Tree Obstruction                              | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |             |                     |         | ■ Tree Obstruction                  | Running Slope                                   |
| 17                 | Utility Obstruction               | 0 EA       | 17                             | Utility Obstruction                           | 0 EA       | \$1500.00  | \$ 0.00                                           |                           |             |             |                     |         | ■ Utility Obstruction               | — 5 - 8.33%                                     |
| 18                 | Vegetation Obstruction - Low      | 0 EA       | 18                             | Vegetation Obstruction - Low                  | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |             |                     |         | ■ Vegetation Obstruction - Low      | — 8.34% - 10%                                   |
| 19                 | Vegetation Obstruction - Overhead | 0 EA       | 19                             | Vegetation Obstruction - Overhead             | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |             |                     |         | ■ Vegetation Obstruction - Overhead | — 10.01 - 12.5%                                 |
| 20                 | Commercial Entrance               | 0 EA       | 20                             | Commercial Entrance (within slope violation)  | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |             |                     |         | — Sidewalk Collection Path          | — > 12.5%                                       |
| 21                 | Residential Entrance              | 3 EA       | 21                             | Residential Entrance (within slope violation) | 3 EA       | \$ 3000.00 | \$ 9000.00                                        |                           |             |             |                     |         | — Adjacent Sidewalk Collection Path |                                                 |
| 22                 | Total Sidewalk Length Assessed    | 517.876 LF | 22                             | Running Slope Violations**                    | 54.243 SY  | \$ 75.00   | \$ 4068.00                                        |                           |             |             |                     |         | — Buried Sidewalk                   |                                                 |
| 23                 | Average Sidewalk Width            | 60 IN      | 23                             | Cross Slope Violations                        | 72.238 SY  | \$ 75.00   | \$ 5418.00                                        |                           |             |             |                     |         | — Sidewalk Not Surveyed             |                                                 |
| 24                 | No Sidewalk on Block (Approx.)    | 0 LF       | 24                             | Running and Cross Slope Violations            | 35.457 SY  | \$ 75.00   | \$ 2659.00                                        |                           |             |             |                     |         | — Missing Sidewalk Gap              |                                                 |
| 25                 | Missing Sidewalk Gaps (Approx.)   | 466.656 LF | 25                             | Missing Sidewalk Gaps (Approx.)               | 466.656 LF | \$ 41.67   | \$ 19360.00                                       |                           |             |             |                     |         | — No Sidewalk on Block              |                                                 |
| 26                 | Poor Surface Condition (Approx.)  | 0 LF       | 26                             | Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |             |                     |         |                                     |                                                 |
| 27                 | Buried Sidewalk (Approx.)         | 0 LF       | 27                             | Buried Sidewalk (Approx.)                     | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |             |                     |         |                                     |                                                 |
|                    |                                   |            |                                | Sidewalk SubTotal:                            |            |            | \$ 21345.00                                       |                           |             |             |                     |         |                                     |                                                 |

Corridor Total:

\$ 40705.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

■ Island Curb Cuts - Compliant

■ Island Curb Cuts - Non Compliant

■ Signals - Compliant

■ Signals - Non Compliant

■ Transit Stops - Compliant

■ Transit Stops - Non Compliant

■ Railroad Crossings - Compliant

■ Railroad Crossings - Non Compliant

■ Accessible Parking - Compliant

■ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

■ Island Curb Cuts - Adjacent

■ Signals - Adjacent

■ Transit Stops - Adjacent

■ Railroad Crossings - Adjacent

■ Accessible Parking - Adjacent

● Heavings < 1" (Excluded)\*\*\*

● Heavings ≥ 1" (Excluded)\*\*\*

● Uneven Heaving (Excluded)\*\*\*

— Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)\*\*\*

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

— Sidewalk Collection Path

— Adjacent Sidewalk Collection Path

— Buried Sidewalk

— Sidewalk Not Surveyed

— Missing Sidewalk Gap

— No Sidewalk on Block

● Heavings < 1"

● Heavings ≥ 1"

● Uneven Heaving

— Heaving Clusters

▲ Sidewalk Joint Gap

◆ Commercial Entrance

◆ Residential Entrance

✚ Commercial Entrance (within slope violation)

✚ Residential Entrance (within slope violation)

Cross Slope

— 2 - 3%

— 3.01 - 4%

— 4.01 - 5%

— 5.01% - 6%

— 6.01 - 7%

— 7.01 - 8%

— 8.01 - 9%

— 9.01 - 10%

— 10.01 - 12%

— > 12%

Running Slope

— 5 - 8.33%

— 8.34% - 10%

— 10.01 - 12.5%

— > 12.5%

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

\*\*\*Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.