



ADA Survey Summary						ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description		Quantity	Item Description		Quantity	Unit Price	Item Cost			Item Description	Total Count	Non Compliant Count	Cost				
1	Heavings less than 1"	13 EA	1	Heavings less than 1"	7 EA	\$ 100.00	\$	700.00		Curb Ramps	1	1	\$ 3200.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"
2	Heavings 1" or greater	3 EA	2	Heavings 1" or greater	1 EA	\$ 400.00	\$	400.00		Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00		Signal Push Buttons	0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving
4	Heaving Clusters	15.055 SY	4	Heaving Clusters	13.278 SY	\$ 75.00	\$	996.00		Transit Stops	0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00		Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00		Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00		Intersection SubTotal:			\$ 3200.00	■	Missing Sidewalk Obstruction	◆	Residential Entrance
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00						■	Other Obstruction	⊕	Commercial Entrance (within slope violation)
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00						■	Pole Post Hydrant Obstruction	⊕	Residential Entrance (within slope violation)
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00						■	Ponding Obstruction		
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00						■	Sidewalk Joint Obstruction		
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00						■	Sign Obstruction		
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00						■	Storm Grate Obstruction		
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00						■	Transit Obstruction		
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00						■	Traffic Obstruction		
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00						■	Tree Obstruction		
17	Utility Obstruction	1 EA	17	Utility Obstruction	1 EA	\$1500.00	\$	1500.00						■	Utility Obstruction		
18	Vegetation Obstruction - Low	2 EA	18	Vegetation Obstruction - Low	2 EA	\$150.00	\$	300.00						■	Vegetation Obstruction - Low		
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$	150.00						■	Vegetation Obstruction - Overhead		
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$	0.00						■	Sidewalk Collection Path		
21	Residential Entrance	8 EA	21	Residential Entrance (within slope violation)	4 EA	\$ 3000.00	\$	12000.00						■	Adjacent Sidewalk Collection Path		
22	Total Sidewalk Length Assessed	763.859 LF	22	Running Slope Violations**	24.533 SY	\$ 75.00	\$	1840.00						■	Buried Sidewalk		
23	Average Sidewalk Width	48 IN	23	Cross Slope Violations	122.189 SY	\$ 75.00	\$	9164.00						■	Sidewalk Not Surveyed		
24	No Sidewalk on Block (Approx.)	1016.565 LF	24	Running and Cross Slope Violations	74.238 SY	\$ 75.00	\$	5568.00						■	Missing Sidewalk Gap		
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00						■	No Sidewalk on Block		
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00									
27	Buried Sidewalk (Approx.)	294.364 LF	27	Buried Sidewalk (Approx.)	294.364 LF	\$ 41.67	\$	12320.00									
			Sidewalk SubTotal:				\$	32618.00									

Corridor Total:

\$ 35818.00

■

Curb Ramps - Compliant

■

Curb Ramps - Non Compliant

■

Island Curb Cuts - Compliant

■

Island Curb Cuts - Non Compliant

■

Signals - Compliant

■

Signals - Non Compliant

■

Transit Stops - Compliant

■

Transit Stops - Non Compliant

■

Railroad Crossings - Compliant

■

Railroad Crossings - Non Compliant

■

Accessible Parking - Compliant

■

Accessible Parking - Non Compliant

■

Curb Ramps - Adjacent

■

Island Curb Cuts - Adjacent

■

Signals - Adjacent

■

Transit Stops - Adjacent

■

Railroad Crossings - Adjacent

■

Accessible Parking - Adjacent

■

Heavings < 1"

■

Heavings ≥ 1"

■

Uneven Heaving

■

Sidewalk Joint Gap

■

Miscellaneous Obstruction

■

Missing Sidewalk Obstruction

■

Other Obstruction

■

Pole Post Hydrant Obstruction

■

Ponding Obstruction

■

Sidewalk Joint Obstruction

■

Sign Obstruction

■

Storm Grate Obstruction

■

Transit Obstruction

■

Traffic Obstruction

■

Tree Obstruction

■

Utility Obstruction

■

Vegetation Obstruction - Low

■

Vegetation Obstruction - Overhead

■

Sidewalk Collection Path

■

Adjacent Sidewalk Collection Path

■

Buried Sidewalk

■

Sidewalk Not Surveyed

■

Missing Sidewalk Gap

■

No Sidewalk on Block

■

2 - 3%

■

3.01 - 4%

■

4.01 - 5%

■

5.01% - 6%

■

6.01 - 7%

■

7.01 - 8%

■

8.01 - 9%

■

9.01 - 10%

■

10.01 - 12%

■

> 12%

■

5 - 8.33%

■

8.34% - 10%

■

10.01 - 12.5%

■

> 12.5%

■

ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.