




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	Heavings < 1" (Excluded)***	Heavings < 1"	Heaving Clusters (Excluded)	Sidewalk Joint Gap (Excluded)***
1 Heavings less than 1"	8 EA	1 Heavings less than 1"	5 EA	\$ 100.00	\$ 500.00	Curb Ramps	0	0	\$ 0.00	Heavings ≥ 1" (Excluded)***	Heavings ≥ 1"	Uneven Heaving (Excluded)***	Sidewalk Joint Gap
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	Uneven Heaving (Excluded)***	Uneven Heaving	Heaving Clusters (Excluded)	Sidewalk Joint Gap
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	Miscellaneous Obstruction	Commercial Entrance	Sidewalk Joint Gap (Excluded)***	Sidewalk Joint Gap
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	Missing Sidewalk Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	Other Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	Pole Post Hydrant Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 0.00	Ponding Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:			\$ 25734.00	Sidewalk Joint Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Curb Ramps - Compliant				Sign Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	Curb Ramps - Non Compliant				Storm Grate Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	Island Curb Cuts - Compliant				Transit Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	Island Curb Cuts - Non Compliant				Traffic Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	Signals - Compliant				Tree Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	Signals - Non Compliant				Utility Obstruction	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	Transit Stops - Compliant				Vegetation Obstruction - Low	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	Transit Stops - Non Compliant				Vegetation Obstruction - Overhead	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	Railroad Crossings - Compliant				Sidewalk Collection Path	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	Railroad Crossings - Non Compliant				Adjacent Sidewalk Collection Path	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	Accessible Parking - Compliant				Buried Sidewalk	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	Accessible Parking - Non Compliant				Sidewalk Not Surveyed	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
21 Residential Entrance	4 EA	21 Residential Entrance (within slope violation)	4 EA	\$ 3000.00	\$ 12000.00					Missing Sidewalk Gap	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
22 Total Sidewalk Length Assessed	528.041 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					No Sidewalk on Block	Residential Entrance	Sidewalk Joint Gap (Excluded)***	Commercial Entrance
23 Average Sidewalk Width	60 IN	23 Cross Slope Violations	142.805 SY	\$ 75.00	\$ 10710.00								
24 No Sidewalk on Block (Approx.)	0 LF	24 Running and Cross Slope Violations	33.65 SY	\$ 75.00	\$ 2524.00								
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00								
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	162.219 LF	27 Buried Sidewalk (Approx.)	162.219 LF	\$ 41.67	\$ 6820.00								
		Sidewalk SubTotal:			\$ 25734.00								

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.