




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate						
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost		
1 Heavings less than 1"	13 EA		1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	2	2	\$ 3000.00	● Heavings < 1" (Excluded)***	
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	▬ Heaving Clusters (Excluded)	
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 3000.00		■ Missing Sidewalk Obstruction	
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction	
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction	
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction	
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction	
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction	
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■ Storm Grate Obstruction	
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■ Transit Obstruction	
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■ Traffic Obstruction	
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■ Tree Obstruction	
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■ Utility Obstruction	
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Low	
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Overhead	
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00					▬ Sidewalk Collection Path	
21 Residential Entrance	5 EA		21 Residential Entrance (within slope violation)	5 EA	\$ 3000.00	\$ 15000.00					▬ Adjacent Sidewalk Collection Path	
22 Total Sidewalk Length Assessed	379.101 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					▬ Buried Sidewalk	
23 Average Sidewalk Width	48 IN		23 Cross Slope Violations	131.348 SY	\$ 75.00	\$ 9851.00					▬ Sidewalk Not Surveyed	
24 No Sidewalk on Block (Approx.)	365.762 LF		24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00					▬ Missing Sidewalk Gap	
25 Missing Sidewalk Gaps (Approx.)	23.198 LF		25 Missing Sidewalk Gaps (Approx.)	23.198 LF	\$ 41.67	\$ 880.00					▬ No Sidewalk on Block	
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00						
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00						
			Sidewalk SubTotal:			\$ 24951.00						
							Corridor Total:		\$ 28831.00			
							Curb Ramps - Compliant		Curb Ramps - Adjacent			
							Curb Ramps - Non Compliant		Island Curb Cuts - Adjacent			
							Island Curb Cuts - Compliant		Island Curb Cuts - Non Compliant			
							Island Curb Cuts - Non Compliant		Signals - Adjacent			
							Signals - Compliant		Signals - Non Compliant			
							Signals - Non Compliant		Transit Stops - Adjacent			
							Transit Stops - Compliant		Transit Stops - Non Compliant			
							Transit Stops - Non Compliant		Railroad Crossings - Adjacent			
							Railroad Crossings - Compliant		Railroad Crossings - Non Compliant			
							Railroad Crossings - Non Compliant		Accessible Parking - Adjacent			
							Accessible Parking - Compliant		Accessible Parking - Non Compliant			
							Accessible Parking - Non Compliant					
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.												
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.												