




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate						
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost		
1 Heavings less than 1"	4 EA		1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	3	3	\$ 5150.00	● Heavings < 1" (Excluded)***	● Heavings < 1"
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	1	1	\$ 700.00	● Uneven Heaving (Excluded)***	● Uneven Heaving
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	— Heaving Clusters (Excluded)	— Heaving Clusters
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Miscellaneous Obstruction	◆ Commercial Entrance
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 5850.00	■ Missing Sidewalk Obstruction	◆ Residential Entrance
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■ Other Obstruction	✚ Commercial Entrance (within slope violation)
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00					■ Pole Post Hydrant Obstruction	✚ Residential Entrance (within slope violation)
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Ponding Obstruction	
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Joint Obstruction	Cross Slope
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ Sign Obstruction	2 - 3% 7.01 - 8%
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00					■ Storm Grate Obstruction	3.01 - 4% 8.01 - 9%
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00					■ Transit Obstruction	4.01 - 5% 9.01 - 10%
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00					■ Traffic Obstruction	5.01% - 6% 10.01 - 12%
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00					■ Tree Obstruction	6.01 - 7% > 12%
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00					■ Utility Obstruction	Running Slope
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Low	5 - 8.33%
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00					■ Vegetation Obstruction - Overhead	8.34% - 10%
20 Commercial Entrance	2 EA		20 Commercial Entrance (within slope violation)	2 EA	\$ 5000.00	\$ 10000.00					— Sidewalk Collection Path	10.01 - 12.5%
21 Residential Entrance	0 EA		21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00					— Adjacent Sidewalk Collection Path	> 12.5%
22 Total Sidewalk Length Assessed	235.526 LF		22 Running Slope Violations**	7.325 SY	\$ 75.00	\$ 549.00					— Buried Sidewalk	
23 Average Sidewalk Width	60 IN		23 Cross Slope Violations	44.387 SY	\$ 75.00	\$ 3329.00					— Sidewalk Not Surveyed	
24 No Sidewalk on Block (Approx.)	0 LF		24 Running and Cross Slope Violations	17.871 SY	\$ 75.00	\$ 1340.00					— Missing Sidewalk Gap	
25 Missing Sidewalk Gaps (Approx.)	42.36 LF		25 Missing Sidewalk Gaps (Approx.)	42.36 LF	\$ 41.67	\$ 1760.00					— No Sidewalk on Block	
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00						
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00						
			Sidewalk SubTotal:			\$ 15319.00						
							Corridor Total:		\$	22929.00		
							■ Curb Ramps - Compliant		■	Curb Ramps - Adjacent		
							■ Curb Ramps - Non Compliant		■	Island Curb Cuts - Adjacent		
							■ Island Curb Cuts - Compliant		■	Island Curb Cuts - Non Compliant		
							■ Island Curb Cuts - Non Compliant		■	Signals - Adjacent		
							■ Signals - Compliant		■	Transit Stops - Adjacent		
							■ Signals - Non Compliant		■	Transit Stops - Non Compliant		
							■ Transit Stops - Compliant		■	Railroad Crossings - Adjacent		
							■ Transit Stops - Non Compliant		■	Accessible Parking - Adjacent		
							■ Railroad Crossings - Compliant		■			
							■ Railroad Crossings - Non Compliant		■			
							■ Accessible Parking - Compliant		■			
							■ Accessible Parking - Non Compliant		■			
*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.												
**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.												