




ADA Survey Summary						ADA Compliance Cost Estimate *						Intersection Inventory & Compliance Cost Estimate									
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost												
1 Heavings less than 1"	3 EA	1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	5	5	\$ 11950.00	● Heavings < 1" (Excluded)***	● Heavings < 1"	● Heavings < 1" (Excluded)***	● Heavings < 1"	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap	▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"	● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"
2 Heavings 1" or greater	1 EA	2 Heavings 1" or greater	1 EA	\$ 400.00	\$ 400.00	Island Curb Cuts	0	0	\$ 0.00	● Uneven Heaving (Excluded)***	● Uneven Heaving	● Uneven Heaving (Excluded)***	● Uneven Heaving	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction	■ Miscellaneous Obstruction
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	■ Heaving Clusters (Excluded)	■ Heaving Clusters	■ Heaving Clusters (Excluded)	■ Heaving Clusters	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction	■ Missing Sidewalk Obstruction
4 Heaving Clusters	0.442 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	■ Sidewalk Joint Obstruction	■ Sidewalk Joint Obstruction	■ Sidewalk Joint Obstruction	■ Sidewalk Joint Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction	■ Other Obstruction
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	■ Sign Obstruction	■ Sign Obstruction	■ Sign Obstruction	■ Sign Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction	■ Pole Post Hydrant Obstruction
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■ Storm Grate Obstruction	■ Storm Grate Obstruction	■ Storm Grate Obstruction	■ Storm Grate Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction	■ Transit Obstruction
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 11950.00	■ Traffic Obstruction	■ Traffic Obstruction	■ Traffic Obstruction	■ Traffic Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction	■ Tree Obstruction
8 Other Obstruction	2 EA	8 Other Obstruction	2 EA	\$ 500.00	\$ 1000.00					■ Utility Obstruction	■ Utility Obstruction	■ Utility Obstruction	■ Utility Obstruction	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low	■ Vegetation Obstruction - Low
9 Pole Post Hydrant Obstruction	3 EA	9 Pole Post Hydrant Obstruction	3 EA	\$ 5000.00	\$ 15000.00					■ Vegetation Obstruction - Overhead	■ Vegetation Obstruction - Overhead	■ Vegetation Obstruction - Overhead	■ Vegetation Obstruction - Overhead	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path	■ Sidewalk Collection Path
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■ Adjacent Sidewalk Collection Path	■ Adjacent Sidewalk Collection Path	■ Adjacent Sidewalk Collection Path	■ Adjacent Sidewalk Collection Path	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk	■ Buried Sidewalk
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00					■ Sidewalk Not Surveyed	■ Sidewalk Not Surveyed	■ Sidewalk Not Surveyed	■ Sidewalk Not Surveyed	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap	■ Missing Sidewalk Gap
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00					■ No Sidewalk on Block	■ No Sidewalk on Block	■ No Sidewalk on Block	■ No Sidewalk on Block								
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00																
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00																
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00																
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00																
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00																
18 Vegetation Obstruction - Low	1 EA	18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00																
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00																
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00																
21 Residential Entrance	3 EA	21 Residential Entrance (within slope violation)	3 EA	\$ 3000.00	\$ 9000.00																
22 Total Sidewalk Length Assessed	298.935 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00																
23 Average Sidewalk Width	36 IN	23 Cross Slope Violations	39.399 SY	\$ 75.00	\$ 2955.00																
24 No Sidewalk on Block (Approx.)	310.029 LF	24 Running and Cross Slope Violations	43.857 SY	\$ 75.00	\$ 3289.00																
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00																
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00																
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00																
Sidewalk SubTotal:					\$ 31894.00																

Corridor Total:

\$ 43844.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

■ Island Curb Cuts - Compliant

■ Island Curb Cuts - Non Compliant

■ Signals - Compliant

■ Signals - Non Compliant

■ Transit Stops - Compliant

■ Transit Stops - Non Compliant

■ Railroad Crossings - Compliant

■ Railroad Crossings - Non Compliant

■ Accessible Parking - Compliant

■ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

■ Island Curb Cuts - Adjacent

■ Signals - Adjacent

■ Transit Stops - Adjacent

■ Railroad Crossings - Adjacent

■ Accessible Parking - Adjacent

Cross Slope

2 - 3% 3.01 - 4% 4.01 - 5% 5.01% - 6% 6.01 - 7% 7.01 - 8% 8.01 - 9% 9.01 - 10% 10.01 - 12% > 12%

Running Slope

5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.