




ADA Survey Summary				ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate				Legend			
Item	Description	Quantity		Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	20 EA		1	Heavings less than 1"	3 EA	\$ 100.00	\$ 300.00	Curb Ramps		0	0	\$ 0.00	●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	4 EA		2	Heavings 1" or greater	2 EA	\$ 400.00	\$ 800.00	Island Curb Cuts		0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA		3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00	●	Uneven Heaving (Excluded)***
4	Heaving Clusters	90.943 SY		4	Heaving Clusters	15.319 SY	\$ 75.00	\$ 1149.00	Transit Stops		2	2	\$ 4150.00	—	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA		5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA		6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA		7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 4150.00	■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA		8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00						■	Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA		9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						■	Pole Post Hydrant Obstruction
10	Ponding Obstruction	0 EA		10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00						■	Ponding Obstruction
11	Sidewalk Joint Obstruction	0 EA		11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00						■	Sidewalk Joint Obstruction
12	Sign Obstruction	0 EA		12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00						■	Sign Obstruction
13	Storm Grate Obstruction	0 EA		13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00						■	Storm Grate Obstruction
14	Transit Obstruction	0 EA		14	Transit Obstruction	0 EA	\$500.00	\$ 0.00						■	Transit Obstruction
15	Traffic Obstruction	0 EA		15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00						■	Traffic Obstruction
16	Tree Obstruction	0 EA		16	Tree Obstruction	0 EA	\$500.00	\$ 0.00						■	Tree Obstruction
17	Utility Obstruction	1 EA		17	Utility Obstruction	1 EA	\$1500.00	\$ 1500.00						■	Utility Obstruction
18	Vegetation Obstruction - Low	2 EA		18	Vegetation Obstruction - Low	2 EA	\$150.00	\$ 300.00						■	Vegetation Obstruction - Low
19	Vegetation Obstruction - Overhead	1 EA		19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00						■	Vegetation Obstruction - Overhead
20	Commercial Entrance	16 EA		20	Commercial Entrance (within slope violation)	16 EA	\$ 5000.00	\$ 80000.00						■	Sidewalk Collection Path
21	Residential Entrance	0 EA		21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00						■	Adjacent Sidewalk Collection Path
22	Total Sidewalk Length Assessed	2140.24 LF		22	Running Slope Violations**	0.366 SY	\$ 75.00	\$ 27.00						■	Buried Sidewalk
23	Average Sidewalk Width	62 IN		23	Cross Slope Violations	691.12 SY	\$ 75.00	\$ 51834.00						■	Sidewalk Not Surveyed
24	No Sidewalk on Block (Approx.)	0 LF		24	Running and Cross Slope Violations	14.789 SY	\$ 75.00	\$ 1109.00						■	Missing Sidewalk Gap
25	Missing Sidewalk Gaps (Approx.)	0 LF		25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00						■	No Sidewalk on Block
26	Poor Surface Condition (Approx.)	0 LF		26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00						■	
27	Buried Sidewalk (Approx.)	170.818 LF		27	Buried Sidewalk (Approx.)	170.818 LF	\$ 41.67	\$ 7040.00						■	
					Sidewalk SubTotal:			\$ 137170.00							

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.