




ADA Survey Summary						ADA Compliance Cost Estimate *						Intersection Inventory & Compliance Cost Estimate											
Item Description		Quantity	Item Description		Quantity	Unit Price	Item Cost	Item Description		Total Count	Non Compliant Count	Cost											
1	Heavings less than 1"	44 EA	1	Heavings less than 1"	21 EA	\$ 100.00	\$ 2100.00	Curb Ramps		2	2	\$ 3450.00		•	Heavings < 1" (Excluded)***	•	Heavings < 1"	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap	◆	Commercial Entrance
2	Heavings 1" or greater	2 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00		•	Heavings ≥ 1" (Excluded)***	•	Heavings ≥ 1"	◆	Residential Entrance	◆	Residential Entrance	◆	Residential Entrance
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		0	0	\$ 0.00		—	Uneven Heaving (Excluded)***	—	Uneven Heaving	◆	Commercial Entrance (within slope violation)	◆	Commercial Entrance (within slope violation)	◆	Commercial Entrance (within slope violation)
4	Heaving Clusters	18.147 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00		—	Heaving Clusters (Excluded)	—	Heaving Clusters	◆	Residential Entrance (within slope violation)	◆	Residential Entrance (within slope violation)	◆	Residential Entrance (within slope violation)
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00		▲	Sidewalk Joint Obstruction	▲	Sidewalk Joint Obstruction	◆	Cross Slope	◆	Cross Slope	◆	Cross Slope
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00		■	Sign Obstruction	■	Sign Obstruction	◆	Running Slope	◆	Running Slope	◆	Running Slope
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 3450.00		■	Storm Grate Obstruction	■	Storm Grate Obstruction	◆	2 - 3%	◆	2 - 3%	◆	2 - 3%
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 65834.00		■	Transit Obstruction	■	Transit Obstruction	◆	3.01 - 4%	◆	3.01 - 4%	◆	3.01 - 4%
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00							■	Traffic Obstruction	■	Traffic Obstruction	◆	4.01 - 5%	◆	4.01 - 5%	◆	4.01 - 5%
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00							■	Utility Obstruction	■	Utility Obstruction	◆	5.01% - 6%	◆	5.01% - 6%	◆	5.01% - 6%
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00							■	Vegetation Obstruction - Low	■	Vegetation Obstruction - Low	◆	6.01 - 7%	◆	6.01 - 7%	◆	6.01 - 7%
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00							■	Vegetation Obstruction - Overhead	■	Vegetation Obstruction - Overhead	◆	7.01 - 8%	◆	7.01 - 8%	◆	7.01 - 8%
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00							■	Sidewalk Collection Path	■	Sidewalk Collection Path	◆	8.01 - 9%	◆	8.01 - 9%	◆	8.01 - 9%
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00							■	Adjacent Sidewalk Collection Path	■	Adjacent Sidewalk Collection Path	◆	8.34% - 10%	◆	8.34% - 10%	◆	8.34% - 10%
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00							■	Buried Sidewalk	■	Buried Sidewalk	◆	9.01 - 10%	◆	9.01 - 10%	◆	9.01 - 10%
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00							■	Sidewalk Not Surveyed	■	Sidewalk Not Surveyed	◆	10.01 - 12.5%	◆	10.01 - 12.5%	◆	10.01 - 12.5%
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00							■	Missing Sidewalk Gap	■	Missing Sidewalk Gap	◆	> 12.5%	◆	> 12.5%	◆	> 12.5%
18	Vegetation Obstruction - Low	3 EA	18	Vegetation Obstruction - Low	3 EA	\$150.00	\$ 450.00							■	No Sidewalk on Block	■	No Sidewalk on Block	◆		◆		◆	
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00							■		■		◆		◆		◆	
20	Commercial Entrance	5 EA	20	Commercial Entrance (within slope violation)	5 EA	\$ 5000.00	\$ 25000.00							■		■		◆		◆		◆	
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00							■		■		◆		◆		◆	
22	Total Sidewalk Length Assessed	1577.882 LF	22	Running Slope Violations**	3.499 SY	\$ 75.00	\$ 262.00							■		■		◆		◆		◆	
23	Average Sidewalk Width	66.667 IN	23	Cross Slope Violations	446.317 SY	\$ 75.00	\$ 33474.00							■		■		◆		◆		◆	
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	12.638 SY	\$ 75.00	\$ 948.00							■		■		◆		◆		◆	
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00							■		■		◆		◆		◆	
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00							■		■		◆		◆		◆	
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00							■		■		◆		◆		◆	
			Sidewalk SubTotal:				\$ 62384.00																

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.