




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate											
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost								
1 Heavings less than 1"	6 EA	1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00	Curb Ramps	5	5	\$ 16000.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"				
2 Heavings 1" or greater	1 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"				
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving				
4 Heaving Clusters	7.932 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters				
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap				
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance				
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 16000.00	■	Missing Sidewalk Obstruction	◆	Residential Entrance				
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:			\$ 64525.00	■	Other Obstruction	✚	Commercial Entrance (within slope violation)				
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■	Curb Ramps - Compliant	■	Curb Ramps - Adjacent	■	Pole Post Hydrant Obstruction	✚	Residential Entrance (within slope violation)				
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■	Curb Ramps - Non Compliant	■	Curb Ramps - Adjacent	■	Ponding Obstruction		Cross Slope				
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■	Island Curb Cuts - Compliant	■	Island Curb Cuts - Adjacent	■	■	Sidewalk Joint Obstruction	—	2 - 3%	—	7.01 - 8%	
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■	Island Curb Cuts - Non Compliant	■	Island Curb Cuts - Adjacent	■	■	Sign Obstruction	—	3.01 - 4%	—	8.01 - 9%	
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■	Signals - Compliant	■	Signals - Adjacent	■	■	Storm Grate Obstruction	—	4.01 - 5%	—	9.01 - 10%	
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■	Signals - Non Compliant	■	Signals - Adjacent	■	■	Transit Obstruction	—	5.01% - 6%	—	10.01 - 12%	
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■	Transit Stops - Compliant	■	Transit Stops - Adjacent	■	■	Traffic Obstruction	—	6.01 - 7%	—	> 12%	
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■	Transit Stops - Non Compliant	■	Transit Stops - Adjacent	■	■	Tree Obstruction		Running Slope			
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■	Railroad Crossings - Compliant	■	Railroad Crossings - Adjacent	■	■	Utility Obstruction	—	5 - 8.33%	—		
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■	Railroad Crossings - Non Compliant	■	Railroad Crossings - Adjacent	■	■	Vegetation Obstruction - Low	—	8.34% - 10%	—		
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■	Accessible Parking - Compliant	■	Accessible Parking - Adjacent	■	■	Vegetation Obstruction - Overhead	—	10.01 - 12.5%	—		
20 Commercial Entrance	2 EA	20 Commercial Entrance (within slope violation)	2 EA	\$ 5000.00	\$ 10000.00	■	Accessible Parking - Non Compliant	■	Accessible Parking - Adjacent	■	■	Sidewalk Collection Path	—	> 12.5%	—		
21 Residential Entrance	0 EA	21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	■	Sidewalk SubTotal:		\$ 23665.00	■	Adjacent Sidewalk Collection Path						
22 Total Sidewalk Length Assessed	525.262 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	■				■	Buried Sidewalk						
23 Average Sidewalk Width	60 IN	23 Cross Slope Violations	173.714 SY	\$ 75.00	\$ 13029.00	■				■	Sidewalk Not Surveyed						
24 No Sidewalk on Block (Approx.)	1206.129 LF	24 Running and Cross Slope Violations	8.484 SY	\$ 75.00	\$ 636.00	■				■	Missing Sidewalk Gap						
25 Missing Sidewalk Gaps (Approx.)	595.074 LF	25 Missing Sidewalk Gaps (Approx.)	595.074 LF	\$ 41.67	\$ 24860.00	■				■	No Sidewalk on Block						
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00	■				■							
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00	■				■							
		Sidewalk SubTotal:		\$ 23665.00													

● Heavings < 1" (Excluded)*** | ● | Heavings < 1" || ● | Heavings ≥ 1" (Excluded)*** | ● | Heavings ≥ 1" |
●	Uneven Heaving (Excluded)***	●	Uneven Heaving		
—	Heaving Clusters (Excluded)	—	Heaving Clusters		
▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap		
■	Miscellaneous Obstruction	◆	Commercial Entrance		
■	Missing Sidewalk Obstruction	◆	Residential Entrance		
■	Other Obstruction	✚	Commercial Entrance (within slope violation)		
■	Pole Post Hydrant Obstruction	✚	Residential Entrance (within slope violation)		
■	Ponding Obstruction		Cross Slope		
■	Sidewalk Joint Obstruction	—	2 - 3%	—	7.01 - 8%
■	Sign Obstruction	—	3.01 - 4%	—	8.01 - 9%
■	Storm Grate Obstruction	—	4.01 - 5%	—	9.01 - 10%
■	Transit Obstruction	—	5.01% - 6%	—	10.01 - 12%
■	Traffic Obstruction	—	6.01 - 7%	—	> 12%
■	Tree Obstruction		Running Slope		
■	Utility Obstruction	—	5 - 8.33%	—	
■	Vegetation Obstruction - Low	—	8.34% - 10%	—	
■	Vegetation Obstruction - Overhead	—	10.01 - 12.5%	—	
—	Sidewalk Collection Path	—	> 12.5%	—	
—	Adjacent Sidewalk Collection Path				
—	Buried Sidewalk				
—	Sidewalk Not Surveyed				
—	Missing Sidewalk Gap				
—	No Sidewalk on Block				

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.