




ADA Survey Summary			ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate				Corridor Total:			
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost				
1 Heavings less than 1"	14 EA		1 Heavings less than 1"	8 EA	\$ 100.00	\$ 800.00	Curb Ramps	2	2	\$ 5250.00	●	Heavings < 1" (Excluded)***	●	Heavings < 1"
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00	●	Heavings ≥ 1" (Excluded)***	●	Heavings ≥ 1"
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	2	2	\$ 2850.00	●	Uneven Heaving (Excluded)***	●	Uneven Heaving
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00	—	Heaving Clusters (Excluded)	—	Heaving Clusters
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	▲	Sidewalk Joint Gap (Excluded)***	▲	Sidewalk Joint Gap
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00	■	Miscellaneous Obstruction	◆	Commercial Entrance
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 8100.00		■	Missing Sidewalk Obstruction	◆	Residential Entrance
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00					■	Other Obstruction	✚	Commercial Entrance (within slope violation)
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	Corridor Total:		\$ 51348.00		■	Pole Post Hydrant Obstruction	✚	Residential Entrance (within slope violation)
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00					■	Ponding Obstruction		Cross Slope
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■ Curb Ramps - Compliant	■ Curb Ramps - Adjacent			■	Sidewalk Joint Obstruction	■	2 - 3%
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■ Curb Ramps - Non Compliant	■ Curb Ramps - Adjacent			■	Sign Obstruction	■	3.01 - 4%
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Island Curb Cuts - Compliant	■ Island Curb Cuts - Adjacent			■	Storm Grate Obstruction	■	4.01 - 5%
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent			■	Transit Obstruction	■	5.01% - 6%
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Island Curb Cuts - Non Compliant	■ Island Curb Cuts - Adjacent			■	Traffic Obstruction	■	6.01 - 7%
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Compliant	■ Signals - Adjacent			■	Tree Obstruction	■	> 12%
17 Utility Obstruction	1 EA		17 Utility Obstruction	1 EA	\$1500.00	\$ 1500.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Utility Obstruction	■	Running Slope
18 Vegetation Obstruction - Low	1 EA		18 Vegetation Obstruction - Low	1 EA	\$150.00	\$ 150.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Low	■	5 - 8.33%
19 Vegetation Obstruction - Overhead	0 EA		19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	8.34% - 10%
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	10.01 - 12.5%
21 Residential Entrance	2 EA		21 Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	> 12.5%
22 Total Sidewalk Length Assessed	1071.368 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
23 Average Sidewalk Width	60 IN		23 Cross Slope Violations	448.216 SY	\$ 75.00	\$ 33616.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
24 No Sidewalk on Block (Approx.)	0 LF		24 Running and Cross Slope Violations	9.895 SY	\$ 75.00	\$ 742.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
25 Missing Sidewalk Gaps (Approx.)	12.976 LF		25 Missing Sidewalk Gaps (Approx.)	12.976 LF	\$ 41.67	\$ 440.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
27 Buried Sidewalk (Approx.)	0 LF		27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00	■ Signals - Non Compliant	■ Signals - Adjacent			■	Vegetation Obstruction - Overhead	■	
Sidewalk SubTotal:						\$ 42808.00								

● Heavings < 1" (Excluded)***

● Heavings ≥ 1" (Excluded)***

● Uneven Heaving (Excluded)***

— Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)***

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

— Sidewalk Collection Path

— Adjacent Sidewalk Collection Path

— Buried Sidewalk

— Sidewalk Not Surveyed

— Missing Sidewalk Gap

— No Sidewalk on Block

● Heavings < 1"

● Heavings ≥ 1"

● Uneven Heaving

— Heaving Clusters

▲ Sidewalk Joint Gap

◆ Commercial Entrance

◆ Residential Entrance

✚ Commercial Entrance (within slope violation)

✚ Residential Entrance (within slope violation)

Cross Slope

2 - 3%

3.01 - 4%

4.01 - 5%

5.01% - 6%

6.01 - 7%

7.01 - 8%

8.01 - 9%

9.01 - 10%

10.01 - 12%

> 12%

Running Slope

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.