




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item Cost	Item	Description	Total Count	Non Compliant Count	Cost	
1	Heavings less than 1"	7 EA	1	Heavings less than 1"	2 EA	\$ 100.00	\$ 200.00	Curb Ramps		4	4	\$ 9000.00	
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts		0	0	\$ 0.00	
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons		1	1	\$ 650.00	
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops		0	0	\$ 0.00	
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings		0	0	\$ 0.00	
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces		0	0	\$ 0.00	
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:				\$ 9650.00	
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total: \$ 41017.00					
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00						
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	Curb Ramps - Compliant	Curb Ramps - Adjacent	● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)*** — Heaving Clusters (Excluded) ▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead — Sidewalk Collection Path — Adjacent Sidewalk Collection Path — Buried Sidewalk — Sidewalk Not Surveyed — Missing Sidewalk Gap — No Sidewalk on Block ● Heavings < 1" ● Heavings ≥ 1" ● Uneven Heaving — Heaving Clusters ▲ Sidewalk Joint Gap ◆ Commercial Entrance ◆ Residential Entrance ✚ Commercial Entrance (within slope violation) ✚ Residential Entrance (within slope violation) Cross Slope 2 - 3% 7.01 - 8% 3.01 - 4% 8.01 - 9% 4.01 - 5% 9.01 - 10% 5.01% - 6% 10.01 - 12% 6.01 - 7% > 12% Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5%			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	Curb Ramps - Non Compliant	Island Curb Cuts - Adjacent				
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	Island Curb Cuts - Compliant	Island Curb Cuts - Adjacent				
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	Island Curb Cuts - Non Compliant	Island Curb Cuts - Adjacent				
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$ 0.00	Signals - Compliant	Signals - Adjacent				
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	Signals - Non Compliant	Signals - Adjacent				
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$ 0.00	Transit Stops - Compliant	Transit Stops - Adjacent				
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$ 0.00	Transit Stops - Non Compliant	Transit Stops - Adjacent				
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	Railroad Crossings - Compliant	Railroad Crossings - Adjacent				
19	Vegetation Obstruction - Overhead	2 EA	19	Vegetation Obstruction - Overhead	2 EA	\$150.00	\$ 300.00	Railroad Crossings - Non Compliant	Railroad Crossings - Adjacent				
20	Commercial Entrance	2 EA	20	Commercial Entrance (within slope violation)	2 EA	\$ 5000.00	\$ 10000.00	Accessible Parking - Compliant	Accessible Parking - Adjacent				
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00	Accessible Parking - Non Compliant					
22	Total Sidewalk Length Assessed	572.333 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00	*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. **Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.					
23	Average Sidewalk Width	57 IN	23	Cross Slope Violations	187.296 SY	\$ 75.00	\$ 14047.00						
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00						
25	Missing Sidewalk Gaps (Approx.)	143.759 LF	25	Missing Sidewalk Gaps (Approx.)	143.759 LF	\$ 41.67	\$ 5940.00						
26	Poor Surface Condition (Approx.)	19.17 LF	26	Poor Surface Condition (Approx.)	19.17 LF	\$ 41.67	\$ 880.00						
27	Buried Sidewalk (Approx.)	54.333 LF	27	Buried Sidewalk (Approx.)	54.333 LF	\$ 41.67	\$ 2200.00						
			Sidewalk SubTotal:			\$ 25427.00							