




ADA Survey Summary						ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description		Quantity	Item Description		Quantity	Unit Price	Item Cost			Item Description	Total Count	Non Compliant Count		Cost			
1	Heavings less than 1"	10 EA	1	Heavings less than 1"	6 EA	\$ 100.00	\$	600.00		Curb Ramps	3	3	\$	8000.00		●	Heavings < 1" (Excluded)***
2	Heavings 1" or greater	17 EA	2	Heavings 1" or greater	13 EA	\$ 400.00	\$	5200.00		Island Curb Cuts	0	0	\$	0.00		●	Heavings ≥ 1" (Excluded)***
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00		Signal Push Buttons	1	1	\$	400.00		●	Uneven Heaving (Excluded)***
4	Heaving Clusters	188.756 SY	4	Heaving Clusters	122.921 SY	\$ 75.00	\$	9219.00		Transit Stops	0	0	\$	0.00		—	Heaving Clusters (Excluded)
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00		Railroad Crossings	0	0	\$	0.00		▲	Sidewalk Joint Gap (Excluded)***
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00		Accessible Parking Spaces	0	0	\$	0.00		■	Miscellaneous Obstruction
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00		Intersection SubTotal:			\$	8400.00		■	Missing Sidewalk Obstruction
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00								■	Other Obstruction
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00								■	Pole Post Hydrant Obstruction
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00								■	Ponding Obstruction
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00								■	Sidewalk Joint Obstruction
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00								■	Sign Obstruction
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00								■	Storm Grate Obstruction
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00								■	Transit Obstruction
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00								■	Traffic Obstruction
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00								■	Tree Obstruction
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00								■	Utility Obstruction
18	Vegetation Obstruction - Low	1 EA	18	Vegetation Obstruction - Low	1 EA	\$150.00	\$	150.00								■	Vegetation Obstruction - Low
19	Vegetation Obstruction - Overhead	0 EA	19	Vegetation Obstruction - Overhead	0 EA	\$150.00	\$	0.00								■	Vegetation Obstruction - Overhead
20	Commercial Entrance	1 EA	20	Commercial Entrance (within slope violation)	1 EA	\$ 5000.00	\$	5000.00								—	Sidewalk Collection Path
21	Residential Entrance	1 EA	21	Residential Entrance (within slope violation)	1 EA	\$ 3000.00	\$	3000.00								—	Adjacent Sidewalk Collection Path
22	Total Sidewalk Length Assessed	3581.173 LF	22	Running Slope Violations**	79.342 SY	\$ 75.00	\$	5951.00								—	Buried Sidewalk
23	Average Sidewalk Width	60 IN	23	Cross Slope Violations	781.436 SY	\$ 75.00	\$	58608.00								—	Sidewalk Not Surveyed
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	459.78 SY	\$ 75.00	\$	34484.00								—	Missing Sidewalk Gap
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00								—	No Sidewalk on Block
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00									
27	Buried Sidewalk (Approx.)	0 LF	27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00									
						Sidewalk SubTotal:		\$ 122211.00									

Corridor Total:

\$ 130611.00

■

 Curb Ramps - Compliant

■

 Curb Ramps - Non Compliant

■

 Island Curb Cuts - Compliant

■

 Island Curb Cuts - Non Compliant

■

 Signals - Compliant

■

 Signals - Non Compliant

■

 Transit Stops - Compliant

■

 Transit Stops - Non Compliant

■

 Railroad Crossings - Compliant

■

 Railroad Crossings - Non Compliant

■

 Accessible Parking - Compliant

■

 Accessible Parking - Non Compliant

■

 Curb Ramps - Adjacent

■

 Island Curb Cuts - Adjacent

■

 Signals - Adjacent

■

 Transit Stops - Adjacent

■

 Railroad Crossings - Adjacent

■

 Accessible Parking - Adjacent

●

 Heavings < 1"

●

 Heavings ≥ 1"

●

 Uneven Heaving

—

 Heaving Clusters

▲

 Sidewalk Joint Gap

◆

 Commercial Entrance

◆

 Residential Entrance

⊕

 Commercial Entrance (within slope violation)

⊕

 Residential Entrance (within slope violation)

—

 Cross Slope

—

 Running Slope

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.