



Intersection Inventory & Compliance Cost Estimate

Item Description	Quantity	Unit Price	Item Cost
1 Heavings less than 1"	0 EA	\$ 100.00	\$ 0.00
2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00
3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00
4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00
5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00
6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00
7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00
8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00
9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00
10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00
11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00
12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00
13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00
14 Transit Obstruction	0 EA	\$500.00	\$ 0.00
15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00
16 Tree Obstruction	0 EA	\$500.00	\$ 0.00
17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00
18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00
19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00
20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00
21 Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$ 0.00
22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00
23 Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00
24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00
25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00
26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00
27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00

Sidewalk SubTotal:	\$	0.00
--------------------	----	------

Corridor Total: \$ 0.00

 Curb Ramps - Compliant	 Curb Ramps - Adjacent
 Curb Ramps - Non Compliant	
 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent
 Island Curb Cuts - Non Compliant	
 Signals - Compliant	 Signals - Adjacent
 Signals - Non Compliant	
 Transit Stops - Compliant	 Transit Stops - Adjacent
 Transit Stops - Non Compliant	
 Railroad Crossings - Compliant	 Railroad Crossings - Adjacent
 Railroad Crossings - Non Compliant	
 Accessible Parking - Compliant	 Accessible Parking - Adjacent
 Accessible Parking - Non Compliant	

● Heavings < 1" (Excluded)***	● Heavings < 1"
● Heavings ≥ 1" (Excluded)***	● Heavings ≥ 1"
● Uneven Heaving (Excluded)***	● Uneven Heaving
— Heaving Clusters (Excluded)	— Heaving Clusters
▲ Sidewalk Joint Gap (Excluded)***	▲ Sidewalk Joint Gap
■ Miscellaneous Obstruction	◆ Commercial Entrance
■ Missing Sidewalk Obstruction	◆ Residential Entrance
■ Other Obstruction	⊕ Commercial Entrance (within slope violation)
■ Pole Post Hydrant Obstruction	⊕ Residential Entrance (within slope violation)
■ Ponding Obstruction	
■ Sidewalk Joint Obstruction	Cross Slope
■ Sign Obstruction	2 - 3% 7.01 - 8%
■ Storm Grate Obstruction	3.01 - 4% 8.01 - 9%
■ Transit Obstruction	4.01 - 5% 9.01 - 10%
■ Traffic Obstruction	5.01% - 6% 10.01 - 12%
■ Tree Obstruction	6.01 - 7% > 12%
■ Utility Obstruction	Running Slope
■ Vegetation Obstruction - Low	5 - 8.33%
■ Vegetation Obstruction - Overhead	8.34% - 10%
— Sidewalk Collection Path	10.01 - 12.5%
— Adjacent Sidewalk Collection Path	> 12.5%
— Buried Sidewalk	
— Sidewalk Not Surveyed	
— Missing Sidewalk Gap	
— No Sidewalk on Block	

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.