




ADA Survey Summary						ADA Compliance Cost Estimate *						Intersection Inventory & Compliance Cost Estimate											
Item Description			Quantity	Item Description			Quantity	Unit Price	Item Cost		Item Description			Total Count	Non Compliant Count	Cost							
1	Heavings less than 1"		65 EA	1	Heavings less than 1"		11 EA	\$ 100.00	\$	1100.00	1	Curb Ramps - Compliant		5	5	\$	12150.00						
2	Heavings 1" or greater		1 EA	2	Heavings 1" or greater		0 EA	\$ 400.00	\$	0.00	2	Curb Ramps - Non Compliant		1	1	\$	3000.00						
3	Uneven Heavings		0 EA	3	Uneven Heavings		0 EA	\$ 400.00	\$	0.00	3	Island Curb Cuts - Compliant		3	3	\$	1950.00						
4	Heaving Clusters		0 SY	4	Heaving Clusters		0 SY	\$ 75.00	\$	0.00	4	Island Curb Cuts - Non Compliant		4	4	\$	6600.00						
5	Sidewalk Joint Gaps		0 EA	5	Sidewalk Joint Gaps		0 EA	\$ 200.00	\$	0.00	5	Signals - Compliant		0	0	\$	0.00						
6	Miscellaneous Obstruction		0 EA	6	Miscellaneous Obstruction		0 EA	\$ 1500.00	\$	0.00	6	Signals - Non Compliant		0	0	\$	0.00						
7	Missing Sidewalk Obstruction		0 EA	7	Missing Sidewalk Obstruction		0 EA	\$ 200.00	\$	0.00	7	Transit Stops - Compliant		0	0	\$	0.00						
8	Other Obstruction		0 EA	8	Other Obstruction		0 EA	\$ 500.00	\$	0.00	8	Transit Stops - Non Compliant		0	0	\$	0.00						
9	Pole Post Hydrant Obstruction		0 EA	9	Pole Post Hydrant Obstruction		0 EA	\$ 5000.00	\$	0.00	9	Railroad Crossings - Compliant		0	0	\$	0.00						
10	Ponding Obstruction		0 EA	10	Ponding Obstruction		0 EA	\$ 400.00	\$	0.00	10	Railroad Crossings - Non Compliant		0	0	\$	0.00						
11	Sidewalk Joint Obstruction		0 EA	11	Sidewalk Joint Obstruction		0 EA	\$ 100.00	\$	0.00	11	Accessible Parking - Compliant		0	0	\$	0.00						
12	Sign Obstruction		0 EA	12	Sign Obstruction		0 EA	\$ 150.00	\$	0.00	12	Accessible Parking - Non Compliant		0	0	\$	0.00						
13	Storm Grate Obstruction		0 EA	13	Storm Grate Obstruction		0 EA	\$700.00	\$	0.00	13												
14	Transit Obstruction		0 EA	14	Transit Obstruction		0 EA	\$500.00	\$	0.00	14												
15	Traffic Obstruction		0 EA	15	Traffic Obstruction		0 EA	\$2000.00	\$	0.00	15												
16	Tree Obstruction		0 EA	16	Tree Obstruction		0 EA	\$500.00	\$	0.00	16												
17	Utility Obstruction		0 EA	17	Utility Obstruction		0 EA	\$1500.00	\$	0.00	17												
18	Vegetation Obstruction - Low		12 EA	18	Vegetation Obstruction - Low		12 EA	\$150.00	\$	1800.00	18												
19	Vegetation Obstruction - Overhead		0 EA	19	Vegetation Obstruction - Overhead		0 EA	\$150.00	\$	0.00	19												
20	Commercial Entrance		1 EA	20	Commercial Entrance (within slope violation)		1 EA	\$ 5000.00	\$	5000.00	20												
21	Residential Entrance		0 EA	21	Residential Entrance (within slope violation)		0 EA	\$ 3000.00	\$	0.00	21												
22	Total Sidewalk Length Assessed		2956.162 LF	22	Running Slope Violations**		18.857 SY	\$ 75.00	\$	1414.00	22												
23	Average Sidewalk Width		61.333 IN	23	Cross Slope Violations		1021.511 SY	\$ 75.00	\$	76613.00	23												
24	No Sidewalk on Block (Approx.)		0 LF	24	Running and Cross Slope Violations		122.744 SY	\$ 75.00	\$	9206.00	24												
25	Missing Sidewalk Gaps (Approx.)		3062.897 LF	25	Missing Sidewalk Gaps (Approx.)		3062.897 LF	\$ 41.67	\$	127600.00	25												
26	Poor Surface Condition (Approx.)		0 LF	26	Poor Surface Condition (Approx.)		0 LF	\$ 41.67	\$	0.00	26												
27	Buried Sidewalk (Approx.)		348.447 LF	27	Buried Sidewalk (Approx.)		348.447 LF	\$ 41.67	\$	14520.00	27												
				Sidewalk SubTotal:						\$ 95133.00													

● Heavings < 1" (Excluded)***

● Heavings ≥ 1" (Excluded)***

● Uneven Heaving (Excluded)***

● Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)***

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

■ Sidewalk Collection Path

■ Adjacent Sidewalk Collection Path

■ Buried Sidewalk

■ Sidewalk Not Surveyed

■ Missing Sidewalk Gap

■ No Sidewalk on Block

● Heavings < 1"

● Heavings ≥ 1"

● Uneven Heaving

● Heaving Clusters

▲ Sidewalk Joint Gap

◆ Commercial Entrance

◆ Residential Entrance

◆ Commercial Entrance (within slope violation)

◆ Residential Entrance (within slope violation)

Cross Slope

2 - 3% 7.01 - 8%

3.01 - 4% 8.01 - 9%

4.01 - 5% 9.01 - 10%

5.01% - 6% 10.01 - 12%

6.01 - 7% > 12%

Running Slope

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.