




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate									
Item Description	Quantity		Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost					
1 Heavings less than 1"	1 EA		1 Heavings less than 1"	1 EA	\$ 100.00	\$ 100.00	Curb Ramps	1	1	\$ 1850.00	● Heavings < 1" (Excluded)***	● Heavings < 1"	● Heavings ≥ 1"	● Uneven Heaving (Excluded)***	
2 Heavings 1" or greater	0 EA		2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00					● Heaving Clusters (Excluded)
3 Uneven Heavings	0 EA		3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00	▲ Sidewalk Joint Gap (Excluded)***				
4 Heaving Clusters	0 SY		4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00		■ Miscellaneous Obstruction	◆ Commercial Entrance		
5 Sidewalk Joint Gaps	0 EA		5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00	■ Missing Sidewalk Obstruction			◆ Residential Entrance	
6 Miscellaneous Obstruction	0 EA		6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00		■ Other Obstruction			⊕ Commercial Entrance (within slope violation)
7 Missing Sidewalk Obstruction	0 EA		7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:		\$ 1850.00	■ Pole Post Hydrant Obstruction	⊕ Residential Entrance (within slope violation)				
8 Other Obstruction	0 EA		8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:					\$ 12033.00	Cross Slope		
9 Pole Post Hydrant Obstruction	0 EA		9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00	■ Curb Ramps - Compliant		■ Curb Ramps - Adjacent			■ Sidewalk Joint Obstruction	2 - 3%	7.01 - 8%	
10 Ponding Obstruction	0 EA		10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00	■ Curb Ramps - Non Compliant		■ Island Curb Cuts - Adjacent		■ Sign Obstruction	3.01 - 4%	8.01 - 9%		
11 Sidewalk Joint Obstruction	0 EA		11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00	■ Island Curb Cuts - Compliant		■ Signals - Adjacent		■ Storm Grate Obstruction	4.01 - 5%	9.01 - 10%		
12 Sign Obstruction	0 EA		12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00	■ Island Curb Cuts - Non Compliant		■ Transit Stops - Adjacent		■ Transit Obstruction	5.01% - 6%	10.01 - 12%		
13 Storm Grate Obstruction	0 EA		13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00	■ Signals - Compliant		■ Railroad Crossings - Adjacent		■ Traffic Obstruction	6.01 - 7%	> 12%		
14 Transit Obstruction	0 EA		14 Transit Obstruction	0 EA	\$500.00	\$ 0.00	■ Signals - Non Compliant		■ Accessible Parking - Adjacent		■ Tree Obstruction	Running Slope			
15 Traffic Obstruction	0 EA		15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00	■ Transit Stops - Compliant				■ Utility Obstruction	5 - 8.33%			
16 Tree Obstruction	0 EA		16 Tree Obstruction	0 EA	\$500.00	\$ 0.00	■ Transit Stops - Non Compliant				■ Vegetation Obstruction - Low	8.34% - 10%			
17 Utility Obstruction	0 EA		17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00	■ Railroad Crossings - Compliant				■ Vegetation Obstruction - Overhead	10.01 - 12.5%			
18 Vegetation Obstruction - Low	0 EA		18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00	■ Railroad Crossings - Non Compliant				■ Sidewalk Collection Path	> 12.5%			
19 Vegetation Obstruction - Overhead	1 EA		19 Vegetation Obstruction - Overhead	1 EA	\$150.00	\$ 150.00	■ Accessible Parking - Compliant				■ Adjacent Sidewalk Collection Path				
20 Commercial Entrance	0 EA		20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00	■ Accessible Parking - Non Compliant				■ Buried Sidewalk				
21 Residential Entrance	2 EA		21 Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00					■ Sidewalk Not Surveyed				
22 Total Sidewalk Length Assessed	184.249 LF		22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00					■ Missing Sidewalk Gap				
23 Average Sidewalk Width	48 IN		23 Cross Slope Violations	52.435 SY	\$ 75.00	\$ 3933.00					■ No Sidewalk on Block				
24 No Sidewalk on Block (Approx.)	333.227 LF		24 Running and Cross Slope Violations	0 SY	\$ 75.00	\$ 0.00									
25 Missing Sidewalk Gaps (Approx.)	0 LF		25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00									
26 Poor Surface Condition (Approx.)	0 LF		26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00									
27 Buried Sidewalk (Approx.)	117.18 LF		27 Buried Sidewalk (Approx.)	117.18 LF	\$ 41.67	\$ 4840.00									
Sidewalk SubTotal:						\$ 10183.00									
										*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.					
										**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.					
										***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.					