



| ADA Survey Summary                                                                                                                                                                                                                                                                                                 |                                   |             | ADA Compliance Cost Estimate * |                                               |            |            | Intersection Inventory & Compliance Cost Estimate |                           |             |                     |         |   |                                   |               |                                               |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|-------------|--------------------------------|-----------------------------------------------|------------|------------|---------------------------------------------------|---------------------------|-------------|---------------------|---------|---|-----------------------------------|---------------|-----------------------------------------------|
| Item                                                                                                                                                                                                                                                                                                               | Description                       | Quantity    | Item                           | Description                                   | Quantity   | Unit Price | Item Cost                                         | Item Description          | Total Count | Non Compliant Count | Cost    |   |                                   |               |                                               |
| 1                                                                                                                                                                                                                                                                                                                  | Heavings less than 1"             | 35 EA       | 1                              | Heavings less than 1"                         | 1 EA       | \$ 100.00  | \$ 100.00                                         | Curb Ramps                | 0           | 0                   | \$ 0.00 | ● | Heavings < 1" (Excluded)***       | ●             | Heavings < 1"                                 |
| 2                                                                                                                                                                                                                                                                                                                  | Heavings 1" or greater            | 2 EA        | 2                              | Heavings 1" or greater                        | 1 EA       | \$ 400.00  | \$ 400.00                                         | Island Curb Cuts          | 0           | 0                   | \$ 0.00 | ● | Heavings ≥ 1" (Excluded)***       | ●             | Heavings ≥ 1"                                 |
| 3                                                                                                                                                                                                                                                                                                                  | Uneven Heavings                   | 0 EA        | 3                              | Uneven Heavings                               | 0 EA       | \$ 400.00  | \$ 0.00                                           | Signal Push Buttons       | 0           | 0                   | \$ 0.00 | ● | Uneven Heaving (Excluded)***      | ●             | Uneven Heaving                                |
| 4                                                                                                                                                                                                                                                                                                                  | Heaving Clusters                  | 0 SY        | 4                              | Heaving Clusters                              | 0 SY       | \$ 75.00   | \$ 0.00                                           | Transit Stops             | 0           | 0                   | \$ 0.00 | — | Heaving Clusters (Excluded)       | —             | Heaving Clusters                              |
| 5                                                                                                                                                                                                                                                                                                                  | Sidewalk Joint Gaps               | 0 EA        | 5                              | Sidewalk Joint Gaps                           | 0 EA       | \$ 200.00  | \$ 0.00                                           | Railroad Crossings        | 0           | 0                   | \$ 0.00 | ▲ | Sidewalk Joint Gap (Excluded)***  | ▲             | Sidewalk Joint Gap                            |
| 6                                                                                                                                                                                                                                                                                                                  | Miscellaneous Obstruction         | 0 EA        | 6                              | Miscellaneous Obstruction                     | 0 EA       | \$ 1500.00 | \$ 0.00                                           | Accessible Parking Spaces | 0           | 0                   | \$ 0.00 | ■ | Miscellaneous Obstruction         | ◆             | Commercial Entrance                           |
| 7                                                                                                                                                                                                                                                                                                                  | Missing Sidewalk Obstruction      | 0 EA        | 7                              | Missing Sidewalk Obstruction                  | 0 EA       | \$ 200.00  | \$ 0.00                                           | Intersection SubTotal:    |             |                     | \$ 0.00 | ■ | Missing Sidewalk Obstruction      | ◆             | Residential Entrance                          |
| 8                                                                                                                                                                                                                                                                                                                  | Other Obstruction                 | 0 EA        | 8                              | Other Obstruction                             | 0 EA       | \$ 500.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Other Obstruction                 | ⊕             | Commercial Entrance (within slope violation)  |
| 9                                                                                                                                                                                                                                                                                                                  | Pole Post Hydrant Obstruction     | 0 EA        | 9                              | Pole Post Hydrant Obstruction                 | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |                     |         | ■ | Pole Post Hydrant Obstruction     | ⊕             | Residential Entrance (within slope violation) |
| 10                                                                                                                                                                                                                                                                                                                 | Ponding Obstruction               | 0 EA        | 10                             | Ponding Obstruction                           | 0 EA       | \$ 400.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Ponding Obstruction               |               |                                               |
| 11                                                                                                                                                                                                                                                                                                                 | Sidewalk Joint Obstruction        | 0 EA        | 11                             | Sidewalk Joint Obstruction                    | 0 EA       | \$ 100.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Sidewalk Joint Obstruction        | 2 - 3%        | 7.01 - 8%                                     |
| 12                                                                                                                                                                                                                                                                                                                 | Sign Obstruction                  | 0 EA        | 12                             | Sign Obstruction                              | 0 EA       | \$ 150.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Sign Obstruction                  | 3.01 - 4%     | 8.01 - 9%                                     |
| 13                                                                                                                                                                                                                                                                                                                 | Storm Grate Obstruction           | 0 EA        | 13                             | Storm Grate Obstruction                       | 0 EA       | \$700.00   | \$ 0.00                                           |                           |             |                     |         | ■ | Storm Grate Obstruction           | 4.01 - 5%     | 9.01 - 10%                                    |
| 14                                                                                                                                                                                                                                                                                                                 | Transit Obstruction               | 0 EA        | 14                             | Transit Obstruction                           | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |                     |         | ■ | Transit Obstruction               | 5.01% - 6%    | 10.01 - 12%                                   |
| 15                                                                                                                                                                                                                                                                                                                 | Traffic Obstruction               | 0 EA        | 15                             | Traffic Obstruction                           | 0 EA       | \$2000.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Traffic Obstruction               | 6.01 - 7%     | > 12%                                         |
| 16                                                                                                                                                                                                                                                                                                                 | Tree Obstruction                  | 0 EA        | 16                             | Tree Obstruction                              | 0 EA       | \$500.00   | \$ 0.00                                           |                           |             |                     |         | ■ | Tree Obstruction                  |               |                                               |
| 17                                                                                                                                                                                                                                                                                                                 | Utility Obstruction               | 0 EA        | 17                             | Utility Obstruction                           | 0 EA       | \$1500.00  | \$ 0.00                                           |                           |             |                     |         | ■ | Utility Obstruction               | 5 - 8.33%     |                                               |
| 18                                                                                                                                                                                                                                                                                                                 | Vegetation Obstruction - Low      | 0 EA        | 18                             | Vegetation Obstruction - Low                  | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |                     |         | ■ | Vegetation Obstruction - Low      | 8.34% - 10%   |                                               |
| 19                                                                                                                                                                                                                                                                                                                 | Vegetation Obstruction - Overhead | 0 EA        | 19                             | Vegetation Obstruction - Overhead             | 0 EA       | \$150.00   | \$ 0.00                                           |                           |             |                     |         | ■ | Vegetation Obstruction - Overhead | 10.01 - 12.5% |                                               |
| 20                                                                                                                                                                                                                                                                                                                 | Commercial Entrance               | 0 EA        | 20                             | Commercial Entrance (within slope violation)  | 0 EA       | \$ 5000.00 | \$ 0.00                                           |                           |             |                     |         | — | Sidewalk Collection Path          | > 12.5%       |                                               |
| 21                                                                                                                                                                                                                                                                                                                 | Residential Entrance              | 12 EA       | 21                             | Residential Entrance (within slope violation) | 12 EA      | \$ 3000.00 | \$ 36000.00                                       |                           |             |                     |         | — | Adjacent Sidewalk Collection Path |               |                                               |
| 22                                                                                                                                                                                                                                                                                                                 | Total Sidewalk Length Assessed    | 950.755 LF  | 22                             | Running Slope Violations**                    | 0 SY       | \$ 75.00   | \$ 0.00                                           |                           |             |                     |         | — | Buried Sidewalk                   |               |                                               |
| 23                                                                                                                                                                                                                                                                                                                 | Average Sidewalk Width            | 54 IN       | 23                             | Cross Slope Violations                        | 387.88 SY  | \$ 75.00   | \$ 29091.00                                       |                           |             |                     |         | — | Sidewalk Not Surveyed             |               |                                               |
| 24                                                                                                                                                                                                                                                                                                                 | No Sidewalk on Block (Approx.)    | 1140.162 LF | 24                             | Running and Cross Slope Violations            | 0 SY       | \$ 75.00   | \$ 0.00                                           |                           |             |                     |         | — | Missing Sidewalk Gap              |               |                                               |
| 25                                                                                                                                                                                                                                                                                                                 | Missing Sidewalk Gaps (Approx.)   | 0 LF        | 25                             | Missing Sidewalk Gaps (Approx.)               | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |                     |         | — | No Sidewalk on Block              |               |                                               |
| 26                                                                                                                                                                                                                                                                                                                 | Poor Surface Condition (Approx.)  | 0 LF        | 26                             | Poor Surface Condition (Approx.)              | 0 LF       | \$ 41.67   | \$ 0.00                                           |                           |             |                     |         |   |                                   |               |                                               |
| 27                                                                                                                                                                                                                                                                                                                 | Buried Sidewalk (Approx.)         | 110.447 LF  | 27                             | Buried Sidewalk (Approx.)                     | 110.447 LF | \$ 41.67   | \$ 4620.00                                        |                           |             |                     |         |   |                                   |               |                                               |
|                                                                                                                                                                                                                                                                                                                    |                                   |             | Sidewalk SubTotal:             |                                               |            |            | \$ 65591.00                                       |                           |             |                     |         |   |                                   |               |                                               |
| *Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues. |                                   |             |                                |                                               |            |            |                                                   |                           |             |                     |         |   |                                   |               |                                               |
| **Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.                                                                                                                                                                                                |                                   |             |                                |                                               |            |            |                                                   |                           |             |                     |         |   |                                   |               |                                               |
| ***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.                                                                                                                                                                                    |                                   |             |                                |                                               |            |            |                                                   |                           |             |                     |         |   |                                   |               |                                               |