




ADA Survey Summary		ADA Compliance Cost Estimate *				Intersection Inventory & Compliance Cost Estimate							
Item Description	Quantity	Item Description	Quantity	Unit Price	Item Cost	Item Description	Total Count	Non Compliant Count	Cost	● Heavings < 1" (Excluded)*** ● Heavings ≥ 1" (Excluded)*** ● Uneven Heaving (Excluded)*** — Heaving Clusters (Excluded) ▲ Sidewalk Joint Gap (Excluded)*** ■ Miscellaneous Obstruction ■ Missing Sidewalk Obstruction ■ Other Obstruction ■ Pole Post Hydrant Obstruction ■ Ponding Obstruction ■ Sidewalk Joint Obstruction ■ Sign Obstruction ■ Storm Grate Obstruction ■ Transit Obstruction ■ Traffic Obstruction ■ Tree Obstruction ■ Utility Obstruction ■ Vegetation Obstruction - Low ■ Vegetation Obstruction - Overhead — Sidewalk Collection Path — Adjacent Sidewalk Collection Path — Buried Sidewalk — Sidewalk Not Surveyed — Missing Sidewalk Gap — No Sidewalk on Block ● Heavings < 1" ● Heavings ≥ 1" ● Uneven Heaving — Heaving Clusters ▲ Sidewalk Joint Gap ◆ Commercial Entrance ◆ Residential Entrance ✚ Commercial Entrance (within slope violation) ✚ Residential Entrance (within slope violation) Cross Slope 2 - 3% 3.01 - 4% 4.01 - 5% 5.01% - 6% 6.01 - 7% 7.01 - 8% 8.01 - 9% 9.01 - 10% 10.01 - 12% > 12% Running Slope 5 - 8.33% 8.34% - 10% 10.01 - 12.5% > 12.5% <td rowspan="28"> ■ Curb Ramps - Compliant ■ Curb Ramps - Non Compliant ■ Island Curb Cuts - Compliant ■ Island Curb Cuts - Non Compliant ■ Signals - Compliant ■ Signals - Non Compliant ■ Transit Stops - Compliant ■ Transit Stops - Non Compliant ■ Railroad Crossings - Compliant ■ Railroad Crossings - Non Compliant ■ Accessible Parking - Compliant ■ Accessible Parking - Non Compliant ■ Curb Ramps - Adjacent ■ Island Curb Cuts - Adjacent ■ Signals - Adjacent ■ Transit Stops - Adjacent ■ Railroad Crossings - Adjacent ■ Accessible Parking - Adjacent </td>	■ Curb Ramps - Compliant ■ Curb Ramps - Non Compliant ■ Island Curb Cuts - Compliant ■ Island Curb Cuts - Non Compliant ■ Signals - Compliant ■ Signals - Non Compliant ■ Transit Stops - Compliant ■ Transit Stops - Non Compliant ■ Railroad Crossings - Compliant ■ Railroad Crossings - Non Compliant ■ Accessible Parking - Compliant ■ Accessible Parking - Non Compliant ■ Curb Ramps - Adjacent ■ Island Curb Cuts - Adjacent ■ Signals - Adjacent ■ Transit Stops - Adjacent ■ Railroad Crossings - Adjacent ■ Accessible Parking - Adjacent		
1 Heavings less than 1"	6 EA	1 Heavings less than 1"	4 EA	\$ 100.00	\$ 400.00	Curb Ramps	1	1	\$ 1500.00				
2 Heavings 1" or greater	0 EA	2 Heavings 1" or greater	0 EA	\$ 400.00	\$ 0.00	Island Curb Cuts	0	0	\$ 0.00				
3 Uneven Heavings	0 EA	3 Uneven Heavings	0 EA	\$ 400.00	\$ 0.00	Signal Push Buttons	0	0	\$ 0.00				
4 Heaving Clusters	0 SY	4 Heaving Clusters	0 SY	\$ 75.00	\$ 0.00	Transit Stops	0	0	\$ 0.00				
5 Sidewalk Joint Gaps	0 EA	5 Sidewalk Joint Gaps	0 EA	\$ 200.00	\$ 0.00	Railroad Crossings	0	0	\$ 0.00				
6 Miscellaneous Obstruction	0 EA	6 Miscellaneous Obstruction	0 EA	\$ 1500.00	\$ 0.00	Accessible Parking Spaces	0	0	\$ 0.00				
7 Missing Sidewalk Obstruction	0 EA	7 Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$ 0.00	Intersection SubTotal:			\$ 1500.00				
8 Other Obstruction	0 EA	8 Other Obstruction	0 EA	\$ 500.00	\$ 0.00	Corridor Total:				\$ 17073.00			
9 Pole Post Hydrant Obstruction	0 EA	9 Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$ 0.00								
10 Ponding Obstruction	0 EA	10 Ponding Obstruction	0 EA	\$ 400.00	\$ 0.00								
11 Sidewalk Joint Obstruction	0 EA	11 Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$ 0.00								
12 Sign Obstruction	0 EA	12 Sign Obstruction	0 EA	\$ 150.00	\$ 0.00								
13 Storm Grate Obstruction	0 EA	13 Storm Grate Obstruction	0 EA	\$700.00	\$ 0.00								
14 Transit Obstruction	0 EA	14 Transit Obstruction	0 EA	\$500.00	\$ 0.00								
15 Traffic Obstruction	0 EA	15 Traffic Obstruction	0 EA	\$2000.00	\$ 0.00								
16 Tree Obstruction	0 EA	16 Tree Obstruction	0 EA	\$500.00	\$ 0.00								
17 Utility Obstruction	0 EA	17 Utility Obstruction	0 EA	\$1500.00	\$ 0.00								
18 Vegetation Obstruction - Low	0 EA	18 Vegetation Obstruction - Low	0 EA	\$150.00	\$ 0.00								
19 Vegetation Obstruction - Overhead	0 EA	19 Vegetation Obstruction - Overhead	0 EA	\$150.00	\$ 0.00								
20 Commercial Entrance	0 EA	20 Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$ 0.00								
21 Residential Entrance	3 EA	21 Residential Entrance (within slope violation)	2 EA	\$ 3000.00	\$ 6000.00								
22 Total Sidewalk Length Assessed	325.595 LF	22 Running Slope Violations**	0 SY	\$ 75.00	\$ 0.00								
23 Average Sidewalk Width	48 IN	23 Cross Slope Violations	35.905 SY	\$ 75.00	\$ 2693.00								
24 No Sidewalk on Block (Approx.)	333.469 LF	24 Running and Cross Slope Violations	86.398 SY	\$ 75.00	\$ 6480.00								
25 Missing Sidewalk Gaps (Approx.)	0 LF	25 Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$ 0.00								
26 Poor Surface Condition (Approx.)	0 LF	26 Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$ 0.00								
27 Buried Sidewalk (Approx.)	0 LF	27 Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$ 0.00								
Sidewalk SubTotal:					\$ 15573.00								

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.