




ADA Survey Summary			ADA Compliance Cost Estimate *			Intersection Inventory & Compliance Cost Estimate							
Item	Description	Quantity	Item	Description	Quantity	Unit Price	Item	Description	Total Count	Non Compliant Count	Cost		
1	Heavings less than 1"	1 EA	1	Heavings less than 1"	1 EA	\$ 100.00	\$	100.00	Curb Ramps	1	1	\$	1850.00
2	Heavings 1" or greater	0 EA	2	Heavings 1" or greater	0 EA	\$ 400.00	\$	0.00	Island Curb Cuts	0	0	\$	0.00
3	Uneven Heavings	0 EA	3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00	Signal Push Buttons	0	0	\$	0.00
4	Heaving Clusters	0 SY	4	Heaving Clusters	0 SY	\$ 75.00	\$	0.00	Transit Stops	0	0	\$	0.00
5	Sidewalk Joint Gaps	0 EA	5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00	Railroad Crossings	0	0	\$	0.00
6	Miscellaneous Obstruction	0 EA	6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00	Accessible Parking Spaces	0	0	\$	0.00
7	Missing Sidewalk Obstruction	0 EA	7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00	Intersection SubTotal:			\$	1850.00
8	Other Obstruction	0 EA	8	Other Obstruction	0 EA	\$ 500.00	\$	0.00	Corridor Total:				\$ 21768.00
9	Pole Post Hydrant Obstruction	0 EA	9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00	 Curb Ramps - Compliant	 Curb Ramps - Adjacent			
10	Ponding Obstruction	0 EA	10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00	 Curb Ramps - Non Compliant	 Island Curb Cuts - Adjacent			
11	Sidewalk Joint Obstruction	0 EA	11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00	 Island Curb Cuts - Compliant	 Island Curb Cuts - Adjacent			
12	Sign Obstruction	0 EA	12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00	 Island Curb Cuts - Non Compliant	 Signals - Adjacent			
13	Storm Grate Obstruction	0 EA	13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00	 Signals - Compliant	 Transit Stops - Adjacent			
14	Transit Obstruction	0 EA	14	Transit Obstruction	0 EA	\$500.00	\$	0.00	 Signals - Non Compliant	 Transit Stops - Non Compliant			
15	Traffic Obstruction	0 EA	15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00	 Transit Stops - Compliant	 Railroad Crossings - Adjacent			
16	Tree Obstruction	0 EA	16	Tree Obstruction	0 EA	\$500.00	\$	0.00	 Transit Stops - Non Compliant	 Accessible Parking - Adjacent			
17	Utility Obstruction	0 EA	17	Utility Obstruction	0 EA	\$1500.00	\$	0.00	 Railroad Crossings - Compliant				
18	Vegetation Obstruction - Low	0 EA	18	Vegetation Obstruction - Low	0 EA	\$150.00	\$	0.00	 Railroad Crossings - Non Compliant				
19	Vegetation Obstruction - Overhead	1 EA	19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$	150.00	 Accessible Parking - Compliant				
20	Commercial Entrance	0 EA	20	Commercial Entrance (within slope violation)	0 EA	\$ 5000.00	\$	0.00	 Accessible Parking - Non Compliant				
21	Residential Entrance	0 EA	21	Residential Entrance (within slope violation)	0 EA	\$ 3000.00	\$	0.00					
22	Total Sidewalk Length Assessed	616.407 LF	22	Running Slope Violations**	0 SY	\$ 75.00	\$	0.00					
23	Average Sidewalk Width	75.429 IN	23	Cross Slope Violations	256.32 SY	\$ 75.00	\$	19224.00					
24	No Sidewalk on Block (Approx.)	0 LF	24	Running and Cross Slope Violations	5.923 SY	\$ 75.00	\$	444.00					
25	Missing Sidewalk Gaps (Approx.)	0 LF	25	Missing Sidewalk Gaps (Approx.)	0 LF	\$ 41.67	\$	0.00					
26	Poor Surface Condition (Approx.)	0 LF	26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00					
27	Buried Sidewalk (Approx.)	30.778 LF	27	Buried Sidewalk (Approx.)	30.778 LF	\$ 41.67	\$	1320.00					
			Sidewalk SubTotal:					\$	19918.00				

●

 Heavings < 1" (Excluded)***

●

 Heavings ≥ 1" (Excluded)***

●

 Uneven Heaving (Excluded)***

●

 Heaving Clusters (Excluded)

▲

 Sidewalk Joint Gap (Excluded)***

■

 Miscellaneous Obstruction

■

 Missing Sidewalk Obstruction

■

 Other Obstruction

■

 Pole Post Hydrant Obstruction

■

 Ponding Obstruction

■

 Sidewalk Joint Obstruction

■

 Sign Obstruction

■

 Storm Grate Obstruction

■

 Transit Obstruction

■

 Traffic Obstruction

■

 Tree Obstruction

■

 Utility Obstruction

■

 Vegetation Obstruction - Low

■

 Vegetation Obstruction - Overhead

■

 Sidewalk Collection Path

■

 Adjacent Sidewalk Collection Path

■

 Buried Sidewalk

■

 Sidewalk Not Surveyed

■

 Missing Sidewalk Gap

■

 No Sidewalk on Block

●

 Heavings < 1"

●

 Heavings ≥ 1"

●

 Uneven Heaving

●

 Heaving Clusters

▲

 Sidewalk Joint Gap

◆

 Commercial Entrance

◆

 Residential Entrance

⊕

 Commercial Entrance (within slope violation)

⊕

 Residential Entrance (within slope violation)

Cross Slope

■

 2 - 3%

■

 7.01 - 8%

■

 3.01 - 4%

■

 8.01 - 9%

■

 4.01 - 5%

■

 9.01 - 10%

■

 5.01% - 6%

■

 10.01 - 12%

■

 6.01 - 7%

■

 > 12%

Running Slope

■

 5 - 8.33%

■

 8.34% - 10%

■

 10.01 - 12.5%

■

 > 12.5%

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

●

 Heavings < 1" (Excluded)***

●

 Heavings ≥ 1" (Excluded)***

●

 Uneven Heaving (Excluded)***

●

 Heaving Clusters (Excluded)

▲

 Sidewalk Joint Gap (Excluded)***

■

 Miscellaneous Obstruction

■

 Missing Sidewalk Obstruction

■

 Other Obstruction

■

 Pole Post Hydrant Obstruction

■

 Ponding Obstruction

■

 Sidewalk Joint Obstruction

■

 Sign Obstruction

■

 Storm Grate Obstruction

■

 Transit Obstruction

■

 Traffic Obstruction

■

 Tree Obstruction

■

 Utility Obstruction

■

 Vegetation Obstruction - Low

■

 Vegetation Obstruction - Overhead

■

 Sidewalk Collection Path

■

 Adjacent Sidewalk Collection Path

■

 Buried Sidewalk

■

 Sidewalk Not Surveyed

■

 Missing Sidewalk Gap

■

 No Sidewalk on Block

●

 Heavings < 1"

●

 Heavings ≥ 1"

●

 Uneven Heaving

●

 Heaving Clusters

▲

 Sidewalk Joint Gap

◆

 Commercial Entrance

◆

 Residential Entrance

■

 Commercial Entrance (within slope violation)

■

 Residential Entrance (within slope violation)

■

 Cross Slope

■

 Running Slope

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.