
Access Compliance Report - Public Rights-of-Way (Corridor: Sidewalk & Intersection Items)

Corridor ID: RUNNING-BROOK-RD-030





ADA Survey Summary				
Item Description	Quantity			
1 Heavings less than 1"	12 EA			
2 Heavings 1" or greater	2 EA			
3 Uneven Heavings	0 EA			
4 Heaving Clusters	8.89 SY			
5 Sidewalk Joint Gaps	0 EA			
6 Miscellaneous Obstruction	0 EA			
7 Missing Sidewalk Obstruction	0 EA			
8 Other Obstruction	0 EA			
9 Pole Post Hydrant Obstruction	0 EA			
10 Ponding Obstruction	0 EA			
11 Sidewalk Joint Obstruction	0 EA			
12 Sign Obstruction	0 EA			
13 Storm Grate Obstruction	0 EA			
14 Transit Obstruction	0 EA			
15 Traffic Obstruction	0 EA			
16 Tree Obstruction	0 EA			
17 Utility Obstruction	0 EA			
18 Vegetation Obstruction - Low	1 EA			
19 Vegetation Obstruction - Overhead	1 EA			
20 Commercial Entrance	0 EA			
21 Residential Entrance	9 EA			
22 Total Sidewalk Length Assessed	658.943 LF			
23 Average Sidewalk Width	48 IN			
24 No Sidewalk on Block (Approx.)	779.913 LF			
25 Missing Sidewalk Gaps (Approx.)	101.811 LF			
26 Poor Surface Condition (Approx.)	0 LF			
27 Buried Sidewalk (Approx.)	0 LF			

	ADA COIII	pilatice cos	t LStilliate		
Ite	m Description	Quantity	Unit Price	lt	em Cost
1_	Heavings less than 1"	6 EA	\$ 100.00	\$	600.00
2	Heavings 1" or greater	2 EA	\$ 400.00	\$	800.00
3	Uneven Heavings	0 EA	\$ 400.00	\$	0.00
4	Heaving Clusters	1.787 SY	\$ 75.00	\$	134.00
5	Sidewalk Joint Gaps	0 EA	\$ 200.00	\$	0.00
6	Miscellaneous Obstruction	0 EA	\$ 1500.00	\$	0.00
7	Missing Sidewalk Obstruction	0 EA	\$ 200.00	\$	0.00
8	Other Obstruction	0 EA	\$ 500.00	\$	0.00
9	Pole Post Hydrant Obstruction	0 EA	\$ 5000.00	\$	0.00
10	Ponding Obstruction	0 EA	\$ 400.00	\$	0.00
11	Sidewalk Joint Obstruction	0 EA	\$ 100.00	\$	0.00
12	Sign Obstruction	0 EA	\$ 150.00	\$	0.00
13	Storm Grate Obstruction	0 EA	\$700.00	\$	0.00
14	Transit Obstruction	0 EA	\$500.00	\$	0.00
15	Traffic Obstruction	0 EA	\$2000.00	\$	0.00
16	Tree Obstruction	0 EA	\$500.00	\$	0.00
17	Utility Obstruction	0 EA	\$1500.00	\$	0.00
18	Vegetation Obstruction - Low	1 EA	\$150.00	\$	150.00
19	Vegetation Obstruction - Overhead	1 EA	\$150.00	\$	150.00
20	Commercial Entrance (within slope viol	ation) 0 EA	\$ 5000.00	\$	0.00
21	Residential Entrance (within slope viola	tion) 7 EA	\$ 3000.00	\$	21000.00
22	Running Slope Violations**	3.951 SY	\$ 75.00	\$	296.00
23	Cross Slope Violations	90.859 SY	\$ 75.00	\$	6814.00
24	Running and Cross Slope Violations	27.487 SY	\$ 75.00	\$	2062.00
25	Missing Sidewalk Gaps (Approx.)	101.811 LF	\$ 41.67	\$	4180.00
26	Poor Surface Condition (Approx.)	0 LF	\$ 41.67	\$	0.00
27	Buried Sidewalk (Approx.)	0 LF	\$ 41.67	\$	0.00
	Sidewalk SubTotal:			\$	32006.00

Intersection In	ventory & 0	Compliance	Cost Es	timate
-----------------	-------------	------------	---------	--------

Item Description	Total Count	Non Compliant Count	Cost
Curb Ramps	3	3	\$ 6900.00
Island Curb Cuts	0	0	\$ 0.00
Signal Push Buttons	0	0	\$ 0.00
Transit Stops	0	0	\$ 0.00
Railroad Crossings	0	0	\$ 0.00
Accessible Parking Spa	ices 0	0	\$ 0.00
Intersection SubTotal:	<u> </u>	\$	6900.00

ġ.	Curb Ramps - Compliant	Ġ.	Curb Ramps - Adjacent
Ł	Curb Ramps - Non Compliant		
•	Island Curb Cuts - Compliant	4	Island Curb Cuts - Adjac
•	Island Curb Cuts - Non Compliant		
#	Signals - Compliant	#	Signals - Adjacent
#	Signals - Non Compliant		
	Transit Stops - Compliant		Transit Stops - Adjacent
	Transit Stops - Non Compliant		
※	Railroad Crossings - Compliant	©	Railroad Crossings - Adj

Railroad Crossings - Non Compliant Accessible Parking - Compliant Accessible Parking - Non Compliant

Island Curb Cuts - Adjacent	
Signals - Adjacent	
Transit Stops - Adjacent	
Railroad Crossings - Adjacent	_
Accessible Parking - Adjacent	

	Heavings < 1" (Excluded)***	0	Heavings < 1"
	Heavings ≥ 1" (Excluded)***	•	Heavings ≥ 1"
	Uneven Heaving (Excluded)***	•	Uneven Heaving
-	Heaving Clusters (Excluded)		Heaving Clusters
	Sidewalk Joint Gap (Excluded)***	_	Sidewalk Joint Gap
	Miscellaneous Obstruction	•	Commercial Entrance
	Missing Sidewalk Obstruction	•	Residential Entrance
	Other Obstruction	+	Commercial Entrance (within slope violation)
	Pole Post Hydrant Obstruction	4	Residential Entrance (within slope violation)
	Ponding Obstruction	Cros	ss Slope
	Sidewalk Joint Obstruction		2 - 3% 7.01 - 8%
	Sign Obstruction		3.01 - 4% 8.01 - 9%
	Storm Grate Obstruction		4.01 - 5% 9.01 - 10%
	Transit Obstruction		5.01% - 6% 10.01 - 12%
	Traffic Obstruction		6.01 - 7% > 12%
	Tree Obstruction	Run	ning Slope
	Utility Obstruction		5 - 8.33%
	Vegetation Obstruction - Low		8.34% - 10%
	Vegetation Obstruction - Overhead		10.01 - 12.5%
•	Sidewalk Collection Path		> 12.5%
-	Adjacent Sidewalk Collection Path		
•	Buried Sidewalk		
•	Sidewalk Not Surveyed		
-	Missing Sidewalk Gap		
	No Sidewalk on Block		

*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

**Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

***Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.