



| ADA Survey Summary |                                   |          | ADA Compliance Cost Estimate * |                                               |          | Intersection Inventory & Compliance Cost Estimate |            |                           |             |                     |         |                                     |                                                 |                      |
|--------------------|-----------------------------------|----------|--------------------------------|-----------------------------------------------|----------|---------------------------------------------------|------------|---------------------------|-------------|---------------------|---------|-------------------------------------|-------------------------------------------------|----------------------|
| Item               | Description                       | Quantity | Item                           | Description                                   | Quantity | Unit Price                                        | Item Cost  | Item Description          | Total Count | Non Compliant Count | Cost    |                                     |                                                 |                      |
| 1                  | Heavings less than 1"             | 0 EA     | 1                              | Heavings less than 1"                         | 0 EA     | \$ 100.00                                         | \$ 0.00    | Curb Ramps                | 0           | 0                   | \$ 0.00 | ● Heavings < 1" (Excluded)***       | ● Heavings < 1"                                 |                      |
| 2                  | Heavings 1" or greater            | 0 EA     | 2                              | Heavings 1" or greater                        | 0 EA     | \$ 400.00                                         | \$ 0.00    | Island Curb Cuts          | 0           | 0                   | \$ 0.00 | ● Heavings ≥ 1" (Excluded)***       | ● Heavings ≥ 1"                                 |                      |
| 3                  | Uneven Heavings                   | 0 EA     | 3                              | Uneven Heavings                               | 0 EA     | \$ 400.00                                         | \$ 0.00    | Signal Push Buttons       | 0           | 0                   | \$ 0.00 | ● Uneven Heaving (Excluded)***      | ● Uneven Heaving                                |                      |
| 4                  | Heaving Clusters                  | 0 SY     | 4                              | Heaving Clusters                              | 0 SY     | \$ 75.00                                          | \$ 0.00    | Transit Stops             | 0           | 0                   | \$ 0.00 | — Heaving Clusters (Excluded)       | — Heaving Clusters                              |                      |
| 5                  | Sidewalk Joint Gaps               | 0 EA     | 5                              | Sidewalk Joint Gaps                           | 0 EA     | \$ 200.00                                         | \$ 0.00    | Railroad Crossings        | 0           | 0                   | \$ 0.00 | ▲ Sidewalk Joint Gap (Excluded)***  | ▲ Sidewalk Joint Gap                            |                      |
| 6                  | Miscellaneous Obstruction         | 0 EA     | 6                              | Miscellaneous Obstruction                     | 0 EA     | \$ 1500.00                                        | \$ 0.00    | Accessible Parking Spaces | 0           | 0                   | \$ 0.00 | ■ Miscellaneous Obstruction         | ◆ Commercial Entrance                           |                      |
| 7                  | Missing Sidewalk Obstruction      | 0 EA     | 7                              | Missing Sidewalk Obstruction                  | 0 EA     | \$ 200.00                                         | \$ 0.00    | Intersection SubTotal:    |             | \$ 0.00             |         | ■ Missing Sidewalk Obstruction      | ◆ Residential Entrance                          |                      |
| 8                  | Other Obstruction                 | 0 EA     | 8                              | Other Obstruction                             | 0 EA     | \$ 500.00                                         | \$ 0.00    |                           |             |                     |         | ■ Other Obstruction                 | ✚ Commercial Entrance (within slope violation)  |                      |
| 9                  | Pole Post Hydrant Obstruction     | 0 EA     | 9                              | Pole Post Hydrant Obstruction                 | 0 EA     | \$ 5000.00                                        | \$ 0.00    |                           |             |                     |         | ■ Pole Post Hydrant Obstruction     | ✚ Residential Entrance (within slope violation) |                      |
| 10                 | Ponding Obstruction               | 0 EA     | 10                             | Ponding Obstruction                           | 0 EA     | \$ 400.00                                         | \$ 0.00    |                           |             |                     |         | ■ Ponding Obstruction               |                                                 |                      |
| 11                 | Sidewalk Joint Obstruction        | 0 EA     | 11                             | Sidewalk Joint Obstruction                    | 0 EA     | \$ 100.00                                         | \$ 0.00    |                           |             |                     |         | ■ Sidewalk Joint Obstruction        | <b>Cross Slope</b>                              |                      |
| 12                 | Sign Obstruction                  | 0 EA     | 12                             | Sign Obstruction                              | 0 EA     | \$ 150.00                                         | \$ 0.00    |                           |             |                     |         | ■ Sign Obstruction                  | 2 - 3%                                          | 7.01 - 8%            |
| 13                 | Storm Grate Obstruction           | 0 EA     | 13                             | Storm Grate Obstruction                       | 0 EA     | \$700.00                                          | \$ 0.00    |                           |             |                     |         | ■ Storm Grate Obstruction           | 3.01 - 4%                                       | 8.01 - 9%            |
| 14                 | Transit Obstruction               | 0 EA     | 14                             | Transit Obstruction                           | 0 EA     | \$500.00                                          | \$ 0.00    |                           |             |                     |         | ■ Transit Obstruction               | 4.01 - 5%                                       | 9.01 - 10%           |
| 15                 | Traffic Obstruction               | 0 EA     | 15                             | Traffic Obstruction                           | 0 EA     | \$2000.00                                         | \$ 0.00    |                           |             |                     |         | ■ Traffic Obstruction               | 5.01% - 6%                                      | 10.01 - 12%          |
| 16                 | Tree Obstruction                  | 0 EA     | 16                             | Tree Obstruction                              | 0 EA     | \$500.00                                          | \$ 0.00    |                           |             |                     |         | ■ Tree Obstruction                  | 6.01 - 7%                                       | > 12%                |
| 17                 | Utility Obstruction               | 0 EA     | 17                             | Utility Obstruction                           | 0 EA     | \$1500.00                                         | \$ 0.00    |                           |             |                     |         | ■ Utility Obstruction               |                                                 | <b>Running Slope</b> |
| 18                 | Vegetation Obstruction - Low      | 0 EA     | 18                             | Vegetation Obstruction - Low                  | 0 EA     | \$150.00                                          | \$ 0.00    |                           |             |                     |         | ■ Vegetation Obstruction - Low      | 5 - 8.33%                                       |                      |
| 19                 | Vegetation Obstruction - Overhead | 0 EA     | 19                             | Vegetation Obstruction - Overhead             | 0 EA     | \$150.00                                          | \$ 0.00    |                           |             |                     |         | ■ Vegetation Obstruction - Overhead | 8.34% - 10%                                     |                      |
| 20                 | Commercial Entrance               | 0 EA     | 20                             | Commercial Entrance (within slope violation)  | 0 EA     | \$ 5000.00                                        | \$ 0.00    |                           |             |                     |         | — Sidewalk Collection Path          | 10.01 - 12.5%                                   |                      |
| 21                 | Residential Entrance              | 0 EA     | 21                             | Residential Entrance (within slope violation) | 0 EA     | \$ 3000.00                                        | \$ 0.00    |                           |             |                     |         | — Adjacent Sidewalk Collection Path | > 12.5%                                         |                      |
| 22                 | Total Sidewalk Length Assessed    | 0 LF     | 22                             | Running Slope Violations**                    | 0 SY     | \$ 75.00                                          | \$ 0.00    |                           |             |                     |         | — Buried Sidewalk                   |                                                 |                      |
| 23                 | Average Sidewalk Width            | 0 IN     | 23                             | Cross Slope Violations                        | 0 SY     | \$ 75.00                                          | \$ 0.00    |                           |             |                     |         | — Sidewalk Not Surveyed             |                                                 |                      |
| 24                 | No Sidewalk on Block (Approx.)    | 0 LF     | 24                             | Running and Cross Slope Violations            | 0 SY     | \$ 75.00                                          | \$ 0.00    |                           |             |                     |         | — Missing Sidewalk Gap              |                                                 |                      |
| 25                 | Missing Sidewalk Gaps (Approx.)   | 0 LF     | 25                             | Missing Sidewalk Gaps (Approx.)               | 0 LF     | \$ 41.67                                          | \$ 0.00    |                           |             |                     |         | — No Sidewalk on Block              |                                                 |                      |
| 26                 | Poor Surface Condition (Approx.)  | 0 LF     | 26                             | Poor Surface Condition (Approx.)              | 0 LF     | \$ 41.67                                          | \$ 0.00    |                           |             |                     |         |                                     |                                                 |                      |
| 27                 | Buried Sidewalk (Approx.)         | 45.57 LF | 27                             | Buried Sidewalk (Approx.)                     | 45.57 LF | \$ 41.67                                          | \$ 1980.00 |                           |             |                     |         |                                     |                                                 |                      |
|                    |                                   |          |                                | Sidewalk SubTotal:                            |          |                                                   | \$ 0.00    |                           |             |                     |         |                                     |                                                 |                      |

Corridor Total:

\$ 0.00

■ Curb Ramps - Compliant

■ Curb Ramps - Non Compliant

▲ Island Curb Cuts - Compliant

▲ Island Curb Cuts - Non Compliant

📶 Signals - Compliant

📶 Signals - Non Compliant

📶 Transit Stops - Compliant

📶 Transit Stops - Non Compliant

🚶 Railroad Crossings - Compliant

🚶 Railroad Crossings - Non Compliant

♿ Accessible Parking - Compliant

♿ Accessible Parking - Non Compliant

■ Curb Ramps - Adjacent

▲ Island Curb Cuts - Adjacent

📶 Signals - Adjacent

📶 Transit Stops - Adjacent

🚶 Railroad Crossings - Adjacent

♿ Accessible Parking - Adjacent

● Heavings < 1" (Excluded)\*\*\*

● Heavings ≥ 1" (Excluded)\*\*\*

● Uneven Heaving (Excluded)\*\*\*

— Heaving Clusters (Excluded)

▲ Sidewalk Joint Gap (Excluded)\*\*\*

■ Miscellaneous Obstruction

■ Missing Sidewalk Obstruction

■ Other Obstruction

■ Pole Post Hydrant Obstruction

■ Ponding Obstruction

■ Sidewalk Joint Obstruction

■ Sign Obstruction

■ Storm Grate Obstruction

■ Transit Obstruction

■ Traffic Obstruction

■ Tree Obstruction

■ Utility Obstruction

■ Vegetation Obstruction - Low

■ Vegetation Obstruction - Overhead

— Sidewalk Collection Path

— Adjacent Sidewalk Collection Path

— Buried Sidewalk

— Sidewalk Not Surveyed

— Missing Sidewalk Gap

— No Sidewalk on Block

● Heavings < 1"

● Heavings ≥ 1"

● Uneven Heaving

— Heaving Clusters

▲ Sidewalk Joint Gap

◆ Commercial Entrance

◆ Residential Entrance

✚ Commercial Entrance (within slope violation)

✚ Residential Entrance (within slope violation)

**Cross Slope**

2 - 3%

3.01 - 4%

4.01 - 5%

5.01% - 6%

6.01 - 7%

7.01 - 8%

8.01 - 9%

9.01 - 10%

10.01 - 12%

> 12%

**Running Slope**

5 - 8.33%

8.34% - 10%

10.01 - 12.5%

> 12.5%

\*Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.

\*\*Note: Additional investigation may be warranted when sidewalk running slope issues exist within the right-of-way.

\*\*\*Note: Excluded items are violations that occur in areas with slope violations and have been excluded from the cost estimate.